



Level



Pressure



Flow



Temperature

Liquid
Analysis

Registration

Systems
Components

Services



Solutions

Manufacturer Information

for users regarding software updates
(following the NAMUR recommendation 53)

1. Type of device

- ☒ Field device / signal processing device
- ☐ Monitoring- / operation system / hand held terminal etc.
- ☐ Modem / interface

Manufacturer : Endress+Hauser Flowtec AG

Device : Magnetic Inductive Flow Measuring System

Type : Promag 50 PROFIBUS PA (0x1525)

Order code : 50***_*****H

2. Software

Previous firmware version : 3.05.00

New firmware version : 3.06.01

How can the previous firmware version be identified? :

- Local display
- Nameplate for connections
- Configuration and service software e.g. FieldCare

Description of the modifications in comparison to the previous firmware version :

- Fixed the cyclic data exchange problem caused by telegram lengths longer than 84 bytes
- Added a second totalizer to the Promag 50

3. Compatibility

Is the operating tool compatible with the installed device firmware?

- ☐ Yes
- ☒ No, description:

An update of the DD's (device description) is required for all operating tools in use.

