

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Endress+Hauser

Kaegenstrasse 7, CH-4153 Reinach, Switzerland

the Certificate No: **Z01804** for the PROFIBUS Device:

Model Name: Promag 100 DP
Revision: Profile 3.02; SW/FW: All; HW: All
GSD: EH3x1560.GSD, File Version: 1.0
PA039740.GSD

This certificate confirms that the product has successfully passed the certification tests with the following scope:

☒	DP-V0	MS0, Sync, Freeze, Set_Slave_Add
☒	DP-V1	MS1, Prm_Block_Structure, MS2, I&M
☒	Profile	PROFIBUS PA 3.02
☒	Physical Layer	RS485

Test Report Number: AIS 3017 PA 01
Authorized Test Laboratory: AIS, Munich, Germany

The tests were executed in accordance with the following documents:
"Test Specifications for PROFIBUS DP Slaves, Version 3.0.9, September 2008" and
"Test Specifications for PROFIBUS PA Profile 3.0.2, Version 5.0.4, February 2010".

This certificate is granted according to the document:
"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by October 31, 2016 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)



(K.-P. Lindner)