



Certificate of Compliance

Certificate: 1355390

Master Contract: 200600

Project: 70046585

Date Issued: 2015-10-13

Issued to: Endress + Hauser Wetzer GmbH Co. KG
Obere Wank 1
Nesselwang, 87484
GERMANY
Attention: Michael Pfanzelt

The products listed below are eligible to bear the CSA Mark shown



Issued by: Eshwar Kashyap
Eshwar Kashyap

PRODUCTS

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations

Class I, Div. 1 and 2, Groups A, B, C, and D:

- Type TMT 121(7) (8) Transmitter. Input 12 - 30 V, output 4 - 20 mA. Intrinsically Safe when connected per Drawing 14 10 01 112A and having the following entity parameter, $V_{max} = 30$ V, $I_{max} = 100$ mA, $C_i = 0$, $L_i = 0$. Temperature Code T6 at 50°C, T5 at 65°C, and T4 at 85°C.

- TMT 122 Temperature Transmitter. Input 12 - 30 V, output 4 - 20 mA. Intrinsically Safe when connected per Drawing 14 14 01 112A and having the following entity parameter, $V_{max} = 30$ V, $I_{max} = 100$ mA, $C_i = 0$, $L_i = 0$. Temperature Code T6 at 55°C, T5 at 70°C, and T4 at 85°C.

Note: These transmitters are certified as components for use in a suitable enclosure where the final combination is subject to the approval of the local inspection authority.



Certificate: 1355390
Project: 70046585

Master Contract: 200600
Date Issued: 2015-10-13

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 2, Groups A, B, C, and D:

- Type TMT 121(7) (8) Transmitter. Input 12 - 30 V, output 4 - 20 mA. Temperature Code T6 at 50°C, T5 at 65°C, and T4 at 85°C.

- TMT 122 Temperature Transmitter. Input 12 - 30 V, output 4 - 20 mA. Temperature Code T6 at 55°C, T5 at 70°C, and T4 at 85°C.

Note: These transmitters are certified as components for use in a suitable enclosure where the final combination is subject to the approval of the local inspection authority.

CLASS 2252 03 - PROCESS CONTROL EQUIPMENT

- Type TMT 121(7) (8) Transmitter. SELV or Class 2 supply input 12 - 35 V, output 4 - 20 mA.

- TMT 122 Temperature Transmitter. SELV or Class 2 supply input 12 - 35 V, output 4 - 20 mA.

Note: These transmitters are certified as components for use in a suitable enclosure where the final combination is subject to the approval of the local inspection authority.

APPLICABLE REQUIREMENTS

- | | | |
|--|---|--|
| CSA Std C22.2 No. 142-M1987 | - | Process Control Equipment |
| CAN/CSA-C22.2 No. 157-92 | - | Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations |
| CSA Std C22.2 No. 213-M1987 | - | Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations |
| CAN/CSA-C22.2 No. 1010.1-92.
Amends 1 and 2 | - | Safety Requirements For Electrical Equipment For Measurement, Control and laboratory Use: PART 1 General requirements. |



Supplement to Certificate of Compliance

Certificate: 1355390

Master Contract: 200600

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70046585	2015-10-13	Update to include several minor drawing changes.
1613884	2004-11-15	Update to Cover Temperature Rating Correction
1572041	2004-07-30	Update to include C22.2 No. 1010.1-92 for installation in ordinary locations.
1496078	2003-11-12	Update to cover nameplate dwgs revision.
1449080	2003-06-24	Update to cover minor alterations and dwgs revisions.
1355390	2002-11-21	Original certification.