

SIL-11001

SIL Declaration of Conformity

Functional Safety according to IEC 61508

Endress+Hauser Yamanashi Co., Ltd.

862-1 Mitsukunugi, Sakaigawa-cho, Fuefuki-shi,
Yamanashi Prefecture, 406-0846 Japan

Declares as manufacturer, that the level gauge

Proservo NMS


is suitable for the use in safety-instrumented system according to IEC 61508 / IEC 61511, if the functional safety manual SD00337G/08 and following characteristics are observed:

Product	Analogue output 4 to 20 mA	Alarm relay contact output
Safety functions	Level Range, Error related to level measurement	Level MAX, Level MIN, Error related to level measurement
SIL ³⁾	2	
HFT	0	
Device type	Type B	
SFF	94%	95%
PFD _{avg} (T _i = 1 year)	3.63×10^{-4}	2.71×10^{-4}
Proof test interval	Recommended: 2 year	
λ_s ¹⁾	679.19 FIT	635.33 FIT
λ_D ¹⁾	679.19 FIT	635.33 FIT
λ_{DU} ¹⁾	82.97 FIT	61.77 FIT
MTBF ²⁾	84 years	89 years
¹⁾ according to Siemens SN29500 ²⁾ according to Siemens SN29500, including faults outside the safety function ³⁾ consideration according to IEC 61511-1 clause 11.4.4		

The device, including software and the modification process, was passed on the basis of proven-in-use.

Yamanashi, 19 April 2011

Endress+Hauser Yamanashi Co., Ltd.


(General Manager)