



FIELD COMM GROUP™
Connecting the World of
Process Automation

Device Registration

Manufacturer	Endress+Hauser Conducta GmbH&Co.KG Dieselstr. 24 Gerlingen, 70389 Germany	
Model Type	Liquiline Oxygen Oxygen Transmitter	
H1 ITK Profile	6	
Manufacturer Identification (MANUFAC_ID)	0x452B48	
Device Type (DEV_TYPE)	0x10A2	
Device Revision (DEV_REV)	0x02	
Stack Communication Profiles	31PS, 32LT	
H1 Physical Layer Profiles	111, 113, 115, 511	
Device Test Campaign	IT104700	
Device Support File Test Campaign	IT106800	
Stack Test Campaign	CT0165FF	
H1 Physical Layer Test Report	PT-499	
Device Descriptions	0202.FFO 0202.SYM 0202.FF5 0202.SY5	(CRC: 0xFFDAC01D) (CRC: 0x3D7E6A77) (CRC: 0x4CFC71BE) (CRC: 0x7CEFC70B)
Capability File	020102.CFF	(CRC: 0x28EBB69F)
Mandatory Features	Resource Block Alarms and Events Function Block Linking Trending Multi-Bit Alert Reporting Field Diagnostics	
Function Blocks	Analog Input Discrete Input Proportional Integral Derivative Input Selector Signal Characterizer Analog Alarm	
Registration Number	IT/104700/2	
Registration Program	FF-524 2.11	
Date Issued	2016-05-03	

**Authorized
Mark**

Use of mark subject to
Graphic Identify Style Guide



T. J. Masters

Ted Masters
President and Chief Executive Officer