



FIELD COMM GROUP™
Connecting the World of
Process Automation

Device Registration

Manufacturer	Endress+Hauser Conducta GmbH&Co.KG Dieselstr. 24 Gerlingen, 70389 Germany	
Model Type	Liquiline_pHORP pH/ORP Transmitter	
H1 ITK Profile	6	
Manufacturer Identification (MANUFAC_ID)	0x452B48	
Device Type (DEV_TYPE)	0x10A0	
Device Revision (DEV_REV)	0x03	
Stack Communication Profiles	31PS, 32LT	
H1 Physical Layer Profiles	111, 113, 115, 511	
Device Test Campaign	IT104500	
Stack Test Campaign	CT0165FF	
H1 Physical Layer Test Report	PT-499	
Device Descriptions	0301.FFO 0301.SYM 0301.FF5 0301.SY5 030101.CFF	(CRC: 0xFED7E84B) (CRC: 0xB4FD11E9) (CRC: 0x9945E2E9) (CRC: 0xB80F984D) (CRC: 0x4DBB98A5)
Capability File		
Mandatory Features	Resource Block Alarms and Events Function Block Linking Trending Multi-Bit Alert Reporting Field Diagnostics	
Function Blocks	Analog Input Discrete Input Proportional Integral Derivative Input Selector Signal Characterizer Analog Alarm	
Registration Number	IT/104500/1	
Registration Program	FF-524 2.11	
Date Issued	2015-12-10	

**Authorized
Mark**

Use of mark subject to
Graphic Identify Style Guide



T. J. Masters

Ted Masters
President and Chief Executive Officer