



Device Registration

Manufacturer	Endress+Hauser Conducta GmbH&Co.KG Dieselstr. 24 Gerlingen, 70389 Germany	
Model Type	Liquiline Oxygen Oxygen Transmitter	
H1 ITK Profile	6	
Manufacturer Identification (MANUFAC_ID)	0x452B48	
Device Type (DEV_TYPE)	0x10A2	
Device Revision (DEV_REV)	0x02	
Stack Communication Profiles	31PS, 32LT	
H1 Physical Layer Profiles	111, 113, 115, 511	
Device Test Campaign	IT104700	
Stack Test Campaign	CT0165FF	
H1 Physical Layer Test Report	PT-499	
Device Descriptions	0201.FFO 0201.SYM 0201.FF5 0201.SY5 020101.CFF	(CRC: 0x3B214394) (CRC: 0x61922EDB) (CRC: 0x95FFD521) (CRC: 0xDF7C06F8) (CRC: 0x9D033F2B)
Capability File		
Mandatory Features	Resource Block Alarms and Events Function Block Linking Trending Multi-Bit Alert Reporting Field Diagnostics	
Function Blocks	Analog Input Discrete Input Proportional Integral Derivative Input Selector Signal Characterizer Analog Alarm	
Registration Number	IT/104700/1	
Registration Program	FF-524 2.11	
Date Issued	2015-12-10	

**Authorized
Mark**

Use of mark subject to
Graphic Identify Style Guide



T. J. Masters

Ted Masters
President and Chief Executive Officer