



Certificate of Compliance

Certificate: 80107564 **Master Contract:** 200600
Project: 80230334 **Date Issued:** 2025-06-25
Issued to: Endress+Hauser Wetzler **Issued by:** Bill Miller
GmbH Co. KG Bill Miller, Certifier III
Obere Wank 1
Nesselwang, Bavaria 87484
Germany

Attention: Michael Pfanzelt

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



PRODUCTS

Class 2258 02 PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class 2258 82 PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

Ex ec IIC Gc

Class I, Zone 2, AEx ec IIC Gc

Class I, Division 2, Groups A, B, C, D

COMPONENT: iTEMP Temperature Transmitter.

Model(s)	Input Voltage	Input Current
TMT31-aabcdeffgghh, F2058-aabcdeffgghh	10-36 VDC	23 mA



Certificate: 80107564

Master Contract: 200600

Project: 80230334

Date Issued: 2025-06-25

Model TMT31 and identical F2058 of different color. Suitable for Division 2 or Zone 2 when installed per drawing 10000012751.

Where:

aa = Approval: CN (CSA C/US Ex ec IIC Gc), 8N (ATEX II3G Ex ec IIC Gc + CSA C/US Ex ec IIC Gc)

b = Output signal: A (4-20mA)

c = Housing shape: 1 (Form B head transmitter, DIN EN 50446), or 2 (DIN rail, IEC 60715)

d = Electrical connections: A (screw terminals) or B (spring terminals)

e = Sensor input: 1 (Measuring input RTD), or 2 (Measuring input TC)

ff = Device Model: A1 (1)

gg = Sensor Connection: B1 (RTD/Ohm 2-wire), B2 (RTD/Ohm 3-wire) or B3 (RTD/Ohm 4-wire), or B4 (TC)

hh = Sensor type: Two alphanumeric characters representing different software versions to adapt different sensor

Schedule of Limitations:

1. Due to the risk of discharge, the non-metallic parts of the equipment and of all non-metallic accessories have to be protected from electrostatic charging during installation and operation (e.g. only wipe with a damp cloth and do not expose to high voltage fields).
2. The device may only be powered by a power supply unit with a limited energy electric circuit in accordance with CSA/UL/EN/IEC 61010-1:2010 chapter 6.3.1/6.3.2 and 9.4 or Class 2 according to CSA 223/UL 1310.
3. For use in the type of protection increased safety Ex ec, and for Zone 2 (EPL Gc), and Class I, Division 2 applications, the transmitter TMT31/F2058 shall be installed completely inside an additional enclosure, providing a degree of protection of not less than IP54 according to CSA/UL 60079-0 and CSA/UL 60079-7 and requiring a tool to open. The ambient temperature within the end use enclosure shall not exceed the limits of the permissible ambient temperature range. Clearances, creepage distances, and separations as defined in CSA/UL 60079-7 must be considered for the installation.
4. If the head transmitter TMT31/F2058, in type of protection increased safe and for use in Zone 2 (EPL Gc) and Class I, Division 2 applications, is mounted in an optional field housing the field housing must be equipped with suitable cable glands, certified according to CSA/UL 60079-0 and CSA/UL 60079-7, providing a degree of ingress protection of not less than IP54.
5. This component has not been evaluated for process pressure and process temperature, or any other source of heating or cooling.
6. Wire end ferrules must be used with spring terminals and when using flexible cables with a cable cross section of $\leq 0.3 \text{ mm}^2$.
7. The end user shall ensure appropriate earthing of any metallic field housing (optional) and any metallic accessories if used.
8. The TMT31 DIN rail thermocouple's temperature input is not considered as galvanically isolated therefore the sensor shall be connected to the local potential equalization or ground.
9. The maximum temperature rise recorded was $+48^\circ\text{K}$. These components do not have any surface that achieves a temperature greater than $135^\circ\text{C}/100^\circ\text{C}/85^\circ\text{C}$ with a 5K safety factor when operated under full load conditions at an ambient of range as follows:

Rating	TMT31 and F2058	Sensor input RTD (e = 1) Ambient Temperature Range	Sensor input TC (e = 2) Ambient Temperature Range	T-Code Guidance
10-36 VDC	Head (c = 1)	$-40^\circ\text{C} \leq T_a \leq +85^\circ\text{C}$	$-40^\circ\text{C} \leq T_a \leq +80^\circ\text{C}$	135°C



Certificate: 80107564

Master Contract: 200600

Project: 80230334

Date Issued: 2025-06-25

			$-40\text{ °C} \leq T_a \leq +50\text{ °C}$	$-40\text{ °C} \leq T_a \leq +45\text{ °C}$	100 °C
			$-40\text{ °C} \leq T_a \leq +35\text{ °C}$	$-40\text{ °C} \leq T_a \leq +30\text{ °C}$	85 °C
		DIN Rail (c = 2)	$-40\text{ °C} \leq T_a \leq +85\text{ °C}$	$-40\text{ °C} \leq T_a \leq +85\text{ °C}$	135 °C
			$-40\text{ °C} \leq T_a \leq +67\text{ °C}$	$-40\text{ °C} \leq T_a \leq +67\text{ °C}$	100 °C
			$-40\text{ °C} \leq T_a \leq +52\text{ °C}$	$-40\text{ °C} \leq T_a \leq +52\text{ °C}$	85 °C
	10-30 VDC	Head (c = 1)	$-40\text{ °C} \leq T_a \leq +85\text{ °C}$	$-40\text{ °C} \leq T_a \leq +85\text{ °C}$	135 °C
			$-40\text{ °C} \leq T_a \leq +57\text{ °C}$	$-40\text{ °C} \leq T_a \leq +53\text{ °C}$	100 °C
			$-40\text{ °C} \leq T_a \leq +42\text{ °C}$	$-40\text{ °C} \leq T_a \leq +38\text{ °C}$	85 °C
		DIN Rail (c = 2)	$-40\text{ °C} \leq T_a \leq +85\text{ °C}$	$-40\text{ °C} \leq T_a \leq +85\text{ °C}$	135 °C
			$-40\text{ °C} \leq T_a \leq +70\text{ °C}$	$-40\text{ °C} \leq T_a \leq +70\text{ °C}$	100 °C
			$-40\text{ °C} \leq T_a \leq +55\text{ °C}$	$-40\text{ °C} \leq T_a \leq +55\text{ °C}$	85 °C

10. The factory programming 4-pins, covered pins, (CDI-Connection) are not used during normal operations.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 60079-0:19 - Explosive atmospheres — Part 0: Equipment -General requirements

CAN/CSA-C22.2 No. 60079-7:16 (R2021) - Explosive atmospheres - Part 7: Equipment protection by increased safety 'e'

ANSI/UL 60079-0-2019 - Standard for Safety for Explosive Atmospheres - Part 0: General Requirements

ANSI/UL 60079-7-2017 (R2021) Fifth Edition - Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

CAN/CSA C22.2 No. 213-17+ UPD 1 (2018) + UPD 2 (2019) + UPD 3 (2021) - Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations

ANSI/UL 121201:2017 - Ninth Edition - Including Revisions Through April 1, 2021 - UL Standard for Safety Nonincendive Electrical



Certificate: 80107564

Master Contract: 200600

Project: 80230334

Date Issued: 2025-06-25

Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

CAN/CSA C22.2 No. 61010-1-12, UPD1:2015, UPD2:2016, AMD1:2018 - Safety requirements for electrical equipment for measurement, control, and laboratory use — Part 1: General requirements

UL 61010-1 3rd ed (Rev. Nov 21, 2018) - UL Standard for Safety Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements - Third Edition; Including Revisions through November 21, 2018

Markings

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

The following are minimum marking to be found on the component:

- Manufacturer's name: "Endress + Hauser Wetzer GmbH Co. KG", or CSA Master Contract Number
- "200600", adjacent to the CSA Mark in lieu of manufacturer's name.
- The CSA Mark, with or without the "C" and "US" indicators, as shown on the Certificate of Compliance
- Model Designation, as specified in the PRODUCTS section, above.
- Electrical Ratings, as specified in the PRODUCTS section, above.
- Ambient temperature range, as specified in the PRODUCTS section, above...
- Serial Number, Date Code or Month and Year of Manufacture.
- Hazardous Location designation: As specified in the PRODUCTS section, above. The word "Class" may be abbreviated "CL", the word "Division" may be abbreviated "DIV", and the word "Groups" may be abbreviated "GRP" or "GP".
- Method of Protection markings (Ex -- markings): As specified in the PRODUCTS section, above.
- Certificate Number: CSA22CA80107564
- Install per drawing 10000012751

The markings as shown in drawing 10000012457 are applied.

Method of Marking:

Laser etched onto enclosure; or

The material of the label type TOP-SCRIPT 101 720 (manufacturer Eltex) and the label type 3105 2008 (Manufacturer WOELCO) is accepted in the CSA Letter of Attestation 2089254.

DOCUMENTATION

An installation manual, data sheet, or other documentation shall be supplied with each unit, containing the following minimum information:



Certificate: 80107564

Master Contract: 200600

Project: 80230334

Date Issued: 2025-06-25

-
- A recapitulation of the information with which the equipment is marked, except for the serial number.
 - Manufacturer's name and address
 - Name and address of importer or repairer, when necessary to facilitate repair.
 - A description of the intended use of the equipment.
 - A statement that if the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

Equipment Ratings:

This includes equipment supply, description of I/O connections and operating environmental conditions.

1. Pollution degree 2;
2. Installation category: DC supplied;
3. Electrical supply 10-36 V dc
5. Temperature -40°C up to +85°

Equipment Installation:

This includes instructions for Assembly and mounting, Location requirements.

Equipment Operation:

This includes explanations of warning symbols used, and instructions for interconnection, and cleaning and decontamination as required.



Certificate: 80107564

Project: 80230334

Master Contract: 200600

Date Issued: 2025-06-25

Notes:

Products certified under Class(es) C225802, C225882 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80107564

Master Contract: 200600

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80230334	2025-06-25	Evaluation to update cCSAus report # 80107564 for non-incendive and increased safety “ec” protected iTEMP Temperature Transmitter Head Model TMT31 Series and F2058HRTD Series for addition of further thermocouple sensor input for TMT31, rename F2058HRTD to F2058, addition of DIN rail housing option and comments of marked up report. Ordinary Locations report 70190447 to be updated separately.
80107564	2022-07-15	Type TMT31 Series and F2058HRTD for installation in Class I, Division 2 and Class I, Zone 2, Group IIC increased safety “ec” protected. Ordinary Location assessment was conducted with CSA under project 80082275.