



防爆合格证

证 号：GYJ23.1132X

制 造 商 恩德斯+豪斯公司

(地址：Obere Wank 1, 87484 Nesselwang, Germany)

产 品 名 称 TID10 显示屏

型 号 规 格 TID 10

防 爆 标 志 Ex ia II C T4...T6 Ga

产 品 标 准 /

图 样 编 号 10000006831

经图样及技术文件的审查和样品检验，确认上述产品符合下列标准：

GB/T 3836.1-2021, GB/T 3836.4-2021

特颁发此证。

本证书有效期：2023年07月04日至2028年07月03日

备 注

1. 安全使用注意事项见本证书附件。
2. 本安电气参数见本证书附件。
3. 本证书同时适用于恩德斯豪斯温度仪表（苏州）有限公司（地址：苏州工业园区江田里路31号）生产的同型号产品。
4. [更改 I] 防爆标志和图号变更，2025年10月29日签发。

批 准

上海仪器仪表自控系统检验测试所有限公司
国家级仪器仪表防爆安全监督检验站


颁 发 日 期 二 〇 二 三 年 七 月 四 日

本证书仅对与认可文件和样品一致的产品有效。

地址：上海市漕宝路103号
邮编：200233

网址：www.nepsi.org.cn
Email: info@nepsi.org.cn

电话：+86 21 64368180
传真：+86 21 64844580



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYJ23.1132X

Manufacturer	Endress + Hauser Wetzer GmbH + Co. KG (Address:Obere Wank 1, 87484 Nesselwang, Germany)
Product	TID10 Display
Model	TID 10
Ex marking	Ex ia IIC T4...T6 Ga
Product standard	/
Drawing number	10000006831

The product was found to comply with the following standard(s):


GB/T 3836.1-2021,GB/T 3836.4-2021

Valid until: 2028.07.03

Remarks

- 1.Conditions for safe use are specified in the attachment to this certificate.
- 2.Intrinsic safety parameters specified in the attachment to this certificate.
- 3.This certificate is also applicable for the product with the same type manufactured by Endress+Hauser Wetzer (Suzhou) Co., Ltd. (address: No.31 JiangTianLiLu,Suzhou Industrial Park).
- 4.[Variation 1]Ex marking and drawing number change. Issue on 2025.10.29.

Approval


**Shanghai Inspection and Testing Institute of
Instruments and Automation Systems Co., Ltd.**
**National Supervision and Inspection Center for
Explosion Protection and Safety of Instrumentation**
Date of issue 2023.07.04

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.