Safety Instructions Nivotester FTC325

[Ex ia Ga] IIC







Nivotester FTC325

Table of contents

About this document	4
Associated documentation	4
Supplementary documentation	4
Certificates and declarations	4
Manufacturer address	4
Extended order code	4
Safety instructions: General	7
Safety instructions: Specific conditions of use	7
Safety instructions: Installation	8
Temperature tables 1	0
Connection data 1	0

About this document	The document number of these Safety Instructions (XA) must match the information on the nameplate.
Associated documentation	All documentation is available on the Internet: www.endress.com/Deviceviewer (enter the serial number from the nameplate). To commission the device, please observe the Operating Instructions pertaining to the device: TI00380F, KA00221F
Supplementary documentation	Explosion protection brochure: CP00021Z The explosion protection brochure is available on the Internet: www.endress.com/Downloads
Certificates and declarations	NEPSI Declaration of Conformity Certificate number: GYJ25.1124X Affixing the certificate number certifies conformity with the following standards (depending on the device version): • GB/T 3836.1-2021 • GB/T 3836.4-2021
Manufacturer address	Endress+Hauser SE+Co. KG Hauptstraße 1 79689 Maulburg, Germany Address of the manufacturing plant: See nameplate.
Extended order code	The extended order code is indicated on the nameplate, which is affixed to the device in such a way that it is clearly visible. Additional information about the nameplate is provided in the associated Operating Instructions.

Structure of the extended order code

FTC325	-	********	+	A*B*C*D*E*F*G*
(Device		(Basic		(Optional
type)		specifications)		specifications)

* = Placeholder

At this position, an option (number or letter) selected from the specification is displayed instead of the placeholders.

Basic specifications

The features that are absolutely essential for the device (mandatory features) are specified in the basic specifications. The number of positions depends on the number of features available. The selected option of a feature can consist of several positions.

Optional specifications

The optional specifications describe additional features for the device (optional features). The number of positions depends on the number of features available. The features have a 2-digit structure to aid identification (e.g. JA). The first digit (ID) stands for the feature group and consists of a number or a letter (e.g. J = Test, Certificate). The second digit constitutes the value that stands for the feature within the group (e.g. A = 3.1 material (wetted parts), inspection certificate).

More detailed information about the device is provided in the following tables. These tables describe the individual positions and IDs in the extended order code which are relevant to hazardous locations.

Extended order code: Nivotester



The following specifications reproduce an extract from the product structure and are used to assign:

- This documentation to the device (using the extended order code on the nameplate).
- The device options cited in the document.

Device type

FTC325

Basic specifications

Position 1 (Position 1 (Approval)		
Selected option Description		Description	
FTC325	Ν	NEPSI [Ex ia Ga] IIC	

Position 2 (I	Position 2 (Input; Housing)		
Selected option Description		Description	
FTC325	1	2-wire PFM; 45 mm, DIN Rail	

Position 3 (Power Supply)		
Selected option Description		
FTC325	А	85 to 253 V _{AC}
	В	20 to 30 V_{AC} / 20 to 60 V_{DC}

Position 4 (Switch Output)		
Selected option Description		Description
FTC325	1	1x SPDT level + 1x SPST alarm N.C. (normal closed)
	2	1x SPDT level + 1x SPST alarm N.O. (normal open)

Optional specifications

No options specific to hazardous locations are available.

Safety instructions: General	 Staff must meet the following conditions for mounting, electrical installation, commissioning and maintenance of the device: Be suitably qualified for their role and the tasks they perform Be trained in explosion protection Be familiar with national regulations For installation, use and maintenance of the device, users must also observe the requirements stated in the Operating Instructions and the standards: GB 50257-2014: "Code for construction and acceptance of electric device for explosion atmospheres and fire hazard electrical equipment installation engineering". GB/T 3836.13-2021: "Explosive atmospheres, Part 13: Equipment repair, overhaul, reclamation and modification". GB/T 3836.16-2022: "Explosive atmospheres, Part 15: Electrical installations design, selection and erection". GB/T 3836.16-2022: "Explosive atmospheres, Part 16: Electrical installations inspection and maintenance". Comply with the installation and safety instructions in the Operating Instructions. Install the device according to the manufacturer's instructions and national regulations. Do not operate the device outside the specified electrical, thermal and mechanical parameters. Avoid electrostatic charging. Alterations to the device can affect the explosion protection and must be carried out by staff authorized to perform such work by Endress+Hauser.
Safety instructions:	To avoid electrostatic charging: Do not rub surfaces with a dry cloth.

Specific

conditions of use

Safety instructions: Installation



E 1

- 1 PFM sensor, Limit level Ex ia IIC/IIB
- 2 PFM sensor
- 3 Level relay
- 4 Fault signal relay/Level relay
- 5 Power supply



₽2

- A Min. 6 mm
- 1 Intrinsically safe contacts
- 2 Nivotester FTC325
- 3 Other type, other product
- To achieve an ingress protection of at least IP55: Protect the device from dust and humidity, e.g. in control rooms, or located in a suitable protective enclosure.
- The device is an associated apparatus: Only use the device outside explosion hazardous areas.
- There must be a distance (thread measure) of at least 50 mm between intrinsically safe and nonintrinsically safe terminals.
- When combining the device with other types and products on the same top-hat rail: Keep the distances comply to the relevant standards and rules.
- When combining with devices from other manufacturers: Observe ingress protection of the enclosure.

Intrinsic safety

- Observe the pertinent guidelines when interconnecting intrinsically safe circuits.
- The intrinsically-safe input circuits are galvanically isolated from other circuits up to a peak value of the nominal voltage of 375 V.

Temperature tables

Ambient temperature range	
Individual installation	-20 °C $\leq T_a \leq +60$ °C
Series installation	$-20 \ ^{\circ}\text{C} \le T_a \le +50 \ ^{\circ}\text{C}$

Connection data

Power supply circuit		
Terminal connections: 1, 2	AC voltage	U = 85 to 253 V _{AC} , 50/60 Hz P \leq 6.0 VA
	DC voltage	$\begin{array}{l} U = 20 \text{ to } 60 \text{ V}_{\text{DC}} \\ U = 20 \text{ to } 30 \text{ V}_{\text{AC}} \text{, } 50/60 \text{ Hz} \\ P \leq 2.0 \text{ W} \end{array}$

Contact circuit	
Level relay Terminal connections: 22, 23, 24	$U \le 250~V_{AC}, I \le 2$ A, P $\le 500~VA$ at $\cos \phi \ge 0.7$ U $\le 40~V_{DC}, I \le 2$ A, P $\le 80~W$
Fault signal relay Terminal connections: 15, 16	$ \begin{array}{l} U \leq 250 \ V_{AC}, I \leq 2 \ A, P \leq 500 \ VA \ at \ cos \ \phi \geq 0.7 \\ U \leq 40 \ V_{DC}, I \leq 2 \ A, P \leq 80 \ W \\ optionally \ NC \ or \ NO, \ e \ \blacksquare 1, \ \blacksquare 8 \end{array} $

Sensor circuit					
Terminal connections: 11, 12	Connection data:	$U_0 \le 13.9 \text{ V}$ $I_0 \le 99 \text{ mA}$ $P_0 \le 874 \text{ mW}$ Trapezium-shaped cha		$L_i = 0.13 \text{ mH}$	
		[Ex ia Ga]	IIC	[Ex ia Ga]	IIB
		Lo	Co	Lo	Co
	Max. external capacitance at max. external inductance	0.85 mH	0.18 µF	0.85 mH	2.06 µF
		0.35 mH	0.26 µF	4.85 mH	1.06 µF
	Max. external capacitance or max. external inductance	3.50 mH	0.60 µF	14.3 mH	4.56 µF
If using explosion protection group		[Ex ib Gb] IIC		[Ex ib Gb] IIB	
[Ex ib Gb] IIC/IIB the application is limited to II (2) G or equipment protection level		Lo	Co	Lo	Co
(EPL) Gb	Max. external capacitance or max. external inductance	3.50 mH	0.60 µF	14.3 mH	4.56 µF



71710249

www.addresses.endress.com

