

Installation Instructions **Spare parts kits for Dipfit CLA140 conductivity assemblies**

Seals



Table of contents

1 Overview 3

2 Designated use 3

3 Personnel authorized to carry out conversion 4

4 Safety instructions 4

5 Scope of delivery 5

6 Replacing the O-rings 5


7 Additional documentation 5

8 Disposal 6


1 Overview

1.1 Spare parts kits

These installation instructions apply to the following spare parts kits:

No.	Designation	Section
51500064	Seal set for CLA140 EPDM	→  5
51500065	Seal set for CLA140 Viton (FPM)	
51500066	Seal set for CLA140 Chemraz (FFKM)	
51500067	Seal set for CLA140 Fluoraz (FEPM)	

1.2 Overview



A0058644

1 Installation positions of O-rings

- 1 O-ring ID 53.57 W 3.53 OD 60.63
- 2 O-ring ID 69.52 W 2.62 OD 74.76

2 Designated use

- The parts in the kits must only be used as maintenance parts for the CLA140 conductivity assembly. Any other use is not permitted!
- Only use original parts from Endress+Hauser.
- In the Device Viewer, check if the spare part is suitable for the device in question.

3 Personnel authorized to carry out conversion

- Installation, commissioning, operation and maintenance of the measuring system may be carried out only by specially trained technical personnel.
- The technical personnel must be authorized by the plant operator to perform the stated tasks.
- The electrical connection may only be established by an electrical technician.
- The technical personnel must have read and understood these Installation Instructions and must follow the instructions they contain.
- Faults at the measuring point may only be rectified by authorized and specially trained personnel.



Repairs not described in the Operating Instructions provided must only be carried out directly at the manufacturer's site or by the service organization.

4 Safety instructions

WARNING

Risk of injury from high pressure, high temperature or chemical hazards if process medium escapes!

- Before installing or removing an assembly, depressurize the system, drain the system and clean it.

CAUTION

Risk to health due to contact with the process medium

- Wear protective gloves, protective goggles and protective clothing, particularly when working with reagents, chemicals or process solutions.
- In case of contact with eyes or skin, rinse the affected area with plenty of water and then seek medical advice. Show the relevant safety data sheet to the physician.

NOTICE

Material damage due to solvents!

- Do not use any halogen-containing organic solvents or acetone. These solvents could destroy plastic components of the assembly.



Potential impact on the process





Before decommissioning an active device, the potential impact on the overall process must be taken into account! This applies in particular when using the associated measuring instrument to control process variables.

5 Scope of delivery




A0058712

 2 CLA140 seals

Kit no.	Number	Kit item no. →  1,  3 and →  2,  5	Size	Remarks/material
51500064 (EPDM)	1	1	O-ring ID 53.57 W 3.53 OD 60.63	EPDM, FPM, FFKM or FEPM
51500065 (FPM)	1	2	O-ring ID 69.52 W 2.62 OD 74.76	EPDM, FPM, FFKM or FEPM
51500066 (FFKM)				
51500067 (FEPM)				

6 Replacing the O-rings

 The procedure for replacing the O-rings can be found in the Operating Instructions of the Dipfit CLA140 (BA00196C) immersion assembly.

7 Additional documentation

Detailed information on the device can be found in the Operating Instructions for the specific assembly and in the other documentation available via:

- www.endress.com/device-viewer
- Smartphone/tablet: Endress+Hauser Operations app

8 Disposal

- ▶ Please observe local regulations!



71707994

www.addresses.endress.com
