





## Manufacturer Information

for users regarding software- and hardware changes  
(According to NAMUR-Recommendation 53)

### 3 Compatibility (Firmware, Hardware I)

Is the new firmware version compatible with the previous version, the installed device software drivers, or service tools and/or is the new hardware I version compatible with the previous hardware I version?

Yes

No, description:

DTM operation with current DTM is possible. For usage of new functionalities a new DTM is required (FieldCare Package Version 1.25.00, DTM-Libraries Version 2.40.00)

Is a firmware update and/or the exchange of hardware I components generally recommended?

Yes, reason:

The update/exchange can be performed as follows:

Flashing with FieldCare.

The required flash-files will be provided with next Update of FieldCare (FieldCare Package Version 1.26.00, DTM-Libraries Version 2.41.00) On request the Flash-Files are available from Endress+Hauser in advance.

No, reason:

An update is recommended:

- For usage of new functionalities

### 4 Operating Instruction

Is a new operating instruction necessary due to the modification due to section 2?

Yes

No

Which operating instruction corresponds to the new firmware:

Device	Communication options	Manual	Identification
FMR50	<b>HART</b>	BA1045F	03.14
FMR51/52	<b>HART</b>	BA1049F	03.14
FMR53/54	<b>HART</b>	BA1050F	03.14
FMR56/57	<b>HART</b>	BA1048F	03.14



## Manufacturer Information

for users regarding software- and hardware changes  
(According to NAMUR-Recommendation 53)

The new instruction manuals can be referred in Internet:  
<http://www.endress.com> - area „DOWNLOAD“  
- declaration of the device and kind of manual

### 5 Price

Does the price of the device change compared to its predecessor version?

- Yes, new price list and updated costs (without installation) are attached  
 No