中国国家强制性产品认证证书

证书编号：2024010305714736

认证委托人名称及地址

恩德斯豪斯温度仪表（苏州）有限公司
苏州工业园区江田里路 31 号

生产者名称及地址

恩德斯豪斯温度仪表（苏州）有限公司
苏州工业园区江田里路 31 号

生产企业名称及地址

恩德斯豪斯温度仪表（苏州）有限公司
苏州工业园区江田里路 31 号

产品名称和系列、型号、规格

阻旋式物位开关

FTE20； Ui: 250V； Uimp: 2.5kV； Ith: 5A； AC-15: Ue/Ie: 250V/3A； DC-13: Ue/Ie: 24V/2A, 250V/0.2A； IP66；型号解释见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2025 年 06 月 25 日 **有效期至：**2029 年 10 月 30 日

本证书为变更证书，证书首次颁发日期：2024 年 10 月 31 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010305714736

FTE20-	**aabbccdeffgghhii**
aa	**Approval:认证**
AA	Non-hazardous area 非防爆使用
BI	ATEX II1/2D Ex ta/tb IIIC Da/Db 粉尘防爆
II	IECEx Ex ta/tb IIIC Da/Db 粉尘防爆
NE	NEPSI Ex tD A20/A21 粉尘防爆
bb	**Process Connection; Material:过程连接，材质**
11	NPT1-1/2 male thread; PBT 螺纹 NPT/T1-1/2; PBT
12	NPT1-1/4 male thread; PBT 螺纹 NPT/T1-1/4; PBT
13	G1-1/2 male thread; PBT 螺纹 G1-1/2; PBT
14	NPT1-1/2 male thread;303 螺纹 NPT1-1/2; 303
15	NPT1-1/4 male thread;303 螺纹 NPT1-1/4; 303
16	G1-1/2 male thread;303 螺纹 G1-1/2; 303
99	Special version, TSP-no. to be spec. 特殊型
	Version, Length:探杆类型，长度
cc	Shaft,75mm 杆式 75mm
AA	Shaft,100mm 杆式 100mm
AB	Shaft,120mm 杆式 120mm
AC	Shaft,200mm 杆式 120mm
AD	Shaft,300mm 杆式 300mm
AE	Rope,2000mm,shortable 缆式，2000mm，可截断
AF	Special version, TSP-no. to be spec. 特殊型
YY	

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010305714736

d	**Power Supply:电源**
1	20-28VDC 直流
2	24VAC 交流
3	115VAC 交流
4	230VAC 交流
9	Special version, TSP-no.to be spec 特殊型
e	**Paddle; Material:阻旋桨，材质**
1	Standard;304 标准 304
2	Hinged;304 铰链式 304
9	Special version, TSP-no. to be spec. 特殊型
ff	**Additional Option:附加选项**
CA	Rotation monitoring 旋转监控
gg	**>>Accessory Mounted:附件安装**
NA	Signal lamp 信号灯
N9	Special version, TSP-no. to be spec.特殊型
	.
hh	**Accessory Enclosed:附件包含**
PA	Weather protection cover 遮阳罩
PB	Flange version 150mm x 150mm 方形法兰
P9	Special version, TSP-no. to be spec. 特殊型
ii	**Marking:标记**
Z1	Tagging(TAG),metal 金属位号
Z2	Tagging(TAG),on device 设备位号
Z3	Commissioning label, paper 纸质位号
Z6	Tagging(TAG),by customer 客户定义位号

ff、gg、hh、ii 为可选项，可省略.

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010305714736

NAME AND ADDRESS OF THE APPLICANT

Endress+Hauser Wetzer（Suzhou）Co., Ltd.
No. 31, Jiangtianli Road, Suzhou Industrial Park

NAME AND ADDRESS OF THE MANUFACTURER

Endress+Hauser Wetzer（Suzhou）Co., Ltd.
No. 31, Jiangtianli Road, Suzhou Industrial Park

NAME AND LOCATION OF THE FACTORY

Endress+Hauser Wetzer（Suzhou）Co., Ltd.
No. 31, Jiangtianli Road, Suzhou Industrial Park

PRODUCT NAME,MODEL AND SPECIFICATION

Soliswitch

FTE20； Ui: 250V; Uimp: 2.5kV; Ith: 5A; AC-15: Ue/Ie: 250V/3A; DC-13: Ue/Ie: 24V/2A, 250V/0.2A; IP66；See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.25,2025 **Valid until:** Oct.30,2029

Date of original issued: Oct.31,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司
11010610269466

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305714736

Appendix: Page 1 of 2

FTE20-	**aabbccdeffgghhii**
aa	**Approval:认证**
AA	Non-hazardous area 非防爆使用
BI	ATEX II1/2D Ex ta/tb IIIC Da/Db 粉尘防爆
II	IECEx Ex ta/tb IIIC Da/Db 粉尘防爆
NE	NEPSI Ex tD A20/A21 粉尘防爆
bb	**Process Connection; Material:过程连接，材质**
11	NPT1-1/2 male thread; PBT 螺纹 NPT/T1-1/2; PBT
12	NPT1-1/4 male thread; PBT 螺纹 NPT/T1-1/4; PBT
13	G1-1/2 male thread; PBT 螺纹 G1-1/2; PBT
14	NPT1-1/2 male thread;303 螺纹 NPT1-1/2; 303
15	NPT1-1/4 male thread;303 螺纹 NPT1-1/4; 303
16	G1-1/2 male thread;303 螺纹 G1-1/2; 303
99	Special version, TSP-no. to be spec. 特殊型
	Version, Length:探杆类型，长度
cc	Shaft,75mm 杆式 75mm
AA	Shaft,100mm 杆式 100mm
AB	Shaft,120mm 杆式 120mm
AC	Shaft,200mm 杆式 120mm
AD	Shaft,300mm 杆式 300mm
AE	Rope,2000mm,shortable 缆式，2000mm，可截断
AF	Special version, TSP-no. to be spec. 特殊型
YY	

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，不得单独使用
This translated document does not have legal validity and cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305714736

Appendix: Page 2 of 2

d	**Power Supply:电源**
1	20-28VDC 直流
2	24VAC 交流
3	115VAC 交流
4	230VAC 交流
9	Special version, TSP-no.to be spec 特殊型
e	**Paddle; Material:阻旋桨，材质**
1	Standard;304 标准 304
2	Hinged;304 铰链式 304
9	Special version, TSP-no. to be spec. 特殊型
ff	**Additional Option:附加选项**
CA	Rotation monitoring 旋转监控
gg	**>>Accessory Mounted:附件安装**
NA	Signal lamp 信号灯
N9	Special version, TSP-no. to be spec.特殊型
	.
hh	**Accessory Enclosed:附件包含**
PA	Weather protection cover 遮阳罩
PB	Flange version 150mm x 150mm 方形法兰
P9	Special version, TSP-no. to be spec. 特殊型
ii	**Marking:标记**
Z1	Tagging(TAG),metal 金属位号
Z2	Tagging(TAG),on device 设备位号
Z3	Commissioning label, paper 纸质位号
Z6	Tagging(TAG),by customer 客户定义位号

ff、gg、hh、ii 为可选项，可省略.

This page is attached to the certificate and should be used at the same time as the certificate page.