Manufacturer Information

For users regarding firmware and hardware updates (in accordance with the NAMUR 53 recommendation)

1	Type of device						
	Field device / signal processing device Monitoring / operating system						
Ma	anufacturer	:	Endress+Hauser				
Product :		Liquiphant FTL51B/62/63/64 with Electronic FEL60H / HART					
Part number / Order code :		:	FTL51B-##BA########## FTL62-##BA######### FTL63-##BA########## FTL64-##BA##########				
Communication / Interface		:	Communication	Device Type			
1110	errace		HART	0x11C4			
2	Firmware, Hardware I						
Ту	pe of change: No change						
	Firmware version Hardware I revision						
Olo	d version / revision :		01.00.01				
Ne	w version / revision :		-				
Но	w can the old Firmware ver	rsio	n be identified:				
	Not relevant						
De	scription of the modificatio	n w	ith respect to the old F	irmware version / Hardware I revision:			
	Adjustment Diagnostic Test Interval RAM Check from 10 minutes to 30 minutes						
	All other diagnostics remain unchanged.						
	Functional safety addit	tion	s (Heartbeat Technolog	gy)			



3 Functional Safety
Impact on Functional Safety:
☐ No ☐ Yes Adjustments pertain to the RAM check only. According to DIN EN 61511-2 paragraph A.11.9.2, if a hardware fault tolerance of 0 and a high or continuous requirement rate (high demand), care must be taken to ensure that the ratio between the frequency of the request and the diagnostic interval must be greater than or equal to 100. This results in a maximum request rate of 1x every 17 hours from the previous specification of 10 min. If this has been exploited, the RAM check will still be run 33 times within the 17 hours with the correct information. It is extremely unlikely that a fault will not be discovered during this time.
Changes in safety figures:
□ No☑ Yes → new figures refer to Safety Manual
Adjustment Diagnostic Test Interval RAM Check from 10 minutes to 30 minutes.
4 Compatibility (Firmware, Hardware I)
Is the new Firmware version compatible with the previous version, the installed device drivers, the operating tool compatible / is the new Hardware I revision compatible with the previous revision?
✓ Yes☐ No, description:
Is a Firmware / Hardware I update generally recommended? ☐ Yes, reason:
No, reason: no new firmware
5 Documentation
Instruction manual
Is a new instruction manual required because of the changes in point 2?
□ Yes ☑ No

Safety	manual
--------	--------

is a new safety manual required because of the changes in point 2:					
\boxtimes	Yes				
	No				
TATI . 1					
Which safety manual corresponds to the new Firmware version / Hardware I revision:					

Device	Manual	Documentation code
Liquiphant FTL51B	FY01068F/00/03.25	Functional Safety Manual
Liquiphant FTL62	FY01069F/00/03.25	Liquiphant FTL51B/62/63/64
Liquiphant FTL63	FY01091F/00/02.25	with electronic insert FEL60H (HART)
Liquiphant FTL64	FY01070F/00/03.25	

The new manuals can be downloaded from the Internet:

<u>www.endress.com</u> - area "DOWNLOADS"

- enter the device details and type of manual

6 Price

Has the price of the device changed?

☐ Yes, new list price and upda	te costs (without installation) are attached
--------------------------------	--