

## Declaration of Conformity

Functional Safety according to IEC 61508

Based on NE 130 Form B.1

Endress+Hauser SE+Co. KG, Hauptstraße 1, 79689 Maulburg

being the manufacturer, declares that the products

**Deltabar S PMD75-ABA7BE1DCBE**

Serial number: N405600109D

Serial number: N405610109D

is suitable for the use in safety-instrumented systems according to IEC 61508. The instructions of the corresponding functional safety manual must be followed.

This declaration of compliance is exclusively valid for the customer listed in the cover letter of the respective Endress+Hauser sales center and for the listed products and accessories in delivery status.

Maulburg, 5-September-2018

Endress+Hauser SE+Co. KG

i. V. 

Dietmar Frühauf

Dept. Manager R&D Devices Level Limit

General			
Device designation and permissible types	PMD75-ABA7BE1DCBE N405610109D; N405600109D		
Safety-related output signal	4...20 mA		
Fault signal	<=3.6mA; >=21mA		
Process variable/function	Pressure Measurement		
Safety function(s)	MIN, MAX, Range		
Device type acc. to IEC 61508-2	<input type="checkbox"/> Type A <input checked="" type="checkbox"/> Type B		
Operating mode	<input checked="" type="checkbox"/> Low Demand Mode <input type="checkbox"/> High Demand Mode <input type="checkbox"/> Continuous Mode		
Valid hardware version	As of version 02.00		
Valid software version	02.30.06 (failure E727 as alarm)		
Safety manual	SD00189P		
Type of evaluation (check only <u>one</u> box)	<input checked="" type="checkbox"/>	Complete HW/SW evaluation parallel to development incl. FMEDA and change request acc. to IEC 61508-2, 3	
	<input type="checkbox"/>	Evaluation of "proven in use" performance for HW/SW incl. FMEDA and change request acc. to IEC 61508-2, 3	
	<input type="checkbox"/>	Evaluation of HW/SW field data to verify „prior use“ acc. to IEC 61511	
	<input type="checkbox"/>	Evaluation by FMEDA acc. to IEC 61508-2 for devices w/o software	
Evaluation through – report/certificate no.	TÜV SÜD Z10 16 09 20351 005		
Test documents	Development documents	Test reports	Data sheets
SIL - Integrity			
Systematic safety integrity		<input type="checkbox"/> SIL 2 capable	<input checked="" type="checkbox"/> SIL 3 capable
Hardware safety integrity	Single channel use (HFT = 0)	<input checked="" type="checkbox"/> SIL 2 capable	<input type="checkbox"/> SIL 3 capable
	Multi channel use (HFT ≥ 1)	<input type="checkbox"/> SIL 2 capable	<input checked="" type="checkbox"/> SIL 3 capable
FMEDA (failure E727 as alarm)			
Safety function	MIN	MAX	Range
$\lambda_{DU}^{1),2)}$	69 FIT	69 FIT	69 FIT
$\lambda_{DD}^{1),2)}$	396 FIT	52 FIT	0 FIT
$\lambda_{SU}^{1),2)}$	440 FIT	440 FIT	440 FIT
$\lambda_{SD}^{1),2)}$	52 FIT	396 FIT	448 FIT
SFF	92,8 %	92,8 %	92,8 %
$PFD_{avg} (T_1 = 1 \text{ year})^{2)}$ (single channel architecture)	$3,02 \times 10^{-4}$	$3,02 \times 10^{-4}$	$3,02 \times 10^{-4}$
$PFD_{avg} (T_1 = 5 \text{ years})^{2)}$ (single channel architecture)	$1,50 \times 10^{-3}$	$1,50 \times 10^{-3}$	$1,50 \times 10^{-3}$
PFH	---	---	---
PTC <sup>3)</sup>	50 % / 99%	50 % / 99%	50 % / 99%
$\lambda_{total}^{1),2)}$	1194 FIT	1194 FIT	1194 FIT
Diagnostic test interval <sup>4)</sup>	5 min	5 min	5 min
Fault reaction time <sup>5)</sup>	5 min	5 min	5 min
Comments			
—			
Declaration			
<input checked="" type="checkbox"/>	Our internal company quality management system ensures information on safety-related systematic faults which become evident in the future		

<sup>1)</sup> FIT = Failure In Time, number of failures per 10<sup>9</sup> h<sup>2)</sup> Valid for average ambient temperature up to +40 °C (+104 °F)

For continuous operation at ambient temperature close to +60 °C (+140 °F), a factor of 2.1 should be applied

<sup>3)</sup> PTC = Proof Test Coverage<sup>4)</sup> All diagnostic functions are performed at least once within the diagnostic test interval<sup>5)</sup> Maximum time between error recognition and error response

General			
Device designation and permissible types	PMD75-ABA7BE1DCBE N405610109D; N405600109D		
Safety-related output signal	4...20 mA		
Fault signal	<=3.6mA; >=21mA		
Process variable/function	Pressure Measurement		
Safety function(s)	MIN, MAX, Range		
Device type acc. to IEC 61508-2	<input type="checkbox"/> Type A <input checked="" type="checkbox"/> Type B		
Operating mode	<input checked="" type="checkbox"/> Low Demand Mode <input type="checkbox"/> High Demand Mode <input type="checkbox"/> Continuous Mode		
Valid hardware version	As of version 02.00		
Valid software version	02.30.06 (failure E727 as warning)		
Safety manual	SD00189P		
Type of evaluation (check only <u>one</u> box)	<input checked="" type="checkbox"/>	Complete HW/SW evaluation parallel to development incl. FMEDA and change request acc. to IEC 61508-2, 3	
	<input type="checkbox"/>	Evaluation of "proven in use" performance for HW/SW incl. FMEDA and change request acc. to IEC 61508-2, 3	
	<input type="checkbox"/>	Evaluation of HW/SW field data to verify „prior use“ acc. to IEC 61511	
	<input type="checkbox"/>	Evaluation by FMEDA acc. to IEC 61508-2 for devices w/o software	
Evaluation through – report/certificate no.	TÜV SÜD Z10 16 09 20351 005		
Test documents	Development documents	Test reports	Data sheets
SIL - Integrity			
Systematic safety integrity		<input type="checkbox"/> SIL 2 capable	<input checked="" type="checkbox"/> SIL 3 capable
Hardware safety integrity	Single channel use (HFT = 0)	<input checked="" type="checkbox"/> SIL 2 capable	<input type="checkbox"/> SIL 3 capable
	Multi channel use (HFT ≥ 1)	<input type="checkbox"/> SIL 2 capable	<input checked="" type="checkbox"/> SIL 3 capable
FMEDA (failure E727 as warning)			
Safety function	MIN	MAX	Range
$\lambda_{DU}^{1),2)}$	76 FIT	76 FIT	76 FIT
$\lambda_{DD}^{1),2)}$	347 FIT	50 FIT	0 FIT
$\lambda_{SU}^{1),2)}$	427 FIT	427 FIT	427 FIT
$\lambda_{SD}^{1),2)}$	50 FIT	347 FIT	397 FIT
SFF	91,0 %	91,0 %	91,0 %
$PFD_{avg} (T_1 = 1 \text{ year})^{2)}$ (single channel architecture)	$3,32 \times 10^{-4}$	$3,32 \times 10^{-4}$	$3,32 \times 10^{-4}$
$PFD_{avg} (T_1 = 5 \text{ years})^{2)}$ (single channel architecture)	$1,65 \times 10^{-3}$	$1,65 \times 10^{-3}$	$1,65 \times 10^{-3}$
PFH	---	---	---
PTC <sup>3)</sup>	50 % / 99%	50 % / 99%	50 % / 99%
$\lambda_{total}^{1),2)}$	1136 FIT	1136 FIT	1136 FIT
Diagnostic test interval <sup>4)</sup>	5 min	5 min	5 min
Fault reaction time <sup>5)</sup>	5 min	5 min	5 min
Comments			
—			
Declaration			
<input checked="" type="checkbox"/>	Our internal company quality management system ensures information on safety-related systematic faults which become evident in the future		

<sup>1)</sup> FIT = Failure In Time, number of failures per 10<sup>9</sup> h

<sup>2)</sup> Valid for average ambient temperature up to +40 °C (+104 °F)

For continuous operation at ambient temperature close to +60 °C (+140 °F), a factor of 2.1 should be applied

<sup>3)</sup> PTC = Proof Test Coverage

<sup>4)</sup> All diagnostic functions are performed at least once within the diagnostic test interval

<sup>5)</sup> Maximum time between error recognition and error response