



Certificate of Compliance

Certificate: 70186173

Master Contract: 151079

Project: 70186173

Date Issued: 2018-10-03

Issued to: Endress+Hauser SE+Co. KG
Hauptstrasse 1
Maulburg, Baden-Württemberg 79689
GERMANY
Attention: Arno Götz

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Sam Zaffino
Sam Zaffino

PRODUCTS

CLASS - C225206 - PROCESS CONTROL EQUIPMENT

CLASS - C225286 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

Capacitive point level switch for bulk solids, model FTI26-xxxx.

Rated 12...30 Vdc, Output load max. 200 mA (one output) or 2 x 105 mA (two outputs), Power consumption max. 8W

Enclosure Type 4X/6P.

Ambient temperature range -25 to +70 °C (or -13 to +158°F)

Process temperature range -20 to +80 °C (or -4 to +176°F)

Pressure 87 PSI

APPLICABLE REQUIREMENTS

CSA Standards:

CAN/CSA-C22.2 No. 61010-1-12

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements



Certificate: 70186173

Project: 70186173

Master Contract: 151079

Date Issued: 2018-10-03

UL Standards:

UL Std. No. 61010-1 (3rd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 70186173

Master Contract: 151079

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70186173	2018-10-03	Issuance of cCSAus report for Ordinary location based on the tests performed under CB scheme std. IEC61010--1 and national differences for CA/US.