



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ20.1134X

This is to certify that the product

Pressure Transmitter

manufactured by Endress + Hauser SE + Co. KG

(Address:Hauptstrasse 1, D-79689 Maulburg, Germany)

which model is Cerabar S PMC71, PMP71/75

Ex marking

Ex iaIIC T2/T3/T4/T6 Ga/Gb, Ex iaIIC T2/T3/T4/T6 Gb,
Ex iaD 20 T85,
Ex iaD 20/21 T85, Ex tD A20/A21 IP66 T85°C,
Ex tD A20/A22 IP66 T85°C

product standard /

drawing number

960534-0007-A, 960535-0051-B, 960006411-C,
960006439-B

has been inspected and certified by NEPSI, and that it conforms
to GB 3836.1-2010,GB 3836.4-2010,GB 3836.20-2010,GB 12476.1-2013,
GB 12476.5-2013,GB 12476.4-2010

This Approval shall remain in force until 2025.05.07

Remarks

- 1.Conditions for safe use are specified in the attachment(s) to this certificate.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment(s) to this certificate.
- 3.Safe parameters specified in the attachment(s) to this certificate.
- 4.This certificate is also applicable for the product with the same type manufactured by Endress+Hauser (Suzhou) Automation Instrumentation Co., Ltd. (address: Su Hong Zhong Lu No.491, Suzhou-SIP, China)

Director



National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date 2020.05.08

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.