



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEx DEK 12.0046X** Page 1 of 5 Certificate history:  
Status: **Current** Issue No: 3 Issue 2 (2018-01-24)  
Date of Issue: 2020-08-06 Issue 1 (2015-10-30)  
Issue 0 (2012-09-14)  
Applicant: **Endress+Hauser SE+Co. KG**  
Hauptstraße 1  
79689 Maulburg  
Germany  
Equipment: **Remote display, Model FHX50**  
Optional accessory:  
Type of Protection: **Ex i**  
Marking: Ex ia IIC T6...T1 Ga  
Ex ia IIIC T100 °C or T105 °C Db  
Ex ic IIC T6...T1 Gc  
Ex ic IIIC T100 °C or T105 °C Dc

Approved for issue on behalf of the IECEx  
Certification Body:

**R. Schuller**

Position:

**Certification Manager**

Signature:  
(for printed version)

Date:

2020-08-06

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**DEKRA Certification B.V.**  
Meander 1051  
6825 MJ Arnhem  
Netherlands





# IECEX Certificate of Conformity

Certificate No.: **IECEX DEK 12.0046X**

Page 2 of 5

Date of issue: 2020-08-06

Issue No: 3

Manufacturer: **Endress+Hauser SE+Co. KG**  
Hauptstraße 1  
79689 Maulburg  
Germany

Additional manufacturing locations: **Refer to Annex 1 for additional manufacturing locations**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2017** Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

**IEC 60079-11:2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NL/DEK/ExTR12.0057/03](#)

Quality Assessment Report:

[DE/TUN/QAR06.0003/08](#)



# IECEx Certificate of Conformity

Certificate No.: **IECEx DEK 12.0046X**

Page 3 of 5

Date of issue: 2020-08-06

Issue No: 3

## **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

Remote Display Model FHX50 intended for use with transmitters of the ProToF platform or equivalent, to remotely provide display of the measurement values and configuration and control of the transmitter to which the display is connected.

The Remote Display is connected to the transmitter via a pluggable cable with a maximum length of 60 m as supplied by the manufacturer. A connection module is provided that is mounted inside the transmitter. This transmitter module is connected to the transmitter's display interface and may replace the internal display.

Alternate cables of different length may be used if the cable parameters comply with the electrical data.

The FHX50 remote display consists of a metal or polymeric enclosure, including a module for connection of the pluggable connection cable (receiver module) and a separately certified display unit complying with the specifications of the ProToF platform.

The Remote Display is provided with keys for local configuration and control.

The enclosure provides a degree of protection of at least IP20 according to IEC 60529.

## **SPECIFIC CONDITIONS OF USE: YES as shown below:**

For applications in explosive atmospheres requiring equipment of EPL Ga or EPL Db, electrostatic charges on the non-metallic parts of the polymeric GF27 enclosure and the cable shall be avoided.

For applications in explosive atmospheres requiring equipment of EPL Ga in combination with aluminum Remote Display enclosure G327, sparks caused by impact and friction shall be avoided.



# IECEx Certificate of Conformity

Certificate No.: **IECEx DEK 12.0046X**

Page 4 of 5

Date of issue: 2020-08-06

Issue No: 3

## Equipment (continued):

### Thermal data

-40 °C to +55 °C for temperature class T6, for polymeric enclosure,  
-50 °C or -40 °C to +60 °C for temperature class T6, for metal enclosure,  
-40 °C to +80 °C for temperature class T4, for polymeric enclosure  
-50 °C or -40 °C to +80 °C for temperature class T4, for metal enclosure.

The maximum surface temperature of the enclosure T100 °C (metal enclosure) respectively 105 °C (polymeric enclosure) is based on the maximum ambient temperature of 80 °C.

### Electrical data

Supply and input circuit (connector X800 of transmitter module):

In type of protection intrinsic safety Ex ia IIC, Ex ia IIIC, Ex ic IIC or Ex ic IIIC, with following maximum values:

$U_i = 7.3 \text{ V}$ ;  $I_i = 327 \text{ mA}$ ;  $P_i = 800 \text{ mW}$ ;  $C_i = 0 \text{ nF}$ ;  $L_i = 0 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboards with TRC[11;14;12;15]

$U_i = 7.3 \text{ V}$ ;  $I_i = 90 \text{ mA}$ ;  $P_i = 540 \text{ mW}$ ;  $C_i = 0 \text{ nF}$ ;  $L_i = 0 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboard with TRC[41]

Output circuit (connector X900, X901):

In type of protection intrinsic safety Ex ia IIC, Ex ia IIIC, Ex ic IIC or Ex ic IIIC, for connection of the remote display, with following maximum values:

$U_o = 7.3 \text{ V}$ ;  $I_o = 157 \text{ mA}$ ;  $P_o = 362 \text{ mW}$ ;  $C_o = 388 \text{ nF}$ ;  $L_o = 149 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboards with TRC[11;14;12;15]

$U_o = 7.3 \text{ V}$ ;  $I_o = 90 \text{ mA}$ ;  $P_o = 362 \text{ mW}$ ;  $C_o = 388 \text{ nF}$ ;  $L_o = 149 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboard with TRC[41]

Maximum allowed capacitance and inductance of the interconnection cable:

$C_c \leq 125 \text{ nF}$ ;  $L_c \leq 149 \text{ }\mu\text{H}$ .

The value of the parameters of the cable provided with the equipment are:

$C_c \leq 0.2 \text{ nF/m}$ ;  $L_c \leq 1 \text{ }\mu\text{H/m}$ .

Supply and input circuit remote display (connector X900, X901):

In type of protection intrinsic safety Ex ia IIC, Ex ia IIIC, Ex ic IIC or Ex ic IIIC, with following maximum values:

$U_i = 7.3 \text{ V}$ ;  $I_i = 157 \text{ mA}$ ;  $P_i = 362 \text{ mW}$ ;  $C_i = 263 \text{ nF}$ ;  $L_i = 0 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboards with TRC[11;14;12;15]

$U_i = 7.3 \text{ V}$ ;  $I_i = 90 \text{ mA}$ ;  $P_i = 362 \text{ mW}$ ;  $C_i = 263 \text{ nF}$ ;  $L_i = 0 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboard with TRC[41]

Supply and output circuit (connector X400 of receiver module):

$U_o = 7.3 \text{ V}$ ;  $I_o = 157 \text{ mA}$ ;  $P_o = 362 \text{ mW}$ ;  $C_o = 0 \text{ nF}$ ;  $L_o = 0 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboards with TRC[11;14;12;15]

$U_o = 7.3 \text{ V}$ ;  $I_o = 90 \text{ mA}$ ;  $P_o = 362 \text{ mW}$ ;  $C_o = 0 \text{ nF}$ ;  $L_o = 0 \text{ }\mu\text{H}$ , when transmitter module is in combination with ProToF Mainboard with TRC[41]



# IECEX Certificate of Conformity

Certificate No.: **IECEX DEK 12.0046X**

Page 5 of 5

Date of issue: 2020-08-06

Issue No: 3

## **DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**

1. Assessed per IEC 60079-0 Ed. 7

### **Annex:**

[224773900-Annex1.pdf](#)

## Annex 1 to Certificate of Conformity IECEx DEK 12.0046X

### Manufacturing locations

1. Endress+Hauser SE+Co. KG  
Hauptstraße 1  
79689 Maulburg  
Germany
2. Endress+Hauser GmbH+Co. KG  
Miramstraße 87  
34123 Kassel  
Germany
3. Endress+Hauser (USA) Automation Instrumentation Inc.  
2340 Endress Place  
Greenwood, Indiana 46143  
USA
4. Endress+Hauser (Suzhou) Automation Instrumentation Co. Ltd.  
China-Singapore Industrial Park (SIP)  
Su-Hong-Zhong-Lu, No. 491  
Jiangsu Province, 215021 Suzhou  
China
5. Endress+Hauser (India) Automation Instrumentation Pvt. Ltd.  
M-192, Waluj  
Aurangabad - 431136  
Maharashtra State  
India
6. Endress+Hauser Yamanashi Co. Ltd.  
862-1, Sakaigawa-cho  
Fuefuki-shi  
406 0846 Yamanashi  
Japan
7. Endress+Hauser (Brasil),  
Instrumentação e Automação Ltda.,  
Avenida Antonio Sesti, 600, Itatiba/SP  
Brasil