XA00486F-D/00/EN/

15.20 71517015 2020-10-05

# Safety Instructions Solicap S FTI77

ATEX: II 1 D Ex ia IIIC T80°C  $T_{200}$  130°C Da

II 1/2 D Ex ia IIIC T80°C T<sub>200</sub> 130°C Da/Db

II 1/2 D Ex ia/tb IIIC T90°C Da/Db

IECEx: Ex ia IIIC T80°C T<sub>200</sub> 130°C Da

Ex ia IIIC T80°C  $T_{200}$  130°C Da/Db

Ex ia/tb IIIC T90°C Da/Db







### Solicap S FTI77

#### Table of contents

About this document
Associated documentation
Supplementary documentation
Manufacturer's certificates
Manufacturer address5
Other standards5
Extended order code5
Safety instructions: General 8
Safety instructions: Special conditions 8
Safety instructions: Installation
Safety instructions: Zone 20
Temperature tables
Connection data

### About this document



This document has been translated into several languages. Legally determined is solely the English source text.

The document translated into EU languages is available:

- In the download area of the Endress+Hauser website:
   www.endress.com -> Downloads -> Manuals and Datasheets ->
   Type: Ex Safety Instruction (XA) -> Text Search: ...
- In the Device Viewer: www.endress.com -> Product tools -> Access device specific information -> Check device features



If not yet available, the document can be ordered.

### Associated documentation

This document is an integral part of the following Operating Instructions:

BA00381F/00

### Supplementary documentation

Explosion-protection brochure: CP00021Z/11

The Explosion-protection brochure is available:

- In the download area of the Endress+Hauser website:
   www.endress.com -> Downloads -> Brochures and Catalogs -> Text Search: CP00021Z
- On the CD for devices with CD-based documentation

### Manufacturer's certificates

#### **EU Declaration of Conformity**

Declaration Number: EG09001

The EU Declaration of Conformity is available: In the download area of the Endress+Hauser website: www.endress.com -> Downloads -> Declaration -> Type: EU Declaration -> Product Code: ...

#### EU type-examination certificate

Certificate number: BVS 09 ATEX E 030

List of applied standards: See EU Declaration of Conformity.

#### **IEC Declaration of Conformity**

Certificate number: IECEx BVS 15.0009

Affixing the certificate number certifies conformity with the following standards (depending on the device version):

IEC 60079-0:2017IEC 60079-11:2011IEC 60079-31:2013

### Manufacturer address

Endress+Hauser SE+Co. KG Hauptstraße 1 79689 Maulburg, Germany

Address of the manufacturing plant: See nameplate.

#### Other standards

Among other things, the following standards shall be observed in their current version for proper installation:

- IEC/EN 60079-14: "Explosive atmospheres Part 14: Electrical installations design, selection and erection"
- EN 1127-1: "Explosive atmospheres Explosion prevention and protection - Part 1: Basic concepts and methodology"

### Extended order code

The extended order code is indicated on the nameplate, which is affixed to the device in such a way that it is clearly visible. Additional information about the nameplate is provided in the associated Operating Instructions.

#### Structure of the extended order code

FTI77	-	********	+	A*B*C*D*E*F*G*
(Device		(Basic		(Optional
type)		specifications)		specifications)

#### \* = Placeholder

At this position, an option (number or letter) selected from the specification is displayed instead of the placeholders.

#### Basic specifications

The features that are absolutely essential for the device (mandatory features) are specified in the basic specifications. The number of

> positions depends on the number of features available. The selected option of a feature can consist of several positions.

#### Optional specifications

The optional specifications describe additional features for the device (optional features). The number of positions depends on the number of features available. The features have a 2-digit structure to aid identification (e.g. JA). The first digit (ID) stands for the feature group and consists of a number or a letter (e.g. J = Test, Certificate). The second digit constitutes the value that stands for the feature within the group (e.g. A = 3.1 material (wetted parts), inspection certificate).

More detailed information about the device is provided in the following tables. These tables describe the individual positions and IDs in the extended order code which are relevant to hazardous locations.

#### Extended order code: Solicap S



The following specifications reproduce an extract from the product structure and are used to assign:

- This documentation to the device (using the extended order code on the nameplate).
- The device options cited in the document.

Device type

FTI77

#### Basic specifications

Position	Position 1 (Approval)			
Selected option		Description		
FTI77	В	ATEX Ex ia/tc IIIC T90°C Da/Dc		
	С	ATEX Ex ia/tb IIIC T90°C Da/Db		
F ATEX II 1 D, II 1/2 D, II 1/3 D Ex ia IIIC T Da/Dc		ATEX II 1 D, II 1/2 D, II 1/3 D Ex ia IIIC T80°C T <sub>200</sub> 130°C Da, Da/Db, Da/Dc		
	4	IECEx Ex ia/tb IIIC T90°C Da/Db		
5 IECEx Ex ia/tc IIIC T90°C Da/Dc		IECEx Ex ia/tc IIIC T90°C Da/Dc		
	6	IECEx Ex ia IIIC T80°C T <sub>200</sub> 130°C Da, Da/Db, Da/Dc		

Position 2 (Application)			
Selected	l option	Description	
FTI77	1	Solid, fine-grained	
	2	Solid, coarse-solids	

Position 3 (Inactive Length L3)				
Selected option		Description		
FTI77	Α	Not selected		
	B, C, L, M	mm/in, steel		
E, F, ( N, P, 1		mm/in, 316L		
	H, S	mm/in, 316L+125mm/5in active build-up protection, 316L		

Position 4, 5 (Active Probe Length L1)			
Selected option Description		Description	
FTI77	Ax, Ex	mm/in, sword, steel	
	Bx, Fx	mm/in, sword, 316L	
	Cx, Gx	mm/in, mm/in rope, steel zinc coated, tension weight steel	
	Dx, Hx	mm/in, mm/in rope, 316, tension weight 316L	

Position	Position 9 (Electronics, Output)			
Selected option		Description		
FTI77	Y	Special version: FEI50H		
	1 1)	FEI51; 2-wire 19-253VAC		
	2 1)	FEI52; 3-wire PNP 10-55VDC		
	4 1)	FEI54; relay DPDT, 19-253VAC, 19-55VDC		
	5	FEI55; 8/16mA, 11-35VDC		
	7 2)	FEI57S; 2-wire PFM		
	8 2)	FEI58; NAMUR+test button (H-L signal)		

- 1) 2)
- Only in connection with supply circuit "Non-intrinsically safe" Only in connection with supply circuit "Intrinsically safe Ex ia"  $\,$

Position 10 (Housing)			
Selected option		Description	
FTI77	1	F15 316L hygiene IP66/67 NEMA4X	
3 F17 Alu IP66/67 NEMA4X 4 F13 Alu IP66 NEMA4X + gas-tight pro		F17 Alu IP66/67 NEMA4X	
		F13 Alu IP66 NEMA4X + gas-tight probe seal	
	5	T13 Alu IP66 NEMA4X + gas-tight probe seal + separate conn. compartment	
	6	F27 316L IP66/67 NEMA6P + gas-tight probe seal	

Position 12 (Type of probe)			
Selected option Description			
FTI77 1		Compact	
	2, 3, 4,	mm/in L4 cable > separate housing	

#### Optional specifications

No options specific to hazardous locations are available.

#### Safety instructions: General

- Staff must meet the following conditions for mounting, electrical installation, commissioning and maintenance of the device:
  - Be suitably qualified for their role and the tasks they perform
  - $\ \ \, \blacksquare$  Be trained in explosion protection
  - Be familiar with national regulations
- Install the device according to the manufacturer's instructions and national regulations.
- Do not operate the device outside the specified electrical, thermal and mechanical parameters.
- Avoid electrostatic charging:
  - Of plastic surfaces (e.g. housing, sensor element, special varnishing, attached additional plates, ..)
  - Of isolated capacities (e.g. isolated metallic plates)

#### Safety instructions: Special conditions

Permitted ambient temperature range at the electronics housing, permitted process temperature:


 $-50 \,^{\circ}\text{C} \le T_a \le +70 \,^{\circ}\text{C}$ 

- Observe the information in the temperature tables.
- In the event of additional or alternative special varnishing on the housing or other metal parts:
  - Observe the danger of electrostatic charging and discharge.
  - Do not rub surfaces with a dry cloth.

Basic specification, Position 10 (Housing) = 4, 5 and covers with glass window Restriction to  $-40~{\rm ^{\circ}C} \le T_a \le +70~{\rm ^{\circ}C}$ .

#### Safety instructions: Installation

Supply circuit "Intrinsically safe Ex ia"




A0033933

#### **1**

- A Zone 20, Zone 21, Zone 22
- B Zone 20
- 1 Strut or rope with tensioning weight
- 2 Probe
- 3 Adapter
- 4 Electronic insert
- 5 Housing
- 6 Certified associated apparatus

#### Supply circuit "Non-intrinsically safe"



A0033933

#### 

- A Zone 21, Zone 22
- B Zone 20
- 1 Strut or rope with tensioning weight
- 2 Probe
- 3 Adapter
- 4 Electronic insert
- 5 Housing
- 6 Power supply
- Do not open in a potentially explosive dust atmosphere.
- Observe the maximum process conditions according to the manufacturer's Operating Instructions.
- At high medium temperatures, note flange pressure load capacity as a factor of temperature.
- To maintain the ingress protection of the housing:
  - Screw the cover tight.
  - Mount the cable entry correctly.
- After aligning (rotating) the housing, retighten the fixing screw (see Operating Instructions).

■ Connect the device using suitable cable and wire entries of protection type "Equipment dust ignition protection by enclosure (Ex t)" or "Increased safety (Ex e)" (ingress protection of at least IP65). Lay connecting cable and secure.

- Seal unused entry glands with approved sealing plugs that correspond to the type of protection.
- Install the device to exclude any mechanical damage or friction during the application. Pay particular attention to flow conditions and tank fittings.
- Mechanically fix probes which are more than 3 m (e.g. using guy ropes).
- Maximum rope tensile load:
  - Fine-grained bulk solids: 7.5 kN
  - Coarse-grained bulk solids: 20 kN
- Maximum lateral load including strut:
  - Fine-grained bulk solids: 250 Nm
  - Coarse-grained bulk solids: 800 Nm

Basic specification, Position 10 (Housing) = 1 Before operation:

- Screw in the cover all the way.
- Tighten the securing clamp on the cover.

Basic specification, Position 10 (Housing) = 3, 4, 5, 6 Tighten the cover with torque 12 Nm.

#### Intrinsic safety

Observe the pertinent guidelines when interconnecting intrinsically safe circuits.

#### Potential equalization

Install potential equalization between the certified associated apparatus (non-hazardous area,  $\mathbb{A}$ ) and the device (explosion-hazardoue area,  $\mathbb{A}$ ).

#### Safety instructions: Zone 20

- In the event of potentially explosive dust/air mixtures, only operate the device under atmospheric conditions.
  - Temperature: -20 to +60 °C
  - Pressure: 80 to 110 kPa (0.8 to 1.1 bar)
  - Air with normal oxygen content, usually 21 % (V/V)
- If no potentially explosive mixtures are present, or if additional protective measures have been taken, the device may also be operated under non-atmospheric conditions in accordance with the manufacturer's specifications.


## Temperature tables

	Probe and electronics housing in Zone 20		
	Connection to certified intrinsically safe power circuits		
Max. surface temperature at an ambient temperature of 70 °C	$80^{\circ}\text{C}$ Deposited material with a layer of 200 mm $T_{200}$ 130 $^{\circ}\text{C}$		

	Probe in	Electronics housing in Zone 21, Zone 22		
	Zone 20	Connection to certified intrinsically safe power circuits	Connection to non-intrinsically safe power circuits	
Max. surface temperature at an ambient temperature of 70 °C	70℃	80 ℃	90°C	
The compact version can also be used for process temperatures between +70 to +400 °C if it can also be ensured that the ambient temperature at the electronics housing does not exceed the values as indicated in the temperature graphic.	400°C	40 °C	40°C	

#### **Compact version**

Strut and rope version, partially insulated




₩ 3

 $T_a$  Ambient temperature in  ${}^{\circ}C$ 

Process temperature in  ${}^{\circ}\!C$ 

#### Version with separate housing



A0033928

€ 4

 $T_a$  Ambient temperature in °C

Process temperature in  ${}^\circ\!C$ 

Temperature at the separate housing:  $-40~{^\circ}\text{C} \le T_a \le +70~{^\circ}\text{C}$ 

#### **Connection data** Connection to certified intrinsically safe circuits Ex ia (Zone 20)

Basic specification, Position 9 (Electronics; Output)	Electrical data
Y	$\begin{split} &U_i \leq 30 \ V \\ &I_i \leq 120 \ mA \\ &P_i \leq 1 \ W \\ &C_i \leq 2.4 \ nF \\ &L_i \leq 0 \end{split}$
5	$\begin{split} &U_i \leq 35 \text{ V} \\ &I_i \leq 100 \text{ mA} \\ &P_i \leq 1 \text{ W} \\ &C_i \leq 2.4 \text{ nF} \\ &L_i \leq 0 \end{split}$
7	$\begin{split} &U_i \leq 16.1  V \\ &I_i \leq 100  mA \\ &P_i \leq 1  W \\ &C_i \leq 2.4  nF \\ &L_i \leq 0 \end{split}$
8	$\begin{split} &U_i \leq 18 \ V \\ &I_i \leq 52 \ mA \\ &P_i \leq 170 \ mW \\ &C_i/L_i \leq 0 \end{split}$

### Connection to non-instrinsically safe circuits (Zone 20/21 or Zone 20/22) $\,$

Basic specification, Position 9 (Electronics; Output)	Electrical data
Y 1)	U ≤ 35 V <sub>DC</sub>
5 1)	U ≤ 35 V <sub>DC</sub>

#### 1) With Basic specification, Position 10 (Housing) = 5 only with limiting module

Basic specification, Position 9 (Electronics; Output)	Power supply	Relay circuit
1	19 to 253 V <sub>AC</sub>	-
2	10 to 55 V <sub>DC</sub>	-
4	19 to 253 V <sub>AC</sub>	$253 \text{ V}_{AC}$ / $6 \text{ A}$ $1500 \text{ VA}$ / $\cos \phi = 1$ $750 \text{ VA}$ / $\cos \phi > 0.7$
	19 to 55 V <sub>DC</sub>	30 V <sub>DC</sub> / 4 A 125 V <sub>DC</sub> / 0.2 A

#### Cable entry parameters

Thre	ad	Clamping range	Material	Sealing insert	O-ring
M20		ø 8 to 10.5 mm <sup>1)</sup> ø 6.5 to 13 mm <sup>2)</sup>	Ms, nickel-plated	Silicone	EPDM (ø 17x2)

- 1) Standard
- 2) Separate clamping inserts available



- The tightening torque refers to cable glands installed by the manufacturer:
  - Recommended torque to connect the cable gland into the housing: 3.75 Nm
  - Recommended torque to tighten the cable into the cable gland: 3.5 Nm
  - Maximum torque to tighten the cable into the cable gland:
     10 Nm
- This value may be different depending on the type of cable.
   However, the maximum value must not be exceeded.
- Only suitable for fixed installation. The operator must pay attention to a suitable strain relief of the cable.
- To maintain the ingress protection of the housing: Install the housing cover, cable glands and blind plugs correctly.







www.addresses.endress.com