



Government of India
Ministry of Commerce & Industry
Petroleum & Explosives Safety Organisation (PESO)
5th Floor, A-Block, CGO Complex, Seminary Hills,
Nagpur - 440006

E-mail : explosives@explosives.gov.in
Phone/Fax No : 0712 -2510248, Fax-2510577

Approval No : A/P/HQ/MH/104/7400 (P548781)

Dated : 15/10/2022

To,

M/s. Endress+Hauser Conducta GmbH+Co.KG,
Dieselstr.24, Gerlingen
70839
GERMANY

Sub : Approval of Intrinsically Safe Type Electrical Equipment under Petroleum Rules 2002- Regarding.

Sir(s),

Please refer to your letter No. OIN1165774 dated 26/09/2022 on the subject.

The following Ex electrical equipment(s) manufactured by you according to IEC 60079-0 : 2017, IEC 60079-11 : 2011, standards and covered under DEKRA testing and Certification GmbH Test reports mentioned below is/are approved for use in Zone 1, Zone 2 of Gas IIC hazardous areas coming under the the Petroleum Rules, 2002 administered by this Organization.

Sr. No	Description	Safety Protection	Equipment reference Number	Test Agency			Drawing no
				Name	Certificate No.	Certificate Date	
1	MEMOSENS-Sensors pH/ORP type *PS**E-	Ex ia IIC T3/T4/T6 Ga	P548781/1	DEKRA testing and Certification GmbH	IECEx BVS 19.0056X	08/02/2021	211038543

This Approval is granted subject to observance of the following conditions:-

- 1)The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the DEKRA testing and Certification GmbH Test Reports referred to above.
- 2)The equipment shall be used only with approved type of accessories and associated apparatus.
- 3)Each equipment shall be marked either by raised lettering cast integrally or by plate attached permanently to the main structure to indicate conspicuously:-
 - (a) Name of the manufacturer
 - (b) Name and number by which the equipment is identified.
 - (c) Number & date of the test report of the DEKRA testing and Certification GmbH applicable to the equipment.
 - (d) Equipment reference number of this letter by which use of apparatus is approved.
 - (e) Protection level.
- 4) A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the DEKRA testing and Certification GmbH Test report and is identical with the one tested and certified at DEKRA testing and Certification GmbH shall be furnished with each equipment.
- 5) The customer shall be supplied with a copy of this letter, an extract of the conditions and maintenance schedule, if any, recommended by DEKRA testing and Certification GmbH in their test reports and copy of instructions booklet detailing operation & maintenance of the equipment so as to maintain its Flame Proof characteristics.
- 6) The After sales service and maintenance of subject equipment shall be looked after by your representative Endress+Hauser India Pvt.Ltd., Endress+Hauser India Pvt.Ltd.

Conditions of the Approval:-

The approval for above equipment is subject to validity of IECEx Quality Assessment Report No. DE/BVS/QAR06.0005

This approval also covers the permissible variations as approved under the DEKRA testing and Certification GmbH test reports referred above. This approval is liable to be cancelled if any of the conditions of the approval is violated or not complied with . The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users/your customers of the subject equipment may please be collected and furnished to this office for verification and record on annual basis.
The Approval is Valid upto 31/12/2026

Yours faithfully,

(A.B. Tamgadge)
Dy. Chief Controller of Explosives
For Chief Controller of Explosives
Nagpur

Copy to :

1. Jt. Chief Controller of Explosives, West Circle, MUMBAI
2. Endress+Hauser India Pvt.Ltd., Endress+Hauser India Pvt.Ltd.

for Chief Controller of Explosives
Nagpur

(For more information regarding status, fees and other details please visit our website <http://peso.gov.in>)

This is System Generated document. Signature is not required.