

**Company** Endress+Hauser Flowtec AG, Kägenstrasse 7, CH-4153 Reinach

declares as manufacturer, for the following products

**Products**  
**Promag W**, with the options "Hard rubber" and "KTW/W270 drinking water approval"  
**Promag 55S** with option "Hard rubber KTW/W270 Drinking water approval"


**Statement**  
The used Hard Rubber Liner for the products above met the requirements of FEA (Federal Environment Agency) for volatile materials in contact with drinking water up to 23°C.

This is certified in the test report of the Hygienic-Institut des Ruhrgebiets with the test report number W-368176an-22-SI/Men.

The test report K-370073-23-Kr/st is valid between 13.02.2023 and 12.02.2024.

This declaration shall be valid until 2024, February 12th

Reinach, 2023, February 22th  
Endress+Hauser Flowtec AG



i.V.

Christian Matt

Head of Main Department  
RDE R&D Electronics



i.V.

Ulrich Kirstetter

Teamleader MVGSA Application Support