

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Endress+Hauser Flowtec AG Kägenstrasse 7 4153 Reinach Switzerland
Measuring instrument	A non-interruptible <b>measuring system</b> for the measurement of LNG. Manufacturer's mark or name : Endress+Hauser Flowtec AG Type designation : LNG Bunker Metering System Accuracy class : 1.5 or 2.5 Destined for the measurement of : Liquefied Natural Gas (LNG)
Valid until	18 December 2030
Initially issued	18 December 2020
Remarks	+ – This revision replaces the previous revision.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
29 September 2023

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at  
<http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

## 1 General information about the measuring system

Properties of this measuring system, whether mentioned or not, shall not conflict with the legislation.

### 1.1 Essential parts

#### 1.1.1 Measurement sensor

Endress+Hauser Flowtec AG, type Promass F or Promass Q.

See Evaluation certificate number TC7149 for details about the measurement sensor.

#### 1.1.2 Flow transmitter

The following flow transmitter can be used:

- Endress+Hauser Flowtec AG, type Promass 300 or Promass 500.

See Evaluation Certificate number TC10822 for details.

The mandatory parameter settings for the Promass 300/500 flow transmitters for the bunkering application are mentioned in Annex 1 of this EU-type examination certificate.

Please note that these settings override the settings mentioned in Annex 1 of TC10822 only for bunkering applications.

#### 1.1.3 Flow computer for the measurement of LNG

The following flow computers can be used:

- Newflow Limited, type NANOflow

See Evaluation Certificate TC11943 for details on the hardware. For this application, the NANOflow is equipped with a dedicated LNG software:

- See chapter 1.2.7 for the software versions.
- See chapter 1.2.8 for information on the dedicated functions of the NANO flow computer.

#### 1.1.4 Flow computer for the batch totalisation

The following flow computer can be used:

- Endress+Hauser FLOWTEC AG, type LNG Metering Computer (LNG MC).

See Evaluation certificate TC11955 for details.

#### 1.1.5 Correction device for the measurement of vapour return

The above mentioned 'Measurement sensor' (chapter 1.1.1), 'Flow transmitter' (chapter 1.1.2) and 'Flow computer for the measurement of LNG' (chapter 1.1.3) can be used as correction device for the vapour return line (measurement of boil-off gas (BOG)).

### 1.2 Essential characteristics

In addition to the characteristics as stated on page 1 of this EU-type examination certificate the following characteristics apply to the measuring system:

#### 1.2.1 Flow rate range ( $Q_{\min}$ – $Q_{\max}$ )

- $Q_{\min}$ : Shall not be smaller than any  $Q_{\min}$  of the components making up the measuring instrument.
- $Q_{\max}$ : Shall not be larger than any  $Q_{\max}$  of the components making up the measuring instrument.
- The ratio  $Q_{\max}/Q_{\min}$  shall be at least 4:1.

- 1.2.2 Minimum measured quantity (MMQ)  
 The MMQ value shall have the form  $1 \times 10^n$ ,  $2 \times 10^n$  or  $5 \times 10^n$ , with n being any integer or zero. The MMQ is the largest of:
- The MMQ stated in the Evaluation Certificate of the measurement sensor.
  - nnn times the largest display scale interval (see table below).
  - nnn times the printed scale interval (see table below).
  - In case the pipe work between measurement sensor and transfer point is not always full of liquid during shutdown periods, the following shall be taken into account regarding the liquid which is not measured or not delivered:
    - If not corrected, the MMQ is nnn times the mass of this liquid.
    - If corrected, the MMQ is nnn times the estimated variance in the corrected mass of this liquid.

Where nnn is determined by:

Accuracy class	1,5	2,5
nnn	67	100

- 1.2.3 Maximum operating pressure ( $P_{max}$ ):  
 The maximum operating pressure shall not exceed the maximum pressure of the measurement sensor as stated in Evaluation Certificate number TC7149.
- 1.2.4 Temperature range liquid: -200 °C ... -120 °C.
- 1.2.5 Temperature range ambient: -25 °C ... +55 °C.
- 1.2.6 Environment classes: M1 / E2
- 1.2.7 The NANO flow computer used a dedicated LNG app for this application, instead of the standard measurement app that is part of TC11943. The following app versions and corresponding checksums are approved:

Part	Version	Checksum	Remark
System	4v7r8310-R	Metrology Block Checksum 5956577C409BCBF2	Used with HMI <sup>[1]</sup> version 1
	4v7r9214-R		Used with HMI <sup>[1]</sup> version 2
ISO6578_2017	-	FDA59B33E2994E8A42A6817D9A473F26	Density calculation
ISO6976_2016	-	C2E97F8644997F84DA5B18320EAE9C4D	Calorific value calculation
Totaliser	-	281EE714633B1E8D5D6623BB61936774	

The system software version can be checked on the LNG Metering Computer. The version is indicated on the same display as LNG Metering Computer software version.

[1] HMI version of the LNG Metering computer.

The checksums of the ISO6578\_2017, ISO6976\_2016, and Totaliser part can be verified via the webserver of the NANO flow computer. The information is shown via login with username user with password nano. This gives a read only access to the NANO flow computer. Via menu items Home – Logs & Info – Constants Log the settings of the NANO flow computer are shown. The software checksums are presented in the second block of the file. If needed, the shown information can be printed.

## 1.2.8 Energy and density calculation of the LNG

- The NANO flow computer makes the following calculations:
  - Energy content of the LNG using the composition measured by the Raman analyser. Although not part of the legal metrology information, the energy calculation is compliant with the ISO 6976:2016 standard. The following energy information is available: Gross and Net calorific value (MJ/kg) and Gross and Net Wobbe Index (MJ/m<sup>3</sup>).
  - Total energy delivered based on the calculated gross calorific value for the LNG and on a fixed calorific value for the vapour return.
  - Density of the LNG using the composition and the actual product temperature. Although not part of the legal metrology information, the density calculation is compliant with the ISO 6578:2017 standard. It is **NOT** allowed to use the density for the conversion from measured mass to measured volume.
  - Calculation of the flow weighted averages of LNG composition, calorific values and LNG density.
  - From version 4v7r9214-R onwards, the methane number is calculated according the following methods: PKI, CARB, ISO 14503 L/C, and ISO 14503 H/C. At the start of the measurement the used method is selected on the LNG Metering Computer. The methane number is for information purposes only.

## 1.3 Essential shapes

### 1.3.1 Configuration

Accuracy class	Type of measuring system	Schematic drawing	Remarks
1,5	Measuring systems for LNG	Annex 2, page 2.	
2,5	Measuring systems for cryogenic liquids (temperature below – 153 °C)		

- The essential parts stated in paragraph 1.1 can be applied in each desired combination as long as there is no conflict with the concerning Evaluation or Parts Certificates.

### 1.3.2 Inscriptions

- The following information is clearly visible on the nameplate:
  - CE marking including the supplementary metrological marking (M + last 2 digits of the year in which the instrument has been put into use).
  - Notified Body identification number, following the supplementary metrological marking.
  - EU-type examination certificate number: **T11948**.
  - Manufacturer's name, registered trade name and/or registered trademark.
  - Manufacturer's postal address.
  - Type designation.
  - Year of manufacture and serial number.
  - Accuracy class.

- Minimum and maximum flow rate.
- Maximum pressure.
- Name(s) or nature(s) of the product(s) to be measured.
- Mechanical and electromagnetic environment class.
- Ambient temperature range.
- Liquid temperature range.
- Serial numbers of all essential parts stated in paragraph 1.1 (optional, see clause 2).

Remarks:

The nameplate must be clearly visible without removing the covers.  
See Annex 2, page 1 for an example of the nameplate.

- Further inscriptions:

- The inscription "Minimum Measured Quantity ... kg" in the vicinity of the display of the calculating and indicating device and/or on the nameplate.
- The inscriptions on the essential parts as mentioned in the applicable Evaluation Certificates or Parts Certificates.

## 1.4 Conditional parts

### 1.4.1 Raman analyser

A Raman analyser is used to determine the composition of the LNG. The composition contains the molar fraction of methane, ethane, propane, n-butane, i-butane, n-pentane, i-pentane and nitrogen. Other components are not measured, as these are only present in trace quantities due to the cryogenic product temperatures.

### 1.4.2 Temperature sensors

4-Wire Class A PT-100 sensors to measure the liquid temperature. The temperature sensor can be installed in a thermowell. Each sensor has its own temperature transducer or is directly connected to the flow computer.

### 1.4.3 Flow control valve

An on/off valve or a flow control valve is located upstream and/or downstream of the measurement sensor and is used to control the flow rate through the measurement sensor.

### 1.4.4 Check valve or non-return valve

A non-return valve can be fitted downstream of the measurement sensor to prevent the reverse flow to be measured with the measuring system.

### 1.4.5 Liquid return valve (optional for Cryogenic products and LNG)

In order to pre-cool the meter before the delivery, a recirculation line downstream of the meter can be used. The valve for opening and closing this recirculation line shall be safe guarded. During the delivery, this valve must be closed, and an alarm shall be generated if this valve comes to the 'not closed' status during the delivery.

### 1.4.6 Pipeline connections

The pipeline connection shall be such that there are no by-passes over the measuring sensor. Other connections to the pipelines can be used for filling the system or gas-exchange. It should be clear to both parties of the transaction that these valves should be closed. Temporary seals can be used during the transaction that it is ensured that the valves are closed during the delivery.

- 1.4.7 **Printing device**  
A printer is connected to the flow computer and is used for printing the reports (deliveries), events and alarms. The printer can be of any brand and type under the condition that it is equipped with a paper out detection and that the communication with the printer is safeguarded.
- 1.4.8 **Memory device**  
The memory device of the LNG Metering Computer is programmed in such way that no overwriting of data batches occurs before settlement of the transaction has taken place.
- 1.5 Conditional characteristics**
- 1.5.1 **Elimination of air or gases**  
During a delivery, no air or gas shall pass through the measuring sensor.
- 1.5.2 **Vapour return / Boil-off Gas (BOG) meter (optional)**
- The correction device is optional and can be used for the measurement of the amount of gas through the vapour return line, which is subtracted by the flow computer from the batch delivered. The operator shall indicate at the start if the BOG line is used or not.
  - The vapour recovery flow can fluctuate greatly, and so the sensor size selected should be based upon the  $Q_{\max}$  vapour that is expected in normal operations.
  - The delivered corrected amount shall be calculated and presented in mass.
  - The calculation of the correction shall be covered by the approval of the flow computer mentioned in paragraph 1.1;
  - The accuracy of the correction device shall be such that the residual effect after the correction is smaller than one third of the applicable Maximum Permissible Error (MPE) of the measuring system.
- 1.5.3 **Protection measures and alarms**
- Protection measures shall be arranged that the measurement can only start when the essential parts mentioned in paragraph 1.1 are ready for operation.
  - Alarms occurring in the essential parts mentioned in paragraph 1.1 shall be transferred to the flow computer. The presence of such an alarm shall be indicated, stored and/or printed by the flow computer. In case of an interruptible measuring system, the flow shall be stopped, and the ongoing delivery shall be ended.
- 1.6 Conditional shapes**
- Housing  
The LNG Metering Computer, the NANO flow computers, and the Raman analyser can be installed in one or more cabinets.
- 1.7 Non-essential parts**
- Pipe work and connections.
  - Valves.
  - Hose(s).
  - Filter/strainer.
  - Drain valves.
  - Pump.
  - Temperature transducers (not for legal metrology).
  - Pressure transducers (not for legal metrology).

## 2 Seals

The following items of the measuring system are sealed:

- Nameplate to the frame of the measurement system. Removal of the nameplate without destroying it or without breaking a seal shall not be possible.
- If the serial numbers of the essential parts stated in paragraph 1.1 are not mentioned on the nameplate, the essential parts have to be sealed against removal.
- For sealing of the essential parts, see the applicable Evaluation Certificates or Parts Certificates.
- Valves installed between the measurement sensor and the transfer point that allow diversion of the measured product from the normal path, are sealed against opening. This requirement is not applicable if opening of the valve (during a delivery) leads to an alarm.

## 3 Conditions for conformity assessment

### 3.1 Verification procedure of the system

- Examination for conformity of the measuring system according to this EU-type examination certificate.
- Essential parts covered by an Evaluation Certificate or Parts Certificate shall be constructed and set-up according to the applicable Evaluation/Parts Certificate.
- In case the measurement is non-repeatable and one of the trading parties is absent, a printing device and/or memory device shall be used for the registration of the measurement data.
- Verification of the correct parameter settings of the essential parts.

### 3.2 Verification procedure of the measurement transducer

- See "Conditions for Conformity Assessment" as mentioned in Evaluation Certificate TC7149.

This part describes the standard procedure (on site calibration or calibration in a test lab) as well as an alternative method based on water calibration only.

As an additional note on chapter 4.4 (Step 2) of procedure CPC-EH-01, the following is also accepted:

- As it is difficult to maintain stable and safe operating conditions during the zero-point verification, it is acceptable to divide the zero-point verification in multiple shorter verifications, under the condition that:
  - The total time of zero-point verification is at least equal to 3 minutes.
  - The value of zero-point verification to calculate with is the average of the performed verifications.
  - Between the verifications, the measurement sensor is flushed for at least 3 minutes and until stable operating conditions are reached again.
- The procedure as described in chapter 4.7 of procedure CPC-EH-01, which describes an alternative method for zeroing in case of extended operating conditions, for example measuring LNG.
- The on value for the low flow cut off of the vapour return meter (BOG) shall be related to the minimum flow rate for gas measurement and not the minimum flow rate of this LNG system. Also, see note (7) of Annex 1.

**Mandatory parameter setting Promass 300 and 500 flow transmitters in case of bunkering. These setting override the settings mentioned in Evaluation Certificate TC10822.**

General settings for all parameters (where applicable):

Mass unit: t, kg or g  
 Mass flow unit: Metrical (for example kg/min)  
 Volume unit: m<sup>3</sup>; dm<sup>3</sup>; cm<sup>3</sup>; L or ml  
 Volume flow unit: Metrical (for example m<sup>3</sup>/h)  
 Density unit: Metrical (for example kg/m<sup>3</sup>)  
 Temperature unit: °C or K  
 Pressure unit: Metrical unit  
 Simulation modes: Shall be disabled

Menu	Sub Menu	Sub sub menu	Parameter	Value
-			Display Language	English (preferred); local language
Operation			Locking Status	CT act.; CT act.-def.par.
Setup			Medium selection	Liquid Gas for BOG meter
	Advanced	Pulse / frequency / Switch output	Operation mode	Frequency
			Minimum frequency	0 Hz
			Maximum frequency	≤ 10 kHz
			Value frequency low	0
			Value frequency high	See note (1)
			Operating mode	Passive
			Failure mode	Actual value
			Curr.output	
	20 mA value			
	PFS output		Assign pulse	Mass flow
			Value per pulse	See note (3)
			Pulse width	See note (4)
	Low flow cut off		Assign variable	Mass flow
			On value	See note (5)
Off value			See notes (6) and (7)	

**Mandatory parameter setting Promass 300 and 500 flow transmitters in case of LNG bunkering.**

**These setting override the settings mentioned in Evaluation Certificate TC10822.**



Menu	Sub Menu	Sub sub menu	Parameter	Value
Setup	Partial pipe det		Assign variable	Density
			Low value	See note (8)
			High value	
	Advanced setup	Totaliser n	Operation mode	See note (9)
			Failure mode	Actual value
	Communication		Baud rate	19200 or 38400
			Data transfer mode	RTU
			Parity	Even
			Byte order	1-0-3-2
			Delay tele.reply	0 ms
Failure mode			Last valid value	
Expert	System	Diagn. handling	Alarm delay	0
	Process param.		Flow damping	In accordance with the calibration data
			Density damping	
Temp. Damping				
Expert	Sensor	Sensor adjust.	Install direct.	Correct installation direction shall be selected.
		Variable adjust	Mass flow offset	See note (10)
			Mass flow factor	See note (11)
		Calibration	Cal.Factor	According calibration data
			Nominal diameter	Correct size
			C0 ... C5	According calibration data

**Mandatory parameter setting Promass 300 and 500 flow transmitters in case of LNG bunkering.**

**These setting override the settings mentioned in Evaluation Certificate TC10822.**


## Notes to the mandatory parameter settings:

- (1) The max value of the frequency should have such a value that the frequency does not exceed 10.000 Hz and does not exceed the maximum input frequency of the connected electronic calculator/indicating device. Primary data transmission (mass) is via frequency, checking is via Modbus.  
The resulting min value of the frequency should not be below 120 Hz.
- (2) The settings in the flow computer shall match the settings in the flow transmitter.
- (3) The settings shall be such that the maximum pulse frequency of 5000 Hz is not exceeded.
- (4) The value shall be such that the pulses can still be processed by the connected flow computer.
- (5) Value at which the low flow cut off is enabled (pulse output stopped).
- (6) Value at which the low flow cut off is disabled (pulsed started). It is given as a percentage in respect of the On value.  
Actual value = On value x (1 + Off value / 100).  
If the actual flow rate is higher than 20% of the minimum flow rate of the (complete) measuring system, pulses must be generated by the flow transmitter.
- (7) The on value for the vapour return meter (BOG) shall be set the factory default for gas measurements as the expected mass flow of this meter is much lower than the minimum flow rate of the system (applicable to LNG).
- (8) Values shall be explained during conformity assessment.  
Empty pipe detection may be off for horizontal meter installation. In all other cases (vertical or angled installation) the empty pipe detection must be ON.
- (9) At least one of the totalisers must be in accordance with the calibration data.
- (10) If the mass or volume flow offset is not zero, the value shall be explained during the conformity assessment for the impact on the measurement performance. These parameters are not intended for a correction of the zero-flow rate.
- (11) If the mass/volume flow factor is not 1 the actual value shall be explained during the conformity assessment for the impact on the measurement performance.
- (12) If the density offset and density factor are not 0 resp. 1, the actual value shall be explained during the conformity assessment.

## Mandatory parameter setting Promass 300 and 500 flow transmitters in case of LNG bunkering.

These setting override the settings mentioned in Evaluation Certificate TC10822.

<p>Endress+Hauser Flowtec AG        Kipferstrasse 7        CH-4153 Reinach/Switzerland</p> <p><b>Endress+Hauser</b> </p> <p>LNG Bunker Metering System</p> <p>Serial number LNG Line 1:XXXXXXXXXXXXXXXXXXXXXXXXXXXX        Serial number BOG Line 2:XXXXXXXXXXXXXXXXXXXXXXXXXXXX</p> <p>Accuracy class: 1.5        Product: LNG/BOG        Max. flow rate: XXX t/h        Min. flow rate: XXX t/h        Min. measured quantity: 19 bar abs.        Max. pressure: 324006-0000ZAA        P&amp;ID drawing number: -200...-120 °C        Temperature range (LNG): -200...-120 °C        Temperature range (BOG): -25...+55 °C        Temperature range (ambient): M1/E2        Environmental classes:</p> <p> EC type-examination certificate Number T11948   Year of manufacturing:XXXX</p> <p>Meter Line 1: LNG                      Meter Line 2: BOG</p>		<p>1. Engrave characters in 1.8 mm height          2. Material: Aluminium, 1 mm thick             surface finish black matt          3. Rivet 4mm</p>		<p>Rep. Scale 1/1</p> <p>Specification refer to protection notice ISO 16016</p> <p>Copyright Nameplate        refer to protection notice ISO 16016 LNG BUNKER METER SYSTEM</p> <p>Parts Endress+Hauser Flowtec AG        CH-4153 Reinach</p>		<p>Replaced for CAD system AutoCAD</p> <p>Change No. 324005-0000ZAA</p> <p>Changes Appears Controlled</p> <p>SAP-Material-No. 324005-0000ZAA</p> <p>No. of document 324005-0000ZAA</p> <p>Material Replaced for Last editor 30.08.2021 BauerG</p> <p>Welding Controlled 04.12.2020 ZIC</p> <p>Seam 04.12.2020 NT</p> <p>Version Status 00</p> <p>Drawn by 000</p> <p>Formal Page 1/1</p>	
---	--	---	--	--	--	--	--



Customer			
Customer order No.			
Drawn by:	MPT/KAL	Date:	13.05.2020
Checked by:	MPT/KAL	Date:	13.05.2020
Approved by:	MPT/ZC	Date:	13.05.2020
E-H order No.			
Title	LNG Energy Metering System LEMS for LNG bunker delivery		
E-H drawing No.	Z374006-000ZAA		

Rev.	0	Issued for approval	Rev.	0	Issued for approval
Description			Description		
Drawn	Chk'd	App'd	Date		
ALL DIMENSIONS IN MILLIMETERS					
Scale				Sheet	1/1
A3					

**Endress+Hauser**  
 Endress+Hauser Flowtec AG, CH-4133 Rebasch