Technical Information Tankside Monitor NRF81

Tank Gauging



Application

Tankside Monitor NRF81 is a robust gateway for collecting and integrating tank gauging data in storage and process applications. It fulfills the exacting demands of tank inventory management, inventory control, custody transfer, loss control, total cost saving, and safe operation.

Typical areas of application

- Hydrostatic Tank Gauging
- Hybrid Tank Measurement Systems

Your benefits

- SIL2 certified
- SIL2 as per IEC 61508, SIL3 for homogeneous or diverse redundancy
- Up to 6 SIL relay outputs
- Wide range of output signals including V1, Modbus RS 485, and HART protocol
- Integration of e.g. temperature, water level, pressure, overfill prevention sensor
- Robust IP66/68, NEMA Type 4X/6P enclosure, stainless steel or aluminum
- Operation and display in a wide variety of local languages



Table of contents

Document information	3 . 3
Function and system design Integration of tank sensors	5
Input/output	. 6 6 . 7
Power supply	16 17 17 18 18 18 18 18
Installation	19 19
Environment	21 21
DIN EN 60721-3-4 Storage temperature Humidity Degree of protection Shock resistance Vibration resistance Electromagnetic compatibility (EMC) Maximum use altitude	21 21 21 21 21 21 21 21 21
Custody transfer approval	22
Mechanical construction	23 23 23 23
Operability	25 25 25 25 26 27
Certificates and approvals CE mark RCM marking Ex approval Single seal according to ANSI/ISA 12.27.01 Functional Safety (SIL) WHG	 28

Weight & Measure approval	29 29 29 29
Ordering information	30 30 30
Application packages	31 31
Accessories	40
Device-specific accessories	40
Communication-specific accessories	41
Service-specific accessories	41
System components	41
Documentation	42
Technical Information (TI)	42
Brief Operating Instructions (KA)	42
Operating Instructions (BA)	42
Description of Device Parameters (GP)	42
Safety Instructions (XA)	42
Installation instructions (EA)	42
Registered trademarks	42

Document information

Symbols

Safety symbols

A DANGER This symbol alerts you to a dangerous situation. Failure to avoid this situation will result in serious or fatal injury.

WARNING

This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in serious or fatal injury.

A CAUTION

This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in minor or medium injury.

NOTICE

This symbol contains information on procedures and other facts which do not result in personal injury.

Electrical symbols

5

Alternating current

$\overline{\mathbf{x}}$

Direct current and alternating current

Direct current

╧

Ground connection

A grounded terminal which, as far as the operator is concerned, is grounded via a grounding system.

Protective earth (PE)

Ground terminals that must be connected to ground prior to establishing any other connections.

- The ground terminals are located on the interior and exterior of the device:
- Interior ground terminal: protective earth is connected to the mains supply.
- Exterior ground terminal: device is connected to the plant grounding system.

Tool symbols

06

Phillips head screwdriver

00 Flat blade screwdriver

06 Torx screwdriver

0

Allen key

Ŕ

Open-ended wrench

Symbols for certain types of information and graphics

Permitted

Procedures, processes or actions that are permitted

V Preferred

Procedures, processes or actions that are preferred

Forbidden

Procedures, processes or actions that are forbidden

🚹 Tip

Indicates additional information

Reference to documentation

Reference to graphic

►

Notice or individual step to be observed

1., 2., 3. Series of steps

Result of a step

۲ Visual inspection

Operation via operating tool

Write-protected parameter

1, 2, 3, ... Item numbers

A, B, C, ... Views

 $\underline{\Lambda} \rightarrow \underline{\square}$ Safety instructions

Observe the safety instructions contained in the associated Operating Instructions

Specifies the minimum value of the temperature resistance of the connection cables

Function and system design

Integration of tank sensors

The Tankside Monitor is a field device for the integration of tank sensors into tank inventory systems. It is typically installed at the bottom of the tank and allows access to all connected tank sensors. All measured and calculated values can be displayed at the on-site display. Via a field communication protocol, they can be transferred to an inventory control system.



- Integration of tank sensors with Tankside Monitor (Example)
- A HART multidrop mode
- B HART and analog mode
- 1 Pressure transmitter
- 2 Level radar
- 3 Average temperature transmitter
- 4 Tankside Monitor
- 5 Field protocol transmits data to an inventory control system
- 6 Inventory control system (e.g. Tankvision NXA820 or Tankvision Professional NXA85)

Typical values measured by the sensors are:

- Level
- Spot temperature
- Average temperature
- Water level
- Pressure
- Secondary level value (for critical applications)

Input/output

HART Ex ia/IS active input



☑ 2 HART Ex ia/IS active input

- E1 HART +
- E2 HART -

The device has a HART Ex ia/IS active input. Additional features are provided if the following Endress+Hauser devices are connected:

Prothermo NMT

The measured level is transmitted to the Prothermo. Prothermo uses this level to calculate the average temperature of the product.

Micropilot S FMR53x

The calculated distance correction factor or distance correction value is sent to the Micropilot. Micropilot uses this value to indicate the corrected level at its local display.

Technical data

- Transmitter power supply voltage 23.0 V 380 $\Omega \cdot I_{load}$
- Maximum load
- $500\,\Omega$ including signal line
- Maximum current of all connected devices 24 mA

The HART Ex ia/IS active input is available by default. It needs not to be chosen explicitly when ordering a device.

I/O modules





Position of the I/O modules in the terminal compartment

The terminal compartment contains up to four I/O modules, depending on the order code.

- Modules with four terminals can be in any of these slots.
- Modules with eight terminals can be in slot B or C.

The exact assignment of the modules to the slots is dependent on the device version. For a detailed description refer to the Operating Instructions of the device in question.

- The following restrictions apply when selecting the modules:
 - The device may contain a maximum of four I/O modules.
 - A maximum of two I/O modules with 8 terminals is possible.

Ordering feature 040: "Primary Output"

NRF81 - xxxx XX xx xx 040			
0 ¹⁾	N ²⁾	T ³⁾	S ⁴⁾
Modbus RS485 ⁵⁾			
A1	1	4	→ 🗎 10
V1 ⁵⁾	·	·	
B1	1	4	→ 🗎 11
4-20mA HART Ex d/2	XP ⁵⁾		
E1	1	8	→ 🗎 13
4-20mA HART Ex i/IS ⁵⁾			
H1	1	8	→ 🗎 13
WM550 ⁵⁾			
C1	1	4	→ 🗎 12

1) Option

- 2) Number of I/O modules
- 3) Number of terminals
- 4) Technical data
- 5) Type of I/O module

Ordering feature 050: "Secondary I/O Analogue"

NRF81 - xxxx xx XX xx ... 050

Ordering feature 050: "Secondary I/O Analogue"

- Type of I/O module:
 - 1 x "Ex d/XP 4-20mA HART + RTD input"
 - Option A1
 - Number of I/O modules
 - 1
 - Number of terminals 1 x 8
 - Technical data \rightarrow 🗎 13
- Type of I/O module:
 - 2 x "Ex d/XP 4-20mA HART + RTD input"
 - Option
 - A2 • Number of I/O modules
 - 2
 - Number of terminals 2 x 8
 - Technical data $\rightarrow \square 13$
- Type of I/O module:
 - 1 x "Ex i/IS 4-20mA HART+ RTD input"
 - Option
 - B1
 - Number of I/O modules
 - 1Number of terminals
 - 1 x 8
 - Technical data \rightarrow 🗎 13
- Type of I/O module:
 - 2 x "Ex i/IS 4-20mA HART+ RTD input"
 - Option B2
 - Number of I/O modules
 - 2Number of terminals 2 x 8
 - Technical data $\rightarrow \square 13$
- Type of I/O module:
 - 1 x "Ex i/IS 4-20mA HART + RTD input"
 - 1 x "Ex d/XP 4-20mA HART + RTD input"
 - Option
 C2
 - Number of I/O modules
 2.
 - Number of terminals
 - 2 x 8
- Technical data \rightarrow 🗎 13
- Type of I/O module:

none

- Option
- XO
- Number of I/O modules
- 0
- Number of terminals
- 0 • Technical data -

Ordering feature 060: "Secondary I/O Digital Ex d/XP"

NRF81 - xxxx xx xx XX ... 060

Ordering feature 060: "Secondary I/O Digital Ex d/XP"

- Type of I/O module:
 - 1 x "2x relay + 2x discrete I/O"
 - Option
 - A1
 - Number of I/O modules
 - 1Number of terminals 1 x 4
 - Technical data $\rightarrow \square 15$
- Type of I/O module:
- 2 x "2x relay + 2x discrete I/O"
- Option
- A2
- Number of I/O modules 2
- Number of terminals 2 x 4
- Technical data $\rightarrow \square 15$
- Type of I/O module:
 - 3 x "2x relay + 2x discrete I/O"
 - Option
 - A3
 - Number of I/O modules
 - 3
 - Number of terminals 3 x 4
 - Technical data \rightarrow 🗎 15
- Type of I/O module:
 - 1x "Modbus RS485" • Option
 - B1
 - Number of I/O modules
 - 1Number of terminals 3 x 4
 - Technical data $\rightarrow \square 10$
- Type of I/O module:
- 1x "Modbus RS485"
- 1 x "2x relay + 2x discrete I/O"
- Option
- B2
- Number of I/O modules 2.
- Number of terminals
 - 2 x 4
- Technical data
 →
 ⇒ 10
 - → 🗎 15
- Type of I/O module: 1x "Modbus RS485"
 - $2 \times "2x \text{ relay} + 2x \text{ discrete I/O"}$
- Option
- B3
- Number of I/O modules
- 3
- Number of terminals
- 3 x 4 • Technical data
- $\rightarrow \blacksquare 10$
- → 🗎 15

- Type of I/O module:
 - 1 x "WM550"
 - Option E1
 - Number of I/O modules
 1
 - Number of terminals 1 x 4
 - Technical data \rightarrow 🗎 12
- Type of I/O module:
- 1 x "WM550"
- 1 x "2x relay + 2x discrete I/O"
- Option
 E2
- Number of I/O modules
 2
- Number of terminals 2 x 4
- Technical data \rightarrow 🗎 12
- Type of I/O module:
- 1 x "WM550"
- 2 x "2x relay + 2x discrete I/O"
- Option
 E3
- Number of I/O modules
 3
- Number of terminals 3 x 4
- Technical data $\rightarrow \square$ 12
- Type of I/O module:
 - none
 - Option X0
 - Number of I/O modules
 0
 - Number of terminals
 0
 - Technical data -

"Modbus RS485": Technical data

Number of units Maximum 15 instruments per loop

- Baud rate: Selectable
- 600 bit/s
- 1200 bit/s
- 2 400 bit/s
- 4800 bit/s
- 9600 bit/s
- 19200 bit/s

Parity: Selectable

- Odd
- Even
- None

Cable 3-wire, with screening

The screening must be connected inside the housing

Termination resistors To be set as required in specific environments Topology Serial bus

Transmission distance Maximum 1200 m (3900 ft)

Instrument address Each transmitter has an individual bus address configured in the software of the transmitter

Isolation

Bus inputs are electrically isolated from the other electronics

Error on alarm Error message classified according to NAMUR NE 107

"V1": Technical data

Number of units Maximum 10 instruments per loop

Baud rate: Selectable 3 300 bit/s

Cable

• 2-wire twisted pair, screening recommended

2-wire, unscreened

Termination resistors Not required

Topology

Serial bus

Tree structure

Transmission distance Maximum 6000 m (19700 ft)

Instrument address

Each transmitter has an individual bus address configured in the software of the transmitter

Isolation

Serial communication circuit isolated from other circuits

Error on alarm

Error message classified according to NAMUR NE 107

WM550: Technical data

Number of units Maximum 15 $^{1)}$ instruments per loop

Baud rate: Selectable

- 600 bit/s
- 1200 bit/s
- 2 400 bit/s
- 4800 bit/s

Cable

- 2-wire twisted pair, unscreened (recommended)
- 2-wire, screened or unscreened

Topology

Current loop or 2 redundant current loops (requires 2 I/O modules WM550)

Transmission distance Maximum 7 000 m (22 967 ft)

Instrument address Each transmitter has an individual bus address configured in the software of the transmitter Isolation

Serial communication circuit isolated from other circuits

Error on alarm Error message classified according to NAMUR NE 107

¹⁾ The maximum number of devices depends on the maximum output voltage of the master and the voltage drop of slaves. For NXA820 with Nxx8x devices, a maximum number of 12 devices is guaranteed

"4-20mA HART" I/O module (Ex d/XP or Ex i/IS): Technical data

General data

Number of units Maximum 6 instruments per loop

Baud rate: Selectable

1200 bit/s

Cable

- 2-wire twisted pair, screened
- Core cross section: 0.2 to 2.5 mm² (24 to 13 AWG)
- Topology
- Serial bus
- Tree structure

Transmission distance Maximum 1200 m (3900 ft)

Instrument address

Each transmitter on a signal loop has an individual bus address. This is defined within the transmitter software and / or auxiliary configuration environment such as host system or Field Communicator 475.

Isolation

Bus inputs are electrically isolated from the other electronics

Input data

Input operating modes

- 4..20mA input (1 external device)
- HART master+4..20mA input (1 external device)
- HART master (up to 6 external devices)

Internal load (to ground) $400 \ \Omega$

100 02

Measuring range 0 to 26 mA

Accuracy

 $\pm 15 \,\mu A$ (after linearization and calibration)

Connection of a Prothermo NMT

The measured level is transmitted to the Prothermo. Prothermo uses this level to calculate the average temperature of the product.

Connection of a Micropilot S FMR5xx

- The auxiliary energy for the Micropilot S can be supplied by the analogue I/O module
- The calculated distance correction factor or distance correction value is sent to the Micropilot. Micropilot uses this value to indicate the corrected level at its local display.

Connection of a RTD temperature probe

2-, 3- or 4-wire connection

Output data

Output operating modes

- 4..20mA output
- HART slave +4..20mA output

Output current

3 to 24 mA

Accuracy

 $\pm 15 \ \mu A$ (after linearization and calibration)

Error on alarm

HART error message classified according to NAMUR NE 107

Data for passive usage (input or output)

- Minimum terminal voltage 10.4 V²⁾
- Maximum terminal voltage 29 V²⁾

²⁾ Observing these values is mandatory in order to ensure correct measured value information.



• Passive input or output: Use terminals 1 and 2

Data for active usage (input or output)

- Transmitter power supply voltage (Ex d/XP)
- 18.5 V 360 Ω · I_{load}
 Transmitter power supply voltage (Ex i/IS)
- 20.0 V 360 $\Omega \cdot I_{load}$ • Output load
 - max. 500 Ω including signal line ³⁾



■ 5 Active input or output: Use terminals 2 and 3

³⁾ Observing this value is mandatory in order to ensure correct measured value information.

"Digital I/O module": Technical data

Output

- Relay switching power for resistive load
 - 30 V_{DC} @ 2 Å
 - 250 V_{DC} @ 0.1 A
 - 250 V_{AC} @ 2 A
- Relay type
 - normally open;
 - can be set to "normally closed" by a software option⁴⁾

Input

- Maximum pick-up voltage
 - 250 V_{AC}
 - 250 V_{DC}
- Minimum pick-up voltage
 - 25 V_{AC}
 - 5 V_{DC}
- Current consumption at maximum voltage
 - $\leq 1 \text{ mA (DC)}$
 - $\leq 2 \text{ mA}$ (AC)

⁴⁾ In case of a power supply failure, the switching state is always "open", irrespective of the selected software option.

Power supply

Terminal assignment



6 Terminal compartment (typical example) and ground terminals

Housing thread

The threads of the electronics and connection compartment can be coated with an anti-friction coating.

The following applies for all housing materials:

Do not lubricate the housing threads.

Terminal area A/B/C/D (slots for I/O modules)

Module: Up to four I/O modules, depending on the order code

- Modules with four terminals can be in any of these slots.
- Modules with eight terminals can be in slot B or C.

The exact assignment of the modules to the slots is dependent on the device version. For a detailed description refer to the Operating Instructions of the device in question.

Terminal area E

Module: HART Ex i/IS interface

- E1:H+
- E2:H-

Terminal area F

Remote display

- F1: V_{CC} (connect to terminal 81 of the remote display)
- F2: Signal B (connect to terminal 84 of the remote display)
- F3: Signal A (connect to terminal 83 of the remote display)
- F4: Gnd (connect to terminal 82 of the remote display)

Terminal area G (for High voltage AC power supply and Low voltage AC power supply)

- G1:N
- G2: not connected
- G3:L

Terminal area G (for Low voltage DC power supply)

- G1:L-
- G2: not connected
- G3:L+

Terminal area: Protective ground

Module: Protective ground connection (M4 screw)

7 Terminal area: Protective ground

Remote display and operating module DKX001



Cable entries	Ordering feature 090 "Electrical Connection" 1)	Cable entries (with blind plugs) ²⁾		
	A	7 x thread M20		
	В	7 x thread M25		
	С	7 x thread G1/2		
	D	7 x thread G3/4		
	Е	7 x thread NPT1/2		
	F	7 x thread NPT3/4		
	 Position 090 of the order code, e.g. NMx8x-xxxxxxxxA The entries NOT having I/O modules inside will be directly assembled with 316L blind plugs without adapters. For details of module positions, refer to the chapter for "Slots for I/O modules" in Operating Instructions. For the following devices with JPN Ex approval, cable glands are attached to the device (see position 010 of the order code). These cable glands must be used 			
	Tankside Monitor NRF81-TA			
Cable specification	Terminals			
	 Wire cross section 0.2 to 2.5 mm² (24 to 13 AWG) Use for terminals with function: Signal and power supply Spring terminals (NRF81-xx1) Screw terminals (NRF81-xx2) 			
	Wire cross section max. 2.5 mm ² (13 AWG) Use for terminals with function: Ground terminal in the te	rminal compartment		
	busing			
	Power supply line			
	Standard device cable is sufficient for the power line.			
	HART communication line			
	 Standard device cable is sufficient if only the analog signal is used. Shielded cable is recommended if using the HART protocol. Observe the grounding concept of the plant. 			
	Modbus communication line			
	 Observe the cable conditions from the TIA-485-A, Telecommunications Industry Association. Additional conditions: Use shielded cable. 			
	V1 communication line			
	 2-wire twisted pair, screened or unscreened cable Resistance in one cable: ≤ 120 Ω Capacitance between lines: ≤ 0.3 μF 			
	WM550 communication line			
	 2-wire twisted pair, unscreened cable Cross section minimum 0.5 mm² (20 AWG) Maximum total cable resistance: ≤ 250 Ω Cable with low capacitance 			
Overvoltage protection	On the communication and power lines; according to IEC 6	50060-1 /DIN 60079-14:		
	10 kA, 8/20 $\mu\text{s},$ 10 pulses according to IEC 60060-1 / DIN	60079-14		
Overvoltage category	Overvoltage category II			
Pollution degree	Pollution degree 2			

Installation



Wall mounting



Wall mounting of the Tankside Monitor

Pipe mounting

A mounting kit consisting of two brackets and four nuts can be ordered with the device. It can be used for mounting the Tankside Monitor on horizontal or vertical pipes.

Ordering feature 620 "Accessory enclosed"

- PV
 - Mounting kit, pipe, DN32-50 (1-1/4" 2")
- PW Mounting kit, pipe, DN80 (3")



IO Mounting of the Tankside Monitor at a vertical pipe



I1 Mounting of the Tankside Monitor at a horizontal pipe

Environment

Ambient temperature range	Device	-40 to +60 °C (-40 to +140 °F)
	Display module	-20 to +70 °C (-4 to +158 °F)
		The readability of the display may be impaired at temperatures outside this temperature range.
Classification of environmental conditions according to DIN EN 60721-3-4	4K5, 4K6, 4B1,	4M7, 4Z2, 4Z3, 4Z8
Storage temperature	–50 to +80 °C (-	-58 to +176 °F)
Humidity	≤ 95 %	
Degree of protection	IP66/68 accorType 6P/4X accor	rding to DIN EN 60529 ccording to NEMA 250
Shock resistance	 30 g (18 ms) Classification	according to DIN EN 60068-2-27 (1993) according to DIN EN 60721-3-4: 4M7
Vibration resistance	 20 to 2000 Hz, 1 (m/s²)²/Hz according to DIN EN 60068-2-64 (1994) This corresponds to an acceleration value of 4.5 g and fulfills class 4M7 of DIN EN 60721-3-4 (1995) 	
Electromagnetic compatibility (EMC)	 Transient emi Interference r recommendat 	issions according to DIN EN 61326, class B esistance according to DIN EN 61326, Appendix A (Industry use) and NAMUR ion NE21
Maximum use altitude	2000 m (6561.	68 ft) above sea level

Custody transfer approval

Options of ordering feature 590 "Additional Approval"

- LK
- NMi witnessed initial verification accuracy, Weight + Measure approval • LL
- PTB witnessed initial verification accuracy, Weight + Measure approval **LN**
- LNE witnessed initial verification accuracy, Weight + Measure approval **LO**
- *NMi type approval
- LP
 - *PTB type approval
- LQ
- *LNE type approval

 LT
- METAS, custody transfer
- LU
 - BEV, custody transfer

Mechanical construction



🖸 12 Dimensions of Tankside Monitor NRF81; unit of measurement: mm(in); adapters for cable entries are not taken into account in this drawing.

Weight

Materials

Housing with electronics: approx. 12 kg (26 lb)

Materials of housing



- Housing
- 1 2 Cover
- 3 Cover lock
- 4 Tag for measuring point label
- 5 Pressure release stopper
- 6 Nameplate
- 7 Mounting plate
- 8 Dummy screws for weather protection cover
- 9 Dummy plug, cable gland or adapter. Depending on device version
- 10 Ground terminal

- 1 Housing
- Aluminum housing type, RAL 5012 (blue):
 - Housing: AC 43000 T6; AlSi10Mg (<0,1 % Cu)
 - Coating: Polyester
- Stainless steel housing type: 316L (1.4404)
- 2 Cover
- Aluminum RAL 7035 (grey): AC 43000 T6; AlSi10Mg (<0,1 % Cu)
- Stainless steel 316L (1.4404)
- Window: Glass
- Seal: FVMQ
- Thread-coating: Graphite-based lubricant varnish
- 3 Cover lock
- Capstan screw: 316L (1.4404)
- Clamp: 316L (1.4435)

4 Tag for measuring point label

- 316L (1.4404)
- 5 Pressure release stopper
- 316L (1.4404)
- 6 Nameplate
- Aluminum housing type: Sticker: Plastic
- Stainless steel housing type:
- Nameplate: 316L (1.4404)
- Groove pins: 316Ti (1.4571)
- Sealing screw: A4
- O-ring: FKM
- 7 Mounting plate
- Aluminum housing type: AC 43000 T6
- Stainless steel housing type: 316L (1.4404)

8 Dummy screws for weather protection cover

- Screw: A4-70
- O-ring: EPDM

9 Dummy plug, cable gland or adapter ⁵⁾

- Dummy plug
- 1.4435
- LD-PE
- Adapter:
- Ms/Ni (TIIS)
- 1.4404 (other versions)
- Seal:
- EPDM
- NBR
- PTFE tape

10 Ground terminal

- Screw: A4-70
- Spring washer: A4
- Clamp and holder: 316L (1.4404)

⁵⁾ Depending on device version

Operating concept	Operator-oriented menu structure for user-specific tasks Commissioning Operation Diagnostics Expert level 			
	Operating languages • English • Chinese • German • Japanese • Spanish			
	Feature 500 of the product structure determines which of these languages is preset on delivery.			
	 Quick and safe commissioning Guided menus ("Make-it-run" wizards) for applications Menu guidance with brief explanations of the individual parameter functions Reliable operation Standardized operation at the device and in the operating tools 			
				 Efficient diagnostics increase measurement reliability Remedy information is integrated in plain text Diverse simulation options
	Operating options	 Local display; operation via the local display is possible without opening the device. Tank Gauging system Plant Asset Management tool (e.g. FieldCare); connected via HART Service port (CDI) 		
Local operation				

Operability



E 13 Local operation of the Tankside Monitor NRF81

Display and operating module 1

Display elements

- 4-line display
- White background lighting; switches to red in event of device errors

1

- Format for displaying measured variables and status variables can be individually configured
- Permitted ambient temperature for the display: -20 to +70 °C (-4 to +158 °F)

The readability of the display may be impaired at temperatures outside the temperature range. **Operating elements**

- External operation via touch control; 3 optical keys: , , , , ,
- Operating elements also accessible in various hazardous areas

Remote display and operating module DKX001

The display and operating elements correspond to those of the display module.

Depending on the installation location, the remote display module DKX001 provides better access to the operating elements than the display on the device.

A0025574



I4 Operation via remote display and operating module DKX001

The remote display and operating module DKX001 is available as an accessory. For details refer to SD01763D.

- The measured value is indicated on the DKX001 and on the local display and operating module simultaneously.
- The operating menu cannot be accessed on both modules at the same time. If the operating menu is entered in one of these modules, the other module is automatically locked. This locking remains active until the menu is closed in the first module (back to measured value display).

The housing material of the display and operating module DKX001 can be selected in the order code. There are 2 options : alu and stainless steel.





■ 15 Remote operation of Tank Gauging devices

- 1 Proservo NMS8x
- 2 Tankside Monitor NRF81
- 3 Micropilot NMR8x
- 4 Field protocol (e.g. Modbus, V1)
- 5 Tankvision Tank Scanner NXA820
- 6 Ethernet

-

7 Computer with operating tool (e.g. FieldCare)

Operation via service interface



 16 Operation via service interface

- Service interface (CDI = Endress+Hauser Common Data Interface) 1
- 2 3 Commubox FXA291
- Computer with "FieldCare" operating tool and "CDI Communication FXA291" COM DTM

	Certificates and approvals
	Current certificates and approvals for the product are available at www.endress.com on the relevant product page:
	1. Select the product using the filters and search field.
	2. Open the product page.
	3. Select Downloads .
CE mark	The measuring system meets the legal requirements of the applicable EU guidelines. These are listed in the corresponding EU Declaration of Conformity together with the standards applied.
	Endress+Hauser confirms successful testing of the device by affixing to it the CE mark.
RCM marking	The supplied product or measuring system meets the ACMA (Australian Communications and Media Authority) requirements for network integrity, interoperability, performance characteristics as well as health and safety regulations. Here, especially the regulatory arrangements for electromagnetic compatibility are met. The products bear the RCM marking on the nameplate.
Ex approval	Certificates are available online for the following approval types.
	■ AEx ■ ATEX
	• FM C/US
	EAC Ex Ex
	• IEC EX • JPN Ex
	• KC Ex ⁶⁾
	Currently available certificates and approvals can be called up via the product configurator.
	Additional safety instructions must be followed for use in hazardous areas. Please refer to the separate "Safety Instructions" (XA) document included in the delivery. Reference to the applicable XA can be found on the nameplate.
Single seal according to ANSI/ISA 12.27.01	The devices have been designed according to ANSI/ISA 12.27.01 as single seal devices, allowing the user to waive the use and save the cost of installing external secondary process seals in the conduit as required by the process sealing sections of ANSI/NFPA 70 (NEC) and CSA 22.1 (CEC) These instruments comply with the North-American installation practice and provide a very safe and cost-saving installation for pressurized applications with hazardous fluids.
	Further information can be found in the Safety Instructions (XA) of the relevant devices.
Functional Safety (SIL)	Use for level monitoring (MIN, MAX, range) up to SIL 2/3 according to IEC 61508:2010.
	For details refer to the "Functional Safety Manual": SD01929G (NRF81)
WHG	DIBt: Z-65.16-588

⁶⁾ KC approval is covered with IEC Ex approval.

Weight & Measure approval	 OIML R85 (2008) NMi PTB PAC WELMEC The device has a sealable locking switch according to the Weight & Measure requirements. This switch locks all software parameters related to the measurement. The switching status is indicated on the display and via the communication protocol. According to guideline 2004/40/EG-ICNIRP Guidelines EN50371 		
Non-ionizing radiation protection			
Test, certificate	Ordering feature 580 "Test, Certificate"	Designation	
	JA	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate	
	KE	Pressure test, internal procedure, inspection certificate	
	KS	Welding documentation, wetted/pressurized seams	
guidelines	Internate entruste, wetter incluite parts, ENTODE 9.1.1 certificate KE Pressure test, internal procedure, inspection certificate KS Undustry standards Directive 2011/65/EU: "Restriction of Hazardous Substances" (RoHS) Directive 2014/32/EC: "Measuring Instruments Directive" (MID) IEC61508: "functional Safety of Electrical/Electronic/Programmable Electronic Safety Systems" (SIL) NACE MR 0175, NACE MR 0103: "Sulfide stress cracking resistant metallic materials equipment" API Recommended Practice 2350: "Overfill Protection for Storage Tanks in Petroleum API MPMS: "Manual of Petroleum Measurement Standards" EN 1127: "Explosive atmospheres - Explosion prevention and protection" IEC 60079: "Equipment protection" EN 1092: "Flanges and their joints" EN 1127: "Explosive atmospheres - Explosion prevention and protection" IEC 61511: "Functional safety - Safety instrumented systems for the process industry storage tanks by automatic methods" IEC4528: "Refrigerated hydrocarbon liquids - Static measurement - Calculation proceed ISO4266: "Petroleum and liquid petroleum products - Direct static measurement - M of contents of vertical cylindrical tanks by Hybrid Tank Measurement - M of contents of vertical cylindrical tanks by Hybrid Tank Measurement - M of contents of vertical cylindrical tanks by Hybrid Tank Measurement - M of contents of vertical storage tanks by hydrostatic tank gauging"		

Ordering information	Detailed ordering information is available from your nearest sales organization www.addresses.endress.com or in the Product Configurator at www.endress.com:			
	1. Select the product using the fi	lters and search field.		
	2. Open the product page.			
	3. Select Configuration .			
	 Product Configurator - the to Up-to-the-minute configura Depending on the device: Dimeasuring range or operatin Automatic verification of example of the or Automatic creation of the or Ability to order directly in the 	ol for individual product configuration tion data rect input of measuring point-specific information such as ng language clusion criteria rder code and its breakdown in PDF or Excel output format he Endress+Hauser Online Shop		
Marking	Option of ordering feature 895 "Marking"	Meaning		
	Z1	Tagging (TAG)		

Optionally, the device can be ordered with a specific tagging and/or bus address according to the table above. When the respective option is selected, the tag or bus address must be defined in an additional specification.

Ordering information

Application packages

Advanced tank measurement	The device software provides the following tank measurement methods:
methods	• Direct level measurement $\rightarrow \square 31$
	• Hybrid tank measurement system (HTMS) $\rightarrow \square$ 32
	• Hydrostatic tank gauging (HTG) $\rightarrow \square 33$
	• Hydrostatic tank shell correction (HyTD) $\rightarrow \cong 35$
	• Thermal tank shell correction (CTSh) $\rightarrow \square$ 35

Direct level measurement

If no advanced tank measurement methods have been selected, level and temperature are measured directly.

Direct level measurement modes

Measuring mode	Installation example	Measured variables	Calculated variables
Level only	A0023756 1 Level transmitter (e.g. typically FMR540, FMR51, but not NMR8x or NMS8x) 2 Tankside Monitor	Level	None
	3 To inventory management system		
Level + temperature		 Level Temperature (spot or average) 	None
	A0023757		
	 Level transmitter (e.g. typically FMR540, FMR51, but not NMR8x or NMS8x) Tankside Monitor To inventory management system Temperature (spot or average) 		

Hybrid tank measurement system (HTMS)

HTMS uses level and pressure measurements to calculate the contents of the tank and (optionally) the density of the medium.

HTMS measuring modes

Measuring mode	Installation example	Measured variables	Calculated variables
HTMS + P1 This mode should be used in atmospheric (i.e. non- pressurized) tanks	1 1	 Level Bottom pressure (at position D1) 	Density of the medium
HTMS + P1 + P3 This mode should be used in non- atmospheric (i.e. pressurized) tanks	A0023759 1 Level transmitter (e.g. typically FMR540, FMR51, but not NMR8x or NMS8x) 2 Tankside Monitor 3 To inventory management system 4 Pressure transmitter (bottom) 5 Pressure transmitter (top)	 Level Bottom pressure (at position <i>D1</i>) Top pressure (at position <i>D3</i>) 	Density of the medium

Hydrostatic tank gauging (HTG)

HTG uses one, two or three pressure measurements at different positions to calculate the tank contents and (optionally) the density of the medium.

HTG measuring modes



Measuring mode	Installation example	Measured variables	Calculated variables
HTG P1 + P2 This mode should be used in atmospheric (i.e. non-pressurized) tanks	A0023762 1 Tankside Monitor 2 To inventory management system 3 Pressure transmitter (middle) 4 Pressure transmitter (bottom)	 Bottom pressure (at position <i>D1</i>) Middle pressure (at position <i>D2</i>) 	 Level Density of the medium
HTG P1 + P2 + P3	1 Tankside Monitor 2 To inventory management system 3 Pressure transmitter (middle) 4 Pressure transmitter (bottom) 5 Pressure transmitter (top)	 Bottom pressure (at position <i>D1</i>) Middle pressure (at position <i>D2</i>) Top pressure (at position <i>D3</i>) 	 Level Density of the medium

Hydrostatic tank shell correction (HyTD)

The hydrostatic tank shell correction can be used to compensate for vertical movement of the Gauge Reference Height due to bulging of the tank shell caused by the hydrostatic pressure exerted by the liquid stored in the tank. The compensation is based on a linear approximation obtained from manual hand dips at several levels distributed over the full range of the tank.



 \blacksquare 17 Movement Δx of the Gauge Reference Height due to the bulging of the tank shell caused by hydrostatic pressure

Thermal tank shell correction (CTSh)

The thermal tank shell correction can be used to compensate for vertical movement of the Gauge Reference Height due to temperature effects on the tank shell or stilling well. The calculation is based on the thermal expansion coefficients of steel and on insulation factors for both the dry and wetted part of the tank shell.

 This correction is recommended for any tank gauge operating at conditions deviating considerably from the conditions during calibration and for extremely high tanks. For refrigerated, cryogenic and heated applications this correction is highly recommended.

• Wire length can also be corrected with the parameters related to CTSh.

Level reference check (LRC)

For tanks where a manual dipping cannot be performed the level gauge can be verified by means of the LRC function.

If the measured level value is not verified by the LRC function applied, the device will issue an error message regarding the measured level.



This reference check is recommended for liquefied gas applications.

LRC with reference level

The radar device compares it's own level reading with the level reading of another level gauge (e.g. Proservo NMS8x). Based on a configurable deviation value (**Allowed difference** parameter), a continuous check is performed.



Application example with Proservo NMS8x

- *1* Lower limit of deviation value "a" as configured in radar level gauge
- 2 Reference value: Measured level as provided by level gauge Proservo NMS8x
- 3 Upper limit of deviation
- 4 Proservo NMS8x provides the reference value
- 5 Level gauges are interconnected via HART interface
- 6 Radar level gauge with configured deviation value "a" for "Allowed difference" parameter
- 7 The measured level is greater than reference value plus deviation value "a": Level value is not verified
- 8 The measured level is within or equal to the limits defined by the deviation value "a": Level value is verified
- 9 The measured level is less than reference value minus deviation value "a": Level value is not verified

Properties

- Frequency: The reference check is performed continuously every 60 seconds.
- Tolerance: Via the **Check fail threshold** parameter, a configurable number of failures is allowed before the status switches to failed.
- Connection: The level reference device is connected via an optional HART I/O board. See ordering feature 050: "Secondary I/O Analogue".

LRC with point reference

Mechanical parts in the tank can be used as reference points to perform a reference measurement. The reference distance can be saved to the device. Based on a configurable deviation value (**Allowed difference** parameter), a manual check can be started.

A closed cut off ball valve or a fixed reference ring at the end of a stilling well are examples for suitable reference measurement installations.



■ 19 Application example with fixed reference point at the end of the stilling well

- 1 Lower limit of deviation value "a" as configured in radar level gauge
- 2 Reference value: Distance from radar level gauge to object fixed to stilling well
- 3 Upper limit of deviation
- 4 Radar level gauge with configured deviation value "a" for "Allowed difference" parameter
- 5 The measured level is greater than reference value plus deviation value "a": Level value is not verified
- 6 The measured level is within or equal to the limits defined by the deviation value "a": Level value is verified
- 7 The measured level is less than reference value minus deviation value "a": Level value is not verified

LRC with reference switch

A level switch (e.g. Liquiphant FTLx) can be mounted within the tank. The check can be performed continuously, each time the level switch is activated or deactivated. The measured level should remain within a configurable deviation.



20 Application example with level switch

- 1 Lower limit of deviation value "a" as configured in radar level gauge
- 2 Reference value: The switching point of an installed level switch represents the reference value for verification
- 3 Upper limit of deviation
- 4 Level switch and level gauge are interconnected via a digital I/O board
- 5 Radar level gauge with configured deviation value "a" for "Allowed difference" parameter
- 6 The measured level is greater than reference value plus deviation value "a": Level value is not verified
- 7 The measured level is within or equal to the limits defined by the deviation value "a": Level value is verified
- 8 The measured level is less than reference value minus deviation value "a": Level value is not verified

Properties

- Modes: The device can be set to monitor the switching point while filling or draining the tank.
- Connection: The level switch is connected via a digital I/O board. See ordering feature 060: "Secondary I/O Digital Ex d/XP".

Gas phase correction for liquefied gases (CLG)

The gas phase in pressurized tanks has a direct impact on the distance determination for time-offlight sensors. This feature corrects the influences of the vapor phase based on its pressure, temperature and composition.



- *1 Prothermo temperature measurement device, equipped with thermowell or protective pipe*
- 2 HART connection
- 3 Radar level gauge Micropilot NMR84
- 4 HART connection
- 5 Digital pressure transmitter

The vapor pressure and temperature measurement devices need to be connected via an optional HART I/O board.

Vapor phase composition

The vapor phase composition is entered manually via the display or an asset management software (e.g. DeviceCare).

The correction function can be set to the following values:

- Off
- Pure gas option: 1 main gas component
- Mix of two gases option: 2 main components with defined share
- Mix of three gases option: 3 main components with defined share
- **Mix of four gases** option: 4 main components with defined share

The share is entered in percent (i. e. mixture of 2 gases with 25 and 75 percent) or in amounts (i. e. mixture of 2 gases with 1 amount and 3 amounts), no unit required.

The gas components can either be selected from a predefined list or defined by the user to use a different gas component. In that case the refractive index for the component has to be entered.



Accessories

🖸 21 Weather protection cover; dimensions: mm (in)

Materials

- Protection cover and mounting brackets Material
- 316L (1.4404)
- Screws and washers Material
 - A4
 - The weather protection cover can be ordered together with the device:
- H Ordering feature 620 "Accessory Enclosed", option PA "Weather Protection Cover") • It can also be ordered as an accessory:
 - Order code: 71292751 (for NMR8x and NRF8x)

Communication-specific accessories	 WirelessHART adapter SWA70 Is used for the wireless connection of field devices The WirelessHART adapter can be easily integrated into field devices and existing infrastructures, offers data protection and transmission safety and can be operated in parallel with other wireless networks For details, see Operating Instructions BA00061S
	 Gauge Emulator, Modbus to BPM Using the protocol converter, it is possible to integrate a field device into a host system even if the field device does not know the communication protocol of the host system. Eliminates vendor lock-in for field devices. Field communication protocol (field device): Modbus RS485 Host communication protocol (host system): Enraf BPM 1 measuring device per Gauge Emulator Separate power supply: 100 to 240 V_{AC}, 50 to 60 Hz, 0.375 A, 15 W Several approvals for the hazardous area
	 Gauge Emulator, Modbus to TRL/2 Using the protocol converter, it is possible to integrate a field device into a host system even if the field device does not know the communication protocol of the host system. Eliminates vendor lock-in for field devices. Field communication protocol (field device): Modbus RS485 Host communication protocol (host system): Saab TRL/2 1 measuring device per Gauge Emulator Separate power supply: 100 to 240 V_{AC}, 50 to 60 Hz, 0.375 A, 15 W Several approvals for the hazardous area
Service-specific accessories	Commubox FXA195 HART For intrinsically safe HART communication with FieldCare via the USB interface
	For details, see "Technical Information" T100404F
	Commubox FXA291 Connects Endress+Hauser field devices with a CDI interface (= Endress+Hauser Common Data Interface) and the USB port of a computer or laptop Order number: 51516983
	For details, see "Technical Information" TI00405C
	DeviceCare SFE100 Configuration tool for HART, PROFIBUS and FOUNDATION Fieldbus field devices DeviceCare is available for download at <u>www.software-products.endress.com</u> . You need to register in the Endress+Hauser software portal to download the application.
	Technical Information TI01134S
	FieldCare SFE500 FDT-based plant asset management tool It can configure all smart field units in your system and helps you manage them. By using the status information, it is also a simple but effective way of checking their status and condition. Technical Information TI00028S
System components	RIA15
-,	Compact process display unit with very low voltage drop for universal use to display 4 to 20 mA/ HART signals
	Technical Information TI01043K
	Tankvision Tank Scanner NXA820 / Tankvision Data Concentrator NXA821 / Tankvision Host Link NXA822 Inventory Management System with completely integrated software for operation via standard web browser
	Technical Information TI00419G

Documentation

The following documentation types are available in the Downloads area of the Endress+Hauser website (www.endress.com/downloads):

- For an overview of the scope of the associated Technical Documentation, refer to the following:
 Device Viewer (www.endress.com/deviceviewer): Enter the serial number from the nameplate
 - *Endress+Hauser Operations app*: Enter serial number from nameplate or scan matrix code on nameplate.

Technical Information (TI)	Planning aid The document contains all the technical data on the device and provides an overview of the accessories and other products that can be ordered for the device.	
Brief Operating Instructions (KA)	Guide that takes you quickly to the 1st measured value The Brief Operating Instructions contain all the essential information from incoming acceptance to initial commissioning.	
Operating Instructions (BA)	The Operating Instructions contain all the information that is required in various phases of the life cycle of the device: from product identification, incoming acceptance and storage, to mounting, connection, operation and commissioning through to troubleshooting, maintenance and disposal.	
	It also contains a detailed explanation of each individual parameter in the operating menu (except the Expert menu). The description is aimed at those who work with the device over the entire life cycle and perform specific configurations.	
Description of Device Parameters (GP)	The Description of Device Parameters provides a detailed explanation of each individual parameter in the 2nd part of the operating menu: the Expert menu. It contains all the device parameters and allows direct access to the parameters by entering a specific code. The description is aimed at those who work with the device over the entire life cycle and perform specific configurations.	
Safety Instructions (XA)	Depending on the approval, the following Safety Instructions (XA) are supplied with the device. They are an integral part of the Operating Instructions.	
	1 The nameplate indicates the Safety Instructions (XA) that are relevant to the device.	
Installation instructions (EA)	Installation Instruction are used to replace a faulty unit with a functioning unit of the same type.	

Registered trademarks

Modbus®

Registered trademark of SCHNEIDER AUTOMATION, INC.



www.addresses.endress.com

