



# شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	24-12-133661/E24-11-136103/NB0007	رقم الشهادة:
Registration Date:	16/12/2024	تاريخ التسجيل:
Valid Until:	15/12/2025	صالحة لغاية:
Issued To:	Endress & Hauser Process Automation UAE Trading LLC P.O. Box 473547 , 17th Floor, Office 1702, Control Tower Building, Dubai Motor City, Dubai , United Arab Emirates	أصدرت إلى :
Sector:	Electrical	كهرباء قطاع:
Product Category:	ECAS-Ex	الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار تصنيف المنتج:
Product Sub-Category:	ECAS-Ex	الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار التصنيف الفرعي للمنتج:

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات

intertek

Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards

المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

600565554

[www.moiat.gov.ae](http://www.moiat.gov.ae)

[@MoIAT](https://www.instagram.com/MoIAT)



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.

This document has been issued electronically and doesn't require a stamp and signature.



## بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

Company Name:	Endress & Hauser Process Automation UAE Trading LLC	اسم الشركة:
Product Category:	ECAS-Ex الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار	تصنيف المنتج:
Certificate No.:	24-12-133661/E24-11-136103/NB0007	رقم التسجيل:
Registration Date:	16/12/2024	تاريخ التسجيل:
Valid Until:	15/12/2025	صالح لغاية:

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/ Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
--------	-----------------------------	-----------------------------------	-------------------------------------	-----------------------------------	-------------------------------------	---------------------	---	---------------------------------------

intertek  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

1	Endress+Hauser	TM111	iTHERM Thermometer TM111; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIIC T <sub>200</sub> 85°C... T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	IECEX EPS 18.0074X DE/EPS/ExTR18.0076/05 DE/TUN/QAR06.0009/12	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	--	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

2	Endress+Hauser	TM112	iTHERM Thermometer TM112; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIIC T <sub>200</sub> 85°C...T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 DE/EPS/ExTR18.0076/05 IECEX EPS 18.0074X	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	---	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

3	Endress+Hauser	TM131	iTHERM Thermometer TM131; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIIC T <sub>200</sub> 85°C...T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 IECEX EPS 18.0074X DE/EPS/ExTR18.0076/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	---	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

4	Endress+Hauser	TM151	iTHERM Thermometer TM151; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIIC T <sub>200</sub> 85°C... T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 DE/EPS/ExTR18.0076/05 IECEX EPS 18.0074X	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	--	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

5	Endress+Hauser	TM152	iTHERM Thermometer TM152; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIIC T <sub>200</sub> 85°C...T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 IECEX EPS 18.0074X DE/EPS/ExTR18.0076/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	---	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

6	Endress+Hauser	TS111	iTHERM Insert TS111; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIC T <sub>200</sub> 85°C...T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 DE/EPS/ExTR18.0076/05 IECEX EPS 18.0074X	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	---	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology







بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

7	Endress+Hauser	TS211	iTHERM Insert TS211; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIIC T <sub>200</sub> 85°C... T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 IECEX EPS 18.0074X DE/EPS/ExTR18.0076/05	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
---	----------------	-------	---	-----	-----	---	---	-------

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل  
**SCHEDULE OF CERTIFICATION**  
Ministry of Industry and Advanced Technology

8	Endress+Hauser	TS212	iTHERM Insert TS212; Type of Protection: intrinsic safety "ia"; Marking: Ex ia IIC T6...T1 Ga   Ex ia IIC T6...T1 Ga/Gb   Ex ia IIC T <sub>200</sub> 85°C...T <sub>200</sub> 450°C Da/Db; For details about ambient temperature range, electrical data, thermal data, and type designation see annex of IECEX EPS 18.0074X Issue No: 5	N/A	N/A	DE/TUN/QAR06.0009/12 DE/EPS/ExTR18.0076/05 IECEX EPS 18.0074X	UAE.S IEC 60079-11, UAE.S IEC 60079-26, UAE.S IEC 60079-0	ITALY
Nothing Follows								

**intertek**  
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة  
Notified body by Ministry of Industry and Advanced Technology

