Safety Instructions Micropilot FMR50/51/52/53/54/56/57

PROFIBUS PA, FOUNDATION Fieldbus

Ex ia IIC T6 Ga/Gb Ex ia IIIC T85°C Da/Db







Micropilot FMR50/51/52/53/54/56/57

PROFIBUS PA, FOUNDATION Fieldbus

Table of contents

Associated documentation	4
Supplementary documentation	4
Certificates and declarations	4
Manufacturer address	5
Other standards	5
Extended order code	5
Safety instructions: General	11
Safety instructions: Specific conditions of use	11
Safety instructions: Installation	13
Safety instructions: Zone 0	16
Temperature tables	16
Connection data	18

Associated documentation

All documentation is available on the Internet:

www.endress.com/Deviceviewer

(enter the serial number from the nameplate).



If not yet available, a translation into EU languages can be ordered.

To commission the device, please observe the Operating Instructions pertaining to the device:

PROFIBUS PA

- BA01124F (FMR50)
- BA01125F (FMR51, FMR52)
- BA01126F (FMR53, FMR54)
- BA01127F (FMR56, FMR57)

FOUNDATION Fieldbus

- BA01120F (FMR50)
- BA01121F (FMR51, FMR52)
- BA01122F (FMR53, FMR54)
- BA01123F (FMR56, FMR57)

Supplementary documentation

Explosion protection brochure: CP00021Z

The explosion protection brochure is available on the Internet:

www.endress.com/Downloads

Certificates and declarations

EU Declaration of Conformity

Declaration Number:

EU 00954

The EU Declaration of Conformity is available on the Internet: www.endress.com/Downloads

EU type-examination certificate

Certificate number:

PTB 12 ATEX 2018 X

List of applied standards: See EU Declaration of Conformity.

IEC Declaration of Conformity

Certificate number:

IECEx PTB 12.0044 X

Affixing the certificate number certifies conformity with the following standards (depending on the device version):

IEC 60079-0:2017IEC 60079-11:2011IEC 60079-26:2021

Manufacturer address

Endress+Hauser SE+Co. KG Hauptstraße 1 79689 Maulburg, Germany

Address of the manufacturing plant: See nameplate.

Other standards

Among other things, the following standards shall be observed in their current version for proper installation:

- IEC/EN 60079-14: "Explosive atmospheres Part 14: Electrical installations design, selection and erection"
- EN 1127-1: "Explosive atmospheres Explosion prevention and protection - Part 1: Basic concepts and methodology"

Extended order code

The extended order code is indicated on the nameplate, which is affixed to the device in such a way that it is clearly visible. Additional information about the nameplate is provided in the associated Operating Instructions.

Structure of the extended order code

FMR5x	-	*****	+	A*B*C*D*E*F*G*
(Device		(Basic		(Optional
type)		specifications)		specifications)

* = Placeholder

At this position, an option (number or letter) selected from the specification is displayed instead of the placeholders.

Basic specifications

The features that are absolutely essential for the device (mandatory features) are specified in the basic specifications. The number of positions depends on the number of features available. The selected option of a feature can consist of several positions.

Optional specifications

The optional specifications describe additional features for the device (optional features). The number of positions depends on the number of features available. The features have a 2-digit structure to aid identification (e.g. JA). The first digit (ID) stands for the feature group

and consists of a number or a letter (e.g. J = Test, Certificate). The second digit constitutes the value that stands for the feature within the group (e.g. A = 3.1 material (wetted parts), inspection certificate).

More detailed information about the device is provided in the following tables. These tables describe the individual positions and IDs in the extended order code which are relevant to hazardous locations.

Extended order code: Micropilot



The following specifications reproduce an extract from the product structure and are used to assign:

- This documentation to the device (using the extended order code on the nameplate).
- The device options cited in the document.

Device type

FMR50, FMR51, FMR52, FMR53, FMR54, FMR56, FMR57

Basic specifications

Position 1, 2 (Approval)			
Selected option		Description	
FMR5x	B2	ATEX II 1/2 G Ex ia IIC T6T1 Ga/Gb ATEX II 1/2 D Ex ia IIIC T85°C Da/Db	
	I2	IECEx Ex ia IIC T6T1 Ga/Gb IECEx Ex ia IIIC T85°C Da/Db	

Position 3 (Power Supply, Output)		
Selected option		Description
FMR5x	Е	2-wire, FOUNDATION Fieldbus, switch output (PFS)
	G	2-wire, PROFIBUS PA, switch output (PFS)

Position 4 (Display, Operation)			
Selected option		Description	
FMR5x	Α	Without, via communication	
	С	SD02, 4-line, push buttons + data backup function	
	Е	SD03, 4-line, illum., touch control + data backup function	
	M 1)	Prepared for display FHX50 + custom connection	
	N 1)	Prepared for display FHX50 + NPT1/2"	

1) FHX50 is approved according to DEK12.0046X or DEKRA 12ATEX0151X.

Position 5 (Housing)		
Selected option	n	Description
FMR51-54 B FMR57	3	GT18 dual compartment, 316L
FMR5x C	:	GT20 dual compartment, Alu coated

Position 6 (Electrical Connection)			
Selected option		Description	
FMR5x	Α	Gland M20, IP66/68 NEMA4X/6P	
	В	Thread M20, IP66/68 NEMA4X/6P	
	С	Thread G1/2, IP66/68 NEMA4X/6P	
	D	Thread NPT1/2, IP66/68 NEMA4X/6P	

Position 7, 8 (Antenna)		
Selected option		Description
FMR50	BN	Horn 80 mm/3", PP cladded, -4080°C
	BR	Horn 100 mm/4", PP cladded, -4080°C
FMR51	Bx	Horn (different sizes)
FMR52	ВО	Horn 50 mm/2", -196200°C, flush mount
	BP	Horn 80 mm/3", -196200°C, flush mount
FMR53	Cx	Rod (different sizes)

Position 7, 8 (Antenna)			
Selected opt	ion	Description	
FMR54	Ax	Without Horn	
	Bx	Horn (different sizes)	
	Dx	Planar (different sizes)	
FMR56	BN	Horn 80 mm/3", PP cladded, -4080°C	
	BR	Horn 100 mm/4", PP cladded, -4080°C	
FMR57	Вх	Horn (different sizes)	
	Fx	Parabolic (different sizes)	
Fx Parabolic (different sizes) Shown in the temperature tables exemplary as follows:			

Position 9, 10 (Seal)		
Selected opt	ion	Description
FMR51	A5	Viton GLT, -40150°C
	C1	Kalrez, -20150℃
	D2	Graphite, -196450°C (HT)
	D3	Graphite, -40250°C (XT)
FMR54	A7	Viton, -20150°C (Planar)
	A8	Viton, -40200°C
	B4	EPDM, -40150°C
	C2	Kalrez, -20200°C, conductive media max. 150°C
	D1	Graphite, -196280°C (XT)
	D2	Graphite, -196400°C (HT)

Position 9,	Position 9, 10 (Seal)			
Selected option		Description		
FMR57	A6	Viton GLT, -40200°C		
	D4	Graphite, -40400°C (HT)		
T	vn in the te	emperature tables ollows:		

Position 11-	Position 11-13 (Process Connection)							
Selected opt	ion	Description						
FMR51-54 FMR57	Axx Cxx Kxx	Flange (different sizes)						
FMR50	UAE	Mounting bracket						
	XR0	Connection, without flange/mounting bracket						
	XxG	Slip on flange (different sizes)						
FMR51	Pxx	Flange (different sizes)						
	Rxx	Thread						
	Txx	Tri-Clamp						
FMR52	Mxx	Slotted-nut						
Txx		Tri-Clamp						
FMR53 RxJ Thread, 316L		Thread, 316L						
	RxF	Thread, PVDF						

Position 11	Position 11-13 (Process Connection)						
Selected op	tion	Description					
FMR56	UAE	Mounting bracket					
	XR0	Connection, without flange/mounting bracket					
	XxG	Slip on flange (different sizes)					
FMR57	RxJ	Thread, 316L					
	XxJ	Align. device (different sizes)					
	n in the te plary as fo	mperature tables llows:					

Position 14 (Air Purge Connection)					
Selected option		Description			
FMR57	1	G1/4			
	2	NPT1/4			

Optional specifications

ID Nx, Ox (A	ID Nx, Ox (Accessory Mounted)							
Selected op	tion	Description						
FMR5x	NA	Overvoltage protection						
FMR51	MO UO VO	Antenna extension (different sizes)						
	OW	Horn protection, PTFE, no airpurge possible						
FMR54	OM ON OR OS	Antenna extension (different sizes)						
FMR57	OP OT	Antenna extension (different sizes)						
	OW	Horn protection, PTFE, no airpurge possible						

Safety instructions: General

- The device is intended to be used in explosive atmospheres as defined in the scope of IEC 60079-0 or equivalent national standards. If no potentially explosive atmospheres are present or if additional protective measures have been taken: The device may be operated according to the manufacturer's specifications.
- Staff must meet the following conditions for mounting, electrical installation, commissioning and maintenance of the device:
 - Be suitably qualified for their role and the tasks they perform
 - Be trained in explosion protection
 - Be familiar with national regulations
- Install the device according to the manufacturer's instructions and national regulations.
- Do not operate the device outside the specified electrical, thermal and mechanical parameters.
- Only use the device in media to which the wetted materials have sufficient durability.
- Avoid electrostatic charging:
 - Of plastic surfaces (e.g. enclosure, sensor element, special varnishing, attached additional plates, ...)
 - Of isolated capacities (e.g. isolated metallic plates)
- Alterations to the device can affect the explosion protection and must be carried out by staff authorized to perform such work by Endress+Hauser.
- Refer to the temperature tables for the relationship between the permitted ambient temperature for the sensor and/or transmitter, depending on the range of application and the temperature class.
- When using in hybrid mixtures (gas and dust occurring simultaneously), observe additional measures for explosion protection.

Safety instructions: Specific conditions of use Permitted ambient temperature range at the electronics enclosure: –40 °C \leq T_a \leq +80 °C

- Observe the information in the temperature tables.
- In the case of process connections made of polymeric material or with polymeric coatings, avoid electrostatic charging of the plastic surfaces.
- To avoid electrostatic charging: Do not rub surfaces with a dry cloth.
- In the event of additional or alternative special varnishing on the enclosure or other metal parts or for adhesive plates:
 - Observe the danger of electrostatic charging and discharge.
 - Do not install in the vicinity of processes (≤ 0.5 m) generating strong electrostatic charges.
- The probe must not be subjected to abrasive or corrosive medium that may adversely affect the partition for the zone separation.
- The zone partition wall of the device is a gas- and dust-tight feed through made of stainless-steel adapter and glass conductor bushing.

Sensor	Zone partition wall material	Wall thickness	Diameter
FMR50-52	Stainless-steel adapter	6 mm	10 mm
FMR56 FMR57	Glass conductor bushing	2.6 mm	2.4 mm
	Welding seam	> 0.2 mm	-
FMR53	Stainless-steel adapter	14 mm	25 mm
FMR54	Glass conductor bushing	4.8 mm	6.3 mm
	Welding seam	> 0.2 mm	-

Device type FMR50, FMR52, FMR53, FMR54 (planar, enamel), FMR56 An antenna coated with non-conductive material can be used if avoiding electrostatic charging (e.g. through friction, cleaning, maintenance, strong medium flow).

Device type FMR51, FMR57 and Optional specification, ID Nx, Ox = OW An antenna coated with non-conductive material can be used if avoiding electrostatic charging (e.g. through friction, cleaning, maintenance, strong medium flow).

Device type FMR57 and Basic specification, Position 11-13 = XxI

- Changing the position of the alignment device must be impossible:
 - After the alignment of the antenna via the pivot bracket
 - After tightening of the clamping flange
 - After setting the damping ring (torque 15 Nm)
- Degree of protection IP67 must be fulfilled.


Device type FMR57 and Basic specification, Position 14 = 1, 2

- If equipment with Ga/Gb or Da/Db is required: In the closed state the minimum degree of protection of the installation must be IP67.
- After removing the air purge connection: Lock the opening with a suitable pluq.
 - Torque: 6-7 Nm
 - For Da/Db: thread engagement > 5 turns
- Degree of protection IP67 must be fulfilled.

Device type FMR51, FMR54, FMR57 and Optional specification, ID Nx, Ox = OM, ON, OR, OS, OU, OV, OP, OT

Avoid contact between sensor and tank wall. Take into account tank fittings and flow conditions (avoid sparks caused by impact and friction).

Safety instructions: Installation



A0025536

- A Zone 1, Zone 21
- 1 Tank; Zone 0, Zone 1 or Zone 20, Zone 21
- 2 Electronic insert
- 3 Enclosure
- 4 Certified associated apparatus
- 5 Potential equalization line
- 6 Potential equalization
- After aligning (rotating) the enclosure, retighten the fixing screw (see Operating Instructions).
- Install the device to exclude any mechanical damage or friction during the application. Pay particular attention to flow conditions and tank fittings.
- Only use certified cable entries or sealing plugs. The metal sealing plugs supplied meet this requirement.
- Before operation:
 - Screw in the cover all the way.
 - Tighten the securing clamp on the cover.
- After mounting and connecting the antenna, ingress protection of the enclosure must be at least IP65.
- Perform the following to achieve the degree of protection:
 - Screw the cover tight.
 - Mount the cable entry correctly.
- Continuous service temperature of the connecting cable:
 -40 °C to ≥ +85 °C; in accordance with the range of service temperature taking into account additional influences of the process conditions (T_{a,min}), (T_{a,max} +20 K).

Basic specification, Position 4 = N


Observe the requirements according to IEC/EN 60079-14 for conduit systems and the wiring and installation instructions of the suitable Safety Instructions (XA). In addition, observe national regulations and standards for conduit systems.

Intrinsic safety

- The device is only suitable for connection to certified, intrinsically safe equipment with explosion protection Ex ia / Ex ib.
- The intrinsically safe input power circuit of the device is isolated from ground. If the device is only equipped with one input, the dielectric strength of the input is at least $500~V_{rms}$. If the device is equipped with more than one input, the dielectric strength of each individual input to ground is at least $500~V_{rms}$, and the dielectric strength of the inputs vis-à-vis one another is also at least $500~V_{rms}$.
- Observe the pertinent guidelines when interconnecting intrinsically safe circuits.
- The device can be connected to the Endress+Hauser FXA291 service tool: refer to the Operating Instructions and specifications in the "Overvoltage protection" chapter.
- When the intrinsically safe Ex ia circuits of the device are connected to certified intrinsically safe circuits of Category Ex ib for Equipment Groups IIC or IIB, the type of protection changes to Ex ib [ia] IIC or Ex ib [ia] IIB. Regardless of the power supply, all the internal circuits correspond to Ex ia IIC type of protection (e.g. service interface, external display, sensor).

Potential equalization

- Integrate the device into the local potential equalization.
- Grounding the screen, see the following figure.



A0022352

- A Version 1: Use small capacitors (e.g. 1 nF, 1500 V dielectric strength, ceramic). Total capacitance connected to the screen may not exceed 10 nF.
- B Version 2
- 1 Terminating resistor
- 2 Distributor/T box
- 3 Screen insulated
- 4 Supply unit/Segment coupler
- 5 Potential equalization (secured in high degree)
- 6 Field device

Overvoltage protection

- If an overvoltage protection against atmospheric over voltages is required: no other circuits may leave the enclosure during normal operation without additional measures.
- For installations which require overvoltage protection to comply with national regulations or standards, install the device using overvoltage protection (e.g. HAW56x from Endress+Hauser).
- Observe the safety instructions of the overvoltage protection.

Optional specification, ID Nx, Ox = NA (Overvoltage protection Type OVP20)

The intrinsically safe input power circuit of the device is isolated from ground. If the device is only equipped with one input, the dielectric strength of the input is at least 290 $V_{\rm rms}.$ If the device is equipped with

more than one input, the dielectric strength of each individual input to ground is at least 290 $V_{\rm rms}$, and the dielectric strength of the inputs vis-à-vis one another is also at least 290 $V_{\rm rms}$.

Safety instructions: Zone 0

- Associated devices with galvanic isolation between the intrinsically safe and non-intrinsically safe circuits are preferred.
- If there is a risk of dangerous potential differences within Zone 0 (e.g. through the occurrence of atmospheric electricity), implement suitable measures for intrinsically safe circuits in Zone 0.

Temperature tables

- → Safety Instructions: XA02413F
- The safety instructions for temperature tables are available on the Internet; www.endress.com/Downloads
- Optional specification, ID Nx, Ox = NA
 (Overvoltage protection Type OVP20)
 When using the internal overvoltage protection: Reduce the admissible ambient temperature at the enclosure by 5 K.
- Observe the permitted temperature range at the antenna.

Explanation of how to use the temperature tables

Unless otherwise indicated, the positions always refer to the basic specification.

Zone 0, Zone 1 or Zone 1

1st column: Position 5 = A, B, ...

2nd column: Position 3 = A, B, ...

(1): 1 channel used(2): 2 channels used

3rd column: Temperature classes T6 (85 °C) to T1 (450 °C)

Column P1 to P6: Position (temperature value) on the axes of the derating $% \left(1\right) =\left(1\right) \left(1\right)$

- lacktriangledown T_a : Ambient temperature in ${}^{\circ}\text{C}$
- T_p: Process temperature in °C
- Column P6 is only relevant for version B of the derating.

Example table

	(1)		P1		P2		P3		P4		P5		P6	
= C			T _p	Ta	T _p	Ta	Tp	Ta	Tp	Ta	T _p	Ta	T _p	Ta
	E, G	T6	-40	60	60	60	85	54	85	-40	-40	-40	-	-
		T5	-40	75	75	75	100	69	100	-40	-40	-40	-	-
		T4	-40	80	80	80	135	68	135	-40	-40	-40	-	-

Zone 20, Zone 21

1st column: Position 5 = A, B, ...

2nd column: Position 3 = A, B, ...

• (1): 1 channel used


• (2): 2 channels used

3rd column: Process temperature

Column P1 to P6: Position (temperature value) on the axes of the derating $\$

■ T_a: Ambient temperature in °C


■ T_p: Process temperature in °C



Example table

	(1)		P1		P2		Р3		P4		P5		P6	
=(T _p	Ta	T _p	Ta	T _p	Ta						
	E, G	135	-40	80	80	80	135	67	135	-40	-40	-40	-	-
		200	-40	80	80	80	200	51	200	-40	-40	-40	-	-

Example diagrams of possible deratings



Connection data

Cable entry: Connection compartment

Ex ia IIC

Not relevant.

Ex ia IIIC

Cable gland: Basic specification, Position 6 = A

Basic specification, Position 5 = B, C

preferably for Position 5 = B

Thread	Clamping range	Material	Sealing insert	O-ring
M20x1,5	ø 7 to 12 mm	1.4404	NBR	EPDM (ø 17x2)

preferably for Position 5 = C

Thread	Clamping range	Material	Sealing insert	O-ring
M20x1,5	ø 8 to 10.5 mm	Ms, nickel-plated	Silicone	EPDM (ø 17x2)



- The tightening torque refers to cable glands installed by the manufacturer:
 - Recommended: 3.5 Nm
 - Maximum: 10 Nm
- This value may be different depending on the type of cable.
 However, the maximum value must not be exceeded.
- Only suitable for fixed installation. The operator must pay attention to a suitable strain relief of the cable.
- The cable glands are suitable for a low risk of mechanical danger (4 Joule) and must be mounted in a protected position if larger impact energy levels are expected.
- To maintain the ingress protection of the enclosure: Install the enclosure cover, cable glands and blind plugs correctly.

Cable entry: Electronics compartment

Cable gland: Basic specification, Position 4 = M

Basic specification, Position 5 = B, C

preferably for Position 5 = B

Thread	Clamping range	Material	Sealing insert	O-ring
M16x1,5	ø 5 to 10 mm	1.4404	PA/NBR	NBR (ø 13x2)

preferably for Position 5 = C

Thread	Clamping range	Material	Sealing insert	O-ring
M16x1,5	ø 5 to 10 mm	Ms, nickel-plated	PA/NBR	NBR (ø 13x2)



- The tightening torque refers to cable glands installed by the manufacturer:
 - Recommended: 3.5 Nm
 - Maximum: 5 Nm
 - This value may be different depending on the type of cable.
 However, the maximum value must not be exceeded.

- Only suitable for fixed installation. The operator must pay attention to a suitable strain relief of the cable.
- The cable glands are suitable for a low risk of mechanical danger (4 Joule) and must be mounted in a protected position if larger impact energy levels are expected.
- To maintain the ingress protection of the enclosure: Install the enclosure cover, cable glands and blind plugs correctly.

Terminals

Optional specification, ID Nx, Ox = NA (Overvoltage protection Type OVP20)

When using the internal overvoltage protection: No changes to the connection values.

Ex ia

Power supply and signal circuit with protection type: intrinsic safety Ex ia IIC. Ex ia IIB. Ex ia IIIC.

Terminal 1 (+), 2 (-)		Terminal 3 (+), 4 (-)				
FISCO	Entity	Switch output (PFS)				
$U_i = 17.5 \text{ V}$ $I_i = 550 \text{ mA}$ $P_i = 5.5 \text{ W}$	$U_i = 30 \text{ V}$ $I_i = 300 \text{ mA}$ $P_i = 1.2 \text{ W}$	$\begin{split} &U_{i}=30~V\\ &I_{i}=300~mA\\ &P_{i}=1~W \end{split}$				
effective inner inducta effective inner capacit		$ \begin{array}{c} \mbox{effective inner inductance} \ L_i = 0 \\ \mbox{effective inner capacitance} \ C_i = 6 \ nF \end{array} $				

Service interface (CDI)

Taking the following values into consideration, the device can be connected to the certified Endress+Hauser FXA291 service tool or a similar interface:

Service interface $U_i = 7.3 \text{ V}$ effective inner inductance L_i = negligible effective inner capacitance C_i = negligible $U_0 = 7.3 \text{ V}$ $I_0 = 100 \text{ mA}$ $P_0 = 160 \text{ mW}$ 0.15 5.00 2.00 1.00 0.50 0.20 0.10 0.05 0.02 0.01 0.005 0.002 0.001 L_0 (mH) = $C_0 (\mu F)^{1} =$ 0.73 1.20 1.60 2.00 2.60 3.20 4.00 5.50 7.30 10.00 12.70 12.70 $C_o (\mu F)^{(2)} =$ 0.49 0.90 1.40 2.00

- 1) Values according to PTB "ispark" program
- 2) Values according to IEC/EN 60079-25, Annex C or equivalent national standards







www.addresses.endress.com