
Brief Operating Instructions Micropilot FMR20 HART

Free space radar





These Instructions are Brief Operating Instructions; they are not a substitute for the Operating Instructions pertaining to the device.

For detailed information, refer to the Operating Instructions and other documentation.

Available for all device versions via:

- Internet: www.endress.com/deviceviewer
- Smart phone/Tablet: Endress+Hauser Operations App






Table of contents

1 1.1 1.2 1.3 1.4	About this document Symbols used Documentation Supplementary documentation Registered trademarks	4 . 5 5
2 2.1 2.2 2.3 2.4 2.5	Basic safety instructions Requirements for personnel Designated use Workplace safety Operational safety Product safety	5 6 7
3 3.1	Product description Product design	
4.1 4.2 4.3 4.4	Incoming acceptance and product identification Goods acceptance Product identification Manufacturer address Nameplate	8 9 . 9
5 5.1 5.2	Installation Installation conditions Post-installation check	12
6.1 6.2 6.3 6.4 6.5	Electrical connection Cable assignment Supply voltage Connecting the device Connection with RIA15 Post-connection check	22 22 23 24
7 7.1 7.2 7.3	Operability	24 25
8 8.1 8.2	System integration via HART protocol Overview of the device description files Measured variables via HART protocol	26
9.1 9.2 9.3	Commissioning and operation Commissioning via SmartBlue (App) Configuring level measurement via operating software Flow measurement configuration	26 29
10 10.1 10.2 10.3	Error - SmartBlue operation	30 31

1 About this document

1.1 Symbols used

1.1.1 Safety symbols

⚠ DANGER

This symbol alerts you to a dangerous situation. Failure to avoid this situation will result in serious or fatal injury.

WARNING

This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in serious or fatal injury.

A CAUTION

This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in minor or medium injury.

NOTICE

This symbol contains information on procedures and other facts which do not result in personal injury.

1.1.2 Symbols for certain types of information and graphics

▼ Permitted

Procedures, processes or actions that are permitted

K Forbidden

Procedures, processes or actions that are forbidden

🚹 Tip

Indicates additional information



Reference to graphic



Notice or individual step to be observed

1., 2., 3.

Series of steps



Result of a step

1, 2, 3, ...

Item numbers

A, B, C, ...

Views

1.2 Documentation

The following documentation types are available in the Downloads section of the Endress +Hauser website (www.endress.com/downloads):



For an overview of the scope of the associated Technical Documentation, refer to the following:

- W@M Device Viewer (www.endress.com/deviceviewer): Enter the serial number from nameplate
- Endress+Hauser Operations App: Enter the serial number from the nameplate or scan the 2D matrix code (QR code) on the nameplate

1.3 Supplementary documentation

BA01578F

Operating Instructions FMR20 HART

TI01043K

Technical Information RIA15

BA01170K

Operating Instructions RIA15

1.4 Registered trademarks

HART®

Registered trademark of the FieldComm Group, Austin, Texas, USA

Apple[®]

Apple, the Apple logo, iPhone, and iPod touch are trademarks of Apple Inc., registered in the U.S. and other countries. App Store is a service mark of Apple Inc.

Android®

Android, Google Play and the Google Play logo are trademarks of Google Inc.

Bluetooth®

The $Bluetooth^{@}$ word mark and logos are registered trademarks owned by the Bluetooth SIG, Inc. and any use of such marks by Endress+Hauser is under license. Other trademarks and trade names are those of their respective owners.

2 Basic safety instructions

2.1 Requirements for personnel

The personnel for installation, commissioning, diagnostics and maintenance must fulfill the following requirements:

- ► Trained, qualified specialists must have a relevant qualification for this specific function and task.
- ▶ Personnel must be authorized by the plant owner/operator.
- ▶ Be familiar with federal/national regulations.

- ▶ Before starting work: personnel must read and understand the instructions in the manual and supplementary documentation as well as the certificates (depending on the application).
- ▶ Personnel must follow instructions and comply with general policies.

The operating personnel must fulfill the following requirements:

- ► Personnel are instructed and authorized according to the requirements of the task by the facility's owner-operator.
- ▶ Personnel follow the instructions in this manual.

2.2 Designated use

Application and media

The measuring device described in these Operating Instructions is intended for continuous, non-contact level measurement in liquids. Because of its operating frequency of approx. 26 GHz, a maximum radiated pulsed power of 5.7 mW and an average power output of 0.015 mW, use outside of closed, metallic vessels is also permitted. If operated outside of closed vessels, the device must be mounted in accordance with the instructions in the "Installation" section. Operation of the devices does not pose a risk to health or the environment.

If the limit values specified in the "Technical data" and the conditions listed in the instructions and additional documentation are observed, the measuring device may be used for the following measurements only:

- ► Measured process variables: distance
- ► Calculated process variables: volume or mass in vessels of any shape; flow through measuring weirs or channels (calculated from the level by the linearization functionality)

To ensure that the measuring device remains in proper condition for the operation time:

- ► Use the measuring device only for media to which the process-wetted materials have an adequate level of resistance.
- ▶ Observe the limit values (see "Technical data").

Incorrect use

The manufacturer is not liable for damage caused by improper or non-designated use.

Verification for borderline cases:

▶ With regard to special media and media used for cleaning, please contact the manufacturer. Endress+Hauser will be happy to assist in clarifying the corrosion-resistant properties of wetted materials but does not accept any warranty or liability.

Residual risks

Due to heat transfer from the process as well as power dissipation within the electronics, the temperature of the electronics housing and the assemblies contained therein may rise to 80 °C (176 °F) during operation. When in operation, the sensor can reach a temperature close to the medium temperature.

Danger of burns from contact with surfaces!

► In the event of elevated fluid temperatures, ensure protection against contact to prevent burns.

2.3 Workplace safety

For work on and with the device:

 Wear the required personal protective equipment according to federal/national regulations.

2.4 Operational safety

Risk of injury!

- ▶ Operate the device only if it is in proper technical condition, free from errors and faults.
- ▶ The operator is responsible for interference-free operation of the device.

Hazardous area

To eliminate the risk of danger to persons or the facility when the device is used in the approval-related area (e.g. explosion protection, pressure equipment safety):

- Check the nameplate to verify if the device ordered can be put to its intended use in the approval-related area.
- Observe the specifications in the separate supplementary documentation that is an integral part of this manual.

2.5 Product safety

This measuring device is designed in accordance with good engineering practice to meet state-of-the-art safety requirements, has been tested, and left the factory in a condition in which it is safe to operate. It meets general safety standards and legal requirements.

2.5.1 CE mark

The measuring system meets the legal requirements of the applicable EU Directives. These are listed in the corresponding EU Declaration of Conformity along with the standards applied.

Endress+Hauser confirms successful testing of the device by affixing to it the CE mark.


2.5.2 EAC conformity

The measuring system meets the legal requirements of the applicable EAC guidelines. These are listed in the corresponding EAC Declaration of Conformity together with the standards applied.

Endress+Hauser confirms successful testing of the device by affixing to it the EAC mark.

3 Product description

3.1 Product design



■ 1 Device design

- A Device with 40 mm antenna
- B Device with 80 mm antenna
- 1 Sensor housing
- 2 Seal
- 3 Process connection rear side
- 4 Cable gland
- 5 Pipe adapter
- 6 O-ring
- 7 Counter nut
- 8 Design ring
- 9 Process connection front side

4 Incoming acceptance and product identification

4.1 Goods acceptance

Check the following during goods acceptance:

- Are the order codes on the delivery note and the product sticker identical?
- Are the goods undamaged?
- Do the nameplate data match the ordering information on the delivery note?
- If required (see nameplate): Are the safety instructions (XA) provided?
- If one of these conditions is not met, please contact the manufacturer's sales office.

4.2 Product identification

The following options are available for the identification of the measuring device:


- Nameplate specifications
- Extended order code with breakdown of the device features on the delivery note
- ► Enter the serial number from the nameplates into *W@M Device Viewer* (www.endress.com/deviceviewer)
 - Lack All the information about the measuring device and the scope of the associated Technical Documentation are displayed.
- ► Enter the serial number from the nameplate into the *Endress+Hauser Operations App* or use the *Endress+Hauser Operations App* to scan the 2-D matrix code (QR Code) provided on the nameplate
 - All the information about the measuring device and the scope of the associated Technical Documentation are displayed.

4.3 Manufacturer address

Endress+Hauser SE+Co. KG Hauptstraße 1 79689 Maulburg, Germany

Address of the manufacturing plant: See nameplate.

4.4 Nameplate




A0029096

■ 2 Nameplate of Micropilot

- 1 Manufacturer address
- 2 Device name
- 3 Order code
- 4 Serial number (ser. no.)
- 5 Extended order code (ext. ord. cd.)
- 6 Supply voltage
- 7 Signal outputs
- 8 Process pressure
- 9 Allowable ambient temperature (T_a)
- 10 Maximum process temperature
- 11 Device ID
- 12 Firmware version (FW)
- 13 Device revision (Dev.Rev.)
- 14 CE mark
- 15 Additional information about the device version (certificates, approvals)
- 16 C-tick
- 17 Materials in contact with process
- 18 Degree of protection: e.g. IP, NEMA
- 19 Certificate symbol
- 20 Certificate and approval relevant data
- 21 Document number of the Safety Instructions: e.g. XA, ZD, ZE

- 22 Modification mark
- 23 2-D matrix code (QR code)
- 24 Manufacturing date: year-month




However, the complete extended order code can also be displayed via the device operating menu: Extended order code 1 to 3 parameter

5 Installation

5.1 Installation conditions

5.1.1 Installation types



A0030605

■ 3 Wall, ceiling or nozzle installation

- A Wall or ceiling mount, adjustable
- B Mounted at front thread
- C Mounted at rear thread
- D Ceiling installation with counter nut (included in delivery)
- *E* Horizontal installation in confined spaces (sewer shaft)
- F Shaft wall mounting


Caution!

- The sensor cables are not designed as supporting cables. Do not use them for suspension purposes.
- Always operate the device in a vertical position in free-space applications.

5.1.2 Nozzle installation

The antenna should be located out of the nozzle for optimum measurement. The interior of the nozzle must be smooth and may not contain any edges or welded joints. The edge of the nozzle should be rounded if possible.

Micropilot FMR20 HART



A0028413

₩ 4 Nozzle installation

80 mm (3 in) antenna

40 mm (1.5 in) antenna

The maximum length of the nozzle L depends on the nozzle diameter D.

Please note the limits for the diameter and length of the nozzle.

80 mm (3 in) antenna, installation inside nozzle

- D: min. 120 mm (4.72 in)
- L: max. 205 mm (8.07 in) + D × 4.5

80 mm (3 in) antenna, installation outside nozzle

- D: min. 80 mm (3 in)
- L: max. D × 4.5


40 mm (1.5 in) antenna, installation outside nozzle

- D: min. 40 mm (1.5 in)
- L: max. D × 1.5

40 mm (1.5 in) antenna, installation inside nozzle

- D: min. 80 mm (3 in)
- L: max. 140 mm (5.5 in) + D × 1.5

5.1.3 Position for installation on a vessel



A0028410

■ 5 Installation position on a vessel

- If possible install the sensor so that its lower edge projects into the vessel.
- Recommended distance **A** wall nozzle outer edge: $\sim \frac{1}{6}$ of the vessel diameter **D**. Under no circumstances should the device be mounted closer than 15 cm (5.91 in) to the vessel wall.
- Do not install the sensor in the middle of the vessel.
- Avoid measurements through the filling curtain.
- Avoid equipment such as limit switches, temperature sensors, baffles, heating coils etc.
- No signals are evaluated within the Blocking distance (BD). It can therefore be used to suppress interference signals (e.g. the effects of condensate) in the vicinity of the antenna. An automatic Blocking distance of at least 0.1 m (0.33 ft) is configured as standard. However, this can be overwritten manually (0 m (0 ft) is also permitted). Automatic calculation:

Blocking distance = Empty calibration - Full calibration - 0.2 m (0.656 ft). Each time a new entry is made in the **Empty calibration** parameter or **Full calibration**


parameter, the **Blocking distance** parameter is recalculated automatically using this formula.

If the result of the calculation is a value < 0.1 m (0.33 ft), the Blocking distance of 0.1 m (0.33 ft) will continue to be used.

5.1.4 Device alignment for installation on a vessel

- Align the antenna vertically to the product surface.
- Align the eyelet with lug towards the vessel wall as well as possible.


Micropilot FMR20 HART



A0028927

Device alignment for installation on a vessel

5.1.5 Beam angle



A0033201

 \blacksquare 7 Relationship between beam angle a, distance D and beamwidth diameter W

The beam angle is defined as the angle α , at which the power density of the radar waves reaches half the value of the maximum power density (3 dB width). Microwaves are also emitted outside the signal beam and can be reflected off interfering installations.

Beam diameter W as a function of beam angle α and distance D.

40 mm (1.5 in) antenna, α 30 °

 $W = D \times 0.54$


40 mm (1.5 in) antenna with flooding protection tube, α 12 $^{\circ}$

 $W = D \times 0.21$

80 mm (3 in) antenna with or without flooding protection tube, α 12 $^{\circ}$

 $W = D \times 0.21$

5.1.6 Measurement in plastic vessels



A0029540

 \blacksquare 8 Measurement in a plastic vessel with a metallic, interfering installation outside of the vessel

- 1 Pipe, tubing
- 2 Ladder
- 3 Grate, railing

If the outer wall of the vessel is made of a non-conductive material (e.g. GFR), microwaves can also be reflected by interfering installations outside of the vessel.


Please ensure there are no interfering installations made of a conductive material in the signal beam (see the beam angle section for information on calculating the beamwidth diameter).

Please contact the manufacturer for further information.

5.1.7 Protective hood

For outdoor use, a protective hood is recommended.

The protective hood can be ordered as an accessory or together with the device via the product structure "Accessory enclosed".



Δ0031277

■ 9 *Protective hood, e.g. with 40 mm (1.5") antenna*




The sensor is not completely covered by the protective hood.

5.1.8 Using the flooding protection tube

The flooding protection tube ensures the sensor measures the maximum level even if it is completely flooded.

In free-field installations and/or in applications where there is a risk of flooding, the flooding protection tube must be used.

The flooding protection tube can be ordered as an accessory or together with the device via the product structure "Accessory enclosed".



A0031093

■ 10 Function of flooding protection tube

- 1 Air pocket
- 2 O-ring (EPDM) seal
- 3 Blocking distance
- 4 Max. level

The tube is screwed directly onto the sensor and seals off the system by means of an O-ring making it air-tight. In the event of flooding, the air pocket that formed in the tube ensures the measurement of the maximum level at the end of the tube. Due to the fact that the Blocking distance is inside the tube, multiple echoes are not analyzed.

Configuration parameters for flooding protection tube

Configuring the blocking distance when using the flooding protection tube

- $\blacktriangleright\:\:$ Navigate to: Main menu \to Setup \to Advanced setup \to Blocking distance
 - ► Enter 100 mm (4 in).


Perform a mapping after the flooding protection tube has been installed and the blocking distance has been configured

- 1. Navigate to: Setup → Confirm distance
 - └─ Compare the distance displayed with the actual value in order to start the recording of an interference echo map.

- 2. Navigate to: Setup → Mapping end point
 - This parameter determines the distance up to which the new mapping is to be recorded.
- 3. Navigate to: Setup → Present mapping
 - □ Displays the distance up to which a mapping has already been recorded.

5.1.9 Installation with mounting bracket, adjustable

The mounting bracket can be ordered as an accessory or together with the device via the product structure "Accessory enclosed".



A0030606

■ 11 Installation with mounting bracket, adjustable

- Wall or ceiling installation is possible.
- Using the mounting bracket, position the antenna so that it is perpendicular to the product surface.

NOTICE


There is no conductive connection between the mounting bracket and transmitter housing.

Electrostatic charging possible.

► Integrate the mounting bracket in the local potential equalization system.

5.1.10 Cantilever installation, with pivot

The cantilever, wall bracket and mounting frame are available as accessories.




■ 12 Cantilever installation, with pivot

- A Cantilever with wall bracket
- *B* Cantilever with mounting frame
- *C* Cantilever can be turned (e.g., in order to position the device over the center of the flume)

5.1.11 Installation of horizontal mounting bracket for sewer shafts

The horizontal mounting bracket for sewer shafts is available as an accessory.




A003774

■ 13 Installation of horizontal mounting bracket for sewer shafts

5.1.12 Mounting in a shaft

The pivoted mounting bracket is available as an accessory.

Micropilot FMR20 HART Installation



A0037748

■ 14 Mounting in a shaft, pivotable and adjustable

- A Arm with wall bracket
- *B* Pivotable and adjustable arm (e.g. to align the device with the center of a channel)


5.2 Post-installation check

- ☐ Is the device or cable undamaged (visual inspection)?
- \square Is the device adequately protected from wet conditions and direct sunlight?
- \square Is the device properly secured?

Micropilot FMR20 HART

6 Electrical connection

6.1 Cable assignment



A0028954


■ 15 Cable assignment

- 1 Plus, brown wire
- 2 Minus, blue wire

6.2 Supply voltage

10.5 to $30 V_{DC}$

An external power supply is necessary.



 \blacksquare 16 Maximum load R, depending on supply voltage U_0 of power supply unit

Battery operation

The sensor's *Bluetooth*® wireless technology communication can be disabled to increase the operating life of the battery.

Potential equalization


No special measures for potential equalization are required.

Various power supply units can be ordered as an accessory from Endress+Hauser.

6.3 Connecting the device

6.3.1 4 to 20 mA HART block diagram

Connection of the device with HART communication, power source and 4 to 20 mA display



■ 17 Block diagram of HART connection

- 1 Device with HART communication
- 2 HART resistor
- 3 Power supply
- The HART communication resistor of 250 Ω in the signal line is always necessary in the case of a low-impedance power supply.

The voltage drop to be taken into account is:

Max. 6 V for 250 Q communication resistor

6.4 Connection with RIA15

FMR20 connection options with RIA15 (can be ordered together with the device) are described in Operating Instructions BA01578F.

6.5 Post-connection check

\square Is the device or cable undamaged (v.	

- ☐ Do the mounted cables have adequate strain relief?
- ☐ Are the cable glands mounted and firmly tightened?
- ☐ Does the supply voltage match the specifications on the nameplate?
- ☐ No reverse polarity, is terminal assignment correct?
- \square Has the voltage drop across the process indicator and communication resistor been taken into account?


7 Operability

7.1 Operating concept

- 4 to 20 mA, HART
- Menu guidance with brief explanations of the individual parameter functions in the operating tool
- \blacksquare Optional: SmartBlue (app) via ${\it Bluetooth} ^{\circledR}$ wireless technology

Micropilot FMR20 HART Operability

7.2 Operation via Bluetooth® wireless technology




A0028895

■ 18 Possibilities for remote operation via Bluetooth® wireless technology

- 1 Transmitter power supply unit
- 2 Smartphone/tablet with SmartBlue (app)
- 3 Transmitter with Bluetooth® wireless technology

7.3 Via HART protocol



A0028894

■ 19 Options for remote operation via HART protocol

- 1 PLC (programmable logic controller)
- *Transmitter power supply unit, e.g. RN221N (with communication resistor)*
- 3 Connection for Commubox FXA195
- 4 Loop-powered RIA15 process indicator
- 5 Commubox FXA195 (USB)
- 6 Computer with operating tool (FieldCare, DeviceCare)
- 7 Smartphone / tablet with SmartBlue (app)
- 8 Transmitter with Bluetooth® wireless technology

8 System integration via HART protocol

8.1 Overview of the device description files

Manufacturer ID

17 (0x11)

Device type ID

44 (0x112c)

HART specification

7.0

8.2 Measured variables via HART protocol

The following measured values are assigned to the HART variables:

Primary variable (PV)

Level linearized (PV)

Secondary variable (SV)

Distance (SV)

Tertiary variable (TV)

Relative echo amplitude (TV)

Quaternary variable (QV)

Temperature (QV)

9 Commissioning and operation

Perform the post-installation check and the post-connection check prior to commissioning.

9.1 Commissioning via SmartBlue (App)

9.1.1 Device requirements

Commissioning via SmartBlue is only possible if the device has Bluetooth capability (Bluetooth module installed at the factory prior to delivery or retrofitted).

9.1.2 SmartBlue system requirements

SmartBlue system requirements

SmartBlue is available as a download from the Google Play Store for Android devices and from the iTunes Store for iOS devices.

- Devices with iOS:
 - iPhone 4S or higher from iOS 9; iPad 2 or higher from iOS 9; iPod touch 5th generation or higher from iOS 9 $\,$
- Devices with Android:

From Android 4.4 KitKat and Bluetooth® 4.0

A0039186

9.1.3 SmartBlue App

1. Scan the QR code or enter "SmartBlue" in the search field of the App Store.



■ 20 Download link


- 2. Start SmartBlue.
- 3. Select device from livelist displayed.
- 4. Enter the login data:
 - User name: admin Password: serial number of the device
- 5. Tap the icons for more information.
- After logging in for the first time, change the password!

9.1.4 Envelope curve display in SmartBlue

Envelope curves can be displayed and recorded in SmartBlue.

In addition to the envelope curve, the following values are displayed:


- D = Distance
- L = Level
- A = Absolute amplitude
- With screenshots, the displayed section (zoom function) is saved
- With video sequences, the whole area without zoom function is saved all the time



A0020494

■ 21 Envelope curve display (sample) in SmartBlue for Android


- 1 Record video
- 2 Create screenshot
- 3 Display mapping menu
- 4 Start/stop video recording
- Move time on time axis



■ 22 Envelope curve display (sample) in SmartBlue for iOS

- 1 Record video
- 2 Create screenshot
- 3 Display mapping menu
- 4 Start/stop video recording
- 5 Move time on time axis

9.2 Configuring level measurement via operating software



A0028417

■ 23 Configuration parameters for level measurement in liquids

- R Reference point of measurement
- D Distance
- L Level
- *E Empty calibration (= zero point)*
- *F* Full calibration (= span)
- BD Blocking distance

9.2.1 Via SmartBlue

- 1. Navigate to: Setup → Distance unit
 - ► Select unit of length for distance calculation
- 2. Navigate to: Setup → Empty calibration
 - ► Specify empty distance E (distance from reference point R to minimum level)
- 3. Navigate to: Setup \rightarrow Full calibration
 - ► Specify full distance F (span: max. level min. level)
- 4. Navigate to: Setup → Distance
 - Shows the distance D that is currently measured from the reference point (lower edge of flange / last sensor thread) to the level
- 5. Navigate to: Setup → Confirm distance
 - Compare the distance displayed with the actual value in order to start the recording of an interference echo map
- 6. Navigate to: Setup → Mapping end point
 - This parameter determines the distance up to which the new mapping is to be recorded

- 7. Navigate to: Setup → Present mapping
 - └ Displays the distance up to which a mapping has already been recorded
- 8. Setup \rightarrow Confirm distance
- 9. Navigate to: Setup → Level
 - ► Shows the level L measured
- 10. Navigate to: Setup → Signal quality
 - └ Displays the signal quality of the analyzed level echo

9.3 Flow measurement configuration

The procedure for configuring flow measurement is described in the Operating Instructions pertaining to the device.

10 Diagnostics and troubleshooting

10.1 General errors

Error	Possible cause	Solution	
Device does not respond	Supply voltage does not match the specification on the nameplate	Apply correct voltage	
	The polarity of the supply voltage is wrong	Correct the polarity	
	The cables do not contact the terminals properly	Ensure electrical contact between the cable and the terminal	
HART communication does not function	Communication resistor missing or incorrectly installed	Install the communication resistor (250 $\Omega)$ correctly	
	Commubox is connected incorrectly	Connect Commubox correctly	
	The communication resistor of the Commubox is switched on or off	Check the communication resistor and connections For details, see Technical Information T100404F	
Device measures incorrectly	Configuration error	Check and correct the parameter configuration Carry out mapping	
Display values not plausible (linearization)	SmartBlue and FieldCare/DeviceCare active at the same time	Log off FieldCare/DeviceCare and disconnect or Log off SmartBlue and disconnect (connection via SmartBlue has priority)	
Linearized output value not plausible	Linearization error	SmartBlue: Check linearization table FieldCare/DeviceCare: Check linearization table Check the vessel selection in the linearization module	

Error	Possible cause	Solution
RIA15 no display	The polarity of the supply voltage is wrong	Correct the polarity
	The cables do not contact the terminals properly	Ensure electrical contact between the cable and the terminal
	RIA15 defective	Replace RIA15
RIA15 start sequence keeps running through	Supply voltage too low	Increase supply voltageSwitch off backlight

10.2 Error - SmartBlue operation

Error	Possible cause	Solution		
Device is not visible in	No Bluetooth	Enable Bluetooth function on smartphone or tablet		
the live list	connection	Bluetooth function of sensor disabled, perform recovery sequence		
Device is not visible in the live list	The device is already connected with another smartphone/tablet	Only one point-to-point connection is established between a sensor and a smartphone or tablet		
Device is visible in the live list but cannot be	Android end device	Is the location function permitted for the app, was it approved the first time?		
accessed via SmartBlue		GPS or positioning function must be activated for certain Android versions in conjunction with Bluetooth		
		Activate GPS - close the app fully and restart - enable the positioning function for the app		
Device is visible in the live list but cannot be accessed via SmartBlue	Apple end device	Log in as standard Enter user name "admin" Enter initial password (device serial number) paying attention to lower/upper case		
Login via SmartBlue not possible	Device is being put into operation for the first time	Enter initial password (device serial number) and change. Pay attention to lower/upper case when entering the serial number.		
Device cannot be operated via SmartBlue	Incorrect password entered	Enter correct password		
Device cannot be operated via SmartBlue	Password forgotten	Contact the Endress+Hauser Service department		
Device cannot be operated via SmartBlue	The sensor temperature is too high	If the ambient temperature results in an elevated sensor temperature of >60 °C (140 °F), Bluetooth communication may be disabled. Shield the device, isolate it and cool it down if necessary.		
TAG in SmartBlue and HART do not match	System-related	The device ID (TAG) is transferred to the live list via Bluetooth® to facilitate device identification. The tag is abbreviated in the middle since the HART tag can be up to 32 characters long but Bluetooth® can only use 29 characters as the device name: e.g: "FMR20N12345678901234567890123456" becomes "FMR20N12345678~567890123456"		

10.3 Diagnostic event in the operating tool

If a diagnostic event is present in the device, the status signal appears in the top left status area of the operating tool along with the corresponding symbol for the event level in accordance with NAMUR NE 107:

- Failure (F)
- Function check (C)
- Out of specification (S)
- Maintenance required (M)

Calling up remedial measures

- ► Navigate to the **Diagnostics** menu
 - └ In the **Actual diagnostics** parameter the diagnostic event is shown with event text







www.addresses.endress.com