

### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

**IECEX EPS 19.0100X** 

Page 1 of 6

Certificate history:

Status:

Current

Issue No: 1

Issue 0 (2021-07-01)

Date of Issue:

2022-02-11

Applicant:

Endress+Hauser Wetzer GmbH + Co. KG

Obere Wank 1 87484 Nesselwang

Germany

Equipment:

Active Barrier (associated apparatus)

Optional accessory:

RN22 and RN42

Type of Protection:

ia

Marking:

[Ex ia Ga] IIC

[Ex ia Da] IIIC

Approved for issue on behalf of the IECEx Certification Body:

Position:

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Gode.





Certificate issued by:

Bureau Veritas Consumer Products Services Germany GmbH Businesspark A96 86842 Türkheim Germany





Certificate No.:

**IECEX EPS 19.0100X** 

Page 2 of 6

Date of issue:

2022-02-11

Issue No: 1

Manufacturer:

Endress+Hauser Wetzer GmbH + Co. KG

Obere Wank 1 87484 Nesselwang

Germany

Additional manufacturing

locations:

Endress+Hauser Wetzer (Suzhou)

Co. Ltd.

Su-Hong-Zhong-Lu No. 465 215021 Suzhou-SIP (P.R. China)

China

Endress+Hauser Wetzer USA INC.

2413 Endress Place Greenwood, IN 46143

United States of America

Endress+Hauser Wetzer (India) Pvt.

Ltd.

M-171/173, MIDC, Waluj Aurangabad – 431 136

India

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

#### STANDARDS:

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017

Edition:7.0

Explosive atmospheres - Part 0: Equipment - General requirements

IEC 60079-11:2011

Edition:6.0

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

DE/EPS/ExTR19.0104/01

Quality Assessment Report:

DE/TUN/QAR06.0009/09



Certificate No.:

**IECEX EPS 19.0100X** 

Page 3 of 6

Date of issue:

2022-02-11

Issue No: 1

#### **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

The active barrier, type RN22, is used for the transmission and galvanic isolation of 0/4 to 20 mA signals.

The device has an active/passive current input to which an intrinsically 2- or 4-wire transmitter can be directly connected. HART communication signals are transmitted bidirectionally by the device.

A two-channel version of the barrier can optionally be provided.

With a signal doubler option, the active barrier is used for the galvanic isolation of a 0/4 to 20 mA signal, which is transmitted to two galvanically isolated outputs.

The active barrier, type RN42, is used for the transmission and galvanic isolation of 0/4 to 20 mA signals.

The device has an active/passive current input to which an intrinsically 2- or 4-wire transmitter can be directly connected. HART communication signals are transmitted bidirectionally by the device.

Ambient temperature range:

 $-40 \,^{\circ}\text{C} \le \text{T}_{a} \le +60 \,^{\circ}\text{C}$ 

#### SPECIFIC CONDITIONS OF USE: YES as shown below:

If several devices are installed side by side, it is important to ensure that the maximum side wall temperature of the individual device of 80°C (176°F) is not exceeded. If this cannot be guaranteed, the devices have to be mounted at a distance from one another or sufficient cooling must be ensured.



Certificate No.:

**IECEX EPS 19.0100X** 

Page 4 of 6

Date of issue:

2022-02-11

Issue No: 1

#### Equipment (continued):

#### Electrical Data:

#### Supply RN22:

terminal 1.1 (+), 1.2 (-) U = 24 V Dc (-20 % / +25 %)

Um = 250 V

Supply RN42:

terminal 1.1 (L/+), 1.2 (N/-) U = 24 to 230 V DC (-20 % / +10 %) 50/60 Hz

Um = 250 V

#### Output circuit:

terminal 3.1 (+), 3.2 (-)

U = 30 V DC I = 0/4-20 mA

terminal 2.1 (+), 2.2 (-)

Um = 30 V

#### Input circuit:

#### Connection 2-wire (active)

RN22:

Uo ≤ 27.3 V DC

terminal 4.1 (+), 4.2 (-)

terminal 6.1 (+), 6.2 (-)

RN42:

terminal 4.1 (+), 4.2 (-)

lo ≤ 87.6 mA
Po = 597 mW
Ci = negligibly small
Li = negligibly small

#### Max. connection values:

Single values:

Ex ia IIC

Ex ia IIB Ex ia IIA

#### Combined values:

aiues.						
Ex ia IIC:	Lo/ Co	1.3 mH 0.047 µF	1 mH 0.052 μF	0.5 mH 0.065 µF		
Ex ia IIB:	Lo/ Co	26 mH 0.39 μF	2 mH 0.44 µF	1 mH 0.53 µF	0.5 mH 0.64 μF	0.2 mH 0.683 μF
Ex ia IIA:	Lo/ Co	49 mH 1.3 μF	20 mH 1.6 µF	2 (2.222.22)	0.5 mH 2.2 μF	0.2 mH 2.28 µF



Certificate No.:

**IECEx EPS 19.0100X** 

Page 5 of 6

Date of issue:

2022-02-11

Issue No: 1

#### Input circuit:

#### Connection 4-wire (passive)

Uo ≤ 27.3 V DC terminal 4.2 (+), 5.1 (-)  $lo \leq 10 \text{ mA}$ terminal 6.2 (+), 5.2 (-)  $Po = 68 \, \text{mW}$ RN42: Ci = negligibly small Li = negligibly small terminal 4.2 (+), 4.3 (-)

Max. connection values (combined):

Ex ia IIC:	Lo/	100 mH	2 mH	1 mH	0.5 mH
	Co	0.065 µF	0.072 µF	0.081 µF	0.088 μF
Ex ia IIB:	Lo/	100 mH	2 mH	1 mH	0.5 mH
	Co	0.48 µF	0.52 µF	0.59 µF	0.683 μF
Ex ia IIA:	Lo/ Co	100 mH 1.7 μF		1 mH 1.9 µF	0.5 mH 2.28 μF

#### Connection 4-wire (passive):

RN22:

Ui ≤ 30 V DC

terminal 4.2 (+), 5.1 (-)

not applicable when keeping Ui Pi not applicable when keeping Ui

terminal 6.2 (+), 5.2 (-)

RN42: terminal 4.2 (+), 4.3 (-)

Ci = negligibly small Li = negligibly small



Certificate No.:	IECEx EPS 19.0100X	Page 6 of 6

Date of issue: 2022-02-11 Issue No: 1

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)** 

Lo/Co values added, minor technical and editorial changes.