

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**Endress+Hauser Conducta GmbH & Co. KG**

Dieselstrasse 24, 70839 Gerlingen, Germany

the Certificate No: **Z01671** for the PROFIBUS Device:

Model Name:      Liquistation CSFxx  
 Revision:         Profile 3.02; SW/FW: 01.13; HW: 01.00  
 GSD:              EH01155C.GSD, File Version: 20.05.2022  
                       PA039760.GSD

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> DP-V0	MS0, Freeze, Auto_Baud, Set_Slave_Add
<input checked="" type="checkbox"/> DP-V1	MS1, Prm_Block_Structure, MS2, I&M
<input checked="" type="checkbox"/> Profile	PROFIBUS PA 3.02
<input checked="" type="checkbox"/> Physical Layer	RS485

Test Report Number:                    342-1 plus Manufacturer Declaration  
 Authorized Test Laboratory:         ifak, Magdeburg, Germany

The tests were executed in accordance with the following documents:  
 "Test Specifications for PROFIBUS DP Slaves, Version 3.0.9, September 2008" and  
 "Test Specifications for PROFIBUS PA Profile 3.0.2, Version 5.0.4, February 2010".


This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **January 24, 2026** the certificate is valid for life.


Karlsruhe, March 30, 2023

Board of PROFIBUS Nutzerorganisation e. V.

  
 \_\_\_\_\_  
 (Official in Charge)

  
 \_\_\_\_\_  
 (Karsten Schneider)



  
 \_\_\_\_\_  
 (Frank Moritz)