


# Operating Instructions

## Proline Promass E 100

Coriolis flowmeter  
PROFIBUS DP



- Make sure the document is stored in a safe place such that it is always available when working on or with the device.
- To avoid danger to individuals or the facility, read the "Basic safety instructions" section carefully, as well as all other safety instructions in the document that are specific to working procedures.
- The manufacturer reserves the right to modify technical data without prior notice. Your Endress+Hauser sales organization will supply you with current information and updates to this manual.

## Table of contents

|          |  |           |  |  |
|----------|--|-----------|--|--|
| <b>1</b> | <b>About this document</b> . . . . .   | <b>6</b>  |  |  |
| 1.1      | Document function . . . . .  | 6         |  |  |
| 1.2      | Symbols . . . . .  | 6         |  |  |
| 1.2.1    | Safety symbols . . . . .   | 6         |  |  |
| 1.2.2    | Electrical symbols . . . . .   | 6         |  |  |
| 1.2.3    | Tool symbols . . . . .   | 6         |  |  |
| 1.2.4    | Symbols for<br>certain types of information . . . . .                                    | 7         |  |  |
| 1.2.5    | Symbols in graphics . . . . .  | 7         |  |  |
| 1.3      | Documentation . . . . .  | 7         |  |  |
| 1.4      | Registered trademarks . . . . .  | 8         |  |  |
| <b>2</b> | <b>Safety instructions</b> . . . . .   | <b>9</b>  |  |  |
| 2.1      | Requirements for the personnel . . . . .   | 9         |  |  |
| 2.2      | Intended use . . . . .   | 9         |  |  |
| 2.3      | Workplace safety . . . . .   | 10        |  |  |
| 2.4      | Operational safety . . . . .   | 10        |  |  |
| 2.5      | Product safety . . . . .   | 10        |  |  |
| 2.6      | IT security . . . . .  | 11        |  |  |
| <b>3</b> | <b>Product description</b> . . . . .   | <b>12</b> |  |  |
| 3.1      | Product design . . . . .   | 12        |  |  |
| 3.1.1    | Device version with PROFIBUS DP<br>communication protocol . . . . .                      | 12        |  |  |
| <b>4</b> | <b>Incoming acceptance and product<br/>identification</b> . . . . .                      | <b>13</b> |  |  |
| 4.1      | Incoming acceptance . . . . .  | 13        |  |  |
| 4.2      | Product identification . . . . .   | 13        |  |  |
| 4.2.1    | Transmitter nameplate . . . . .  | 14        |  |  |
| 4.2.2    | Sensor nameplate . . . . .   | 14        |  |  |
| 4.2.3    | Symbols on the device . . . . .  | 15        |  |  |
| <b>5</b> | <b>Storage and transport</b> . . . . .   | <b>16</b> |  |  |
| 5.1      | Storage conditions . . . . .   | 16        |  |  |
| 5.2      | Transporting the product . . . . .   | 16        |  |  |
| 5.2.1    | Measuring devices without lifting<br>lugs . . . . .                                      | 16        |  |  |
| 5.2.2    | Measuring devices with lifting lugs . .  | 17        |  |  |
| 5.2.3    | Transporting with a fork lift . . . . .  | 17        |  |  |
| 5.3      | Packaging disposal . . . . .   | 17        |  |  |
| <b>6</b> | <b>Installation</b> . . . . .  | <b>18</b> |  |  |
| 6.1      | Installation requirements . . . . .  | 18        |  |  |
| 6.1.1    | Installation position . . . . .  | 18        |  |  |
| 6.1.2    | Environmental and process<br>requirements . . . . .                                      | 20        |  |  |
| 6.1.3    | Special installation instructions . . . . .  | 22        |  |  |
| 6.2      | Installing the measuring instrument . . . . .  | 23        |  |  |
| 6.2.1    | Required tools . . . . .   | 23        |  |  |
| 6.2.2    | Preparing the measuring instrument .   | 23        |  |  |
|          | 6.2.3 Mounting the measuring device . . . . .  | 23        |  |  |
| 6.3      | Post-installation check . . . . .  | 24        |  |  |
| <b>7</b> | <b>Electrical connection</b> . . . . .   | <b>25</b> |  |  |
| 7.1      | Electrical safety . . . . .  | 25        |  |  |
| 7.2      | Connecting requirements . . . . .  | 25        |  |  |
| 7.2.1    | Required tools . . . . .   | 25        |  |  |
| 7.2.2    | Requirements for connecting cable . . .  | 25        |  |  |
| 7.2.3    | Terminal assignment . . . . .  | 26        |  |  |
| 7.2.4    | Pin assignment, device plug . . . . .  | 27        |  |  |
| 7.2.5    | Preparing the measuring device . . . . .   | 27        |  |  |
| 7.3      | Connecting the measuring instrument . . . . .  | 27        |  |  |
| 7.3.1    | Connecting the transmitter . . . . .   | 28        |  |  |
| 7.4      | Potential equalization . . . . .   | 29        |  |  |
| 7.4.1    | Requirements . . . . .   | 29        |  |  |
| 7.5      | Special connection instructions . . . . .  | 30        |  |  |
| 7.5.1    | Connection examples . . . . .  | 30        |  |  |
| 7.6      | Hardware settings . . . . .  | 30        |  |  |
| 7.6.1    | Setting the device address . . . . .   | 30        |  |  |
| 7.6.2    | Enabling the terminating resistor . . . .  | 31        |  |  |
| 7.7      | Ensuring the degree of protection . . . . .  | 32        |  |  |
| 7.8      | Post-connection check . . . . .  | 32        |  |  |
| <b>8</b> | <b>Operation options</b> . . . . .   | <b>34</b> |  |  |
| 8.1      | Overview of operation options . . . . .  | 34        |  |  |
| 8.2      | Structure and function of the operating<br>menu . . . . .                                | 35        |  |  |
| 8.2.1    | Structure of the operating menu . . . . .  | 35        |  |  |
| 8.2.2    | Operating philosophy . . . . .   | 36        |  |  |
| 8.3      | Displaying the measured values via the local<br>display (optionally available) . . . . . | 37        |  |  |
| 8.3.1    | Operational display . . . . .  | 37        |  |  |
| 8.3.2    | User roles and related access<br>authorization . . . . .                                 | 38        |  |  |
| 8.4      | Access to operating menu via web browser . .   | 39        |  |  |
| 8.4.1    | Function range . . . . .   | 39        |  |  |
| 8.4.2    | Prerequisites . . . . .  | 39        |  |  |
| 8.4.3    | Connecting the device . . . . .  | 40        |  |  |
| 8.4.4    | Logging on . . . . .   | 41        |  |  |
| 8.4.5    | User interface . . . . .   | 42        |  |  |
| 8.4.6    | Disabling the Web server . . . . .   | 43        |  |  |
| 8.4.7    | Logging out . . . . .  | 43        |  |  |
| 8.5      | Access to the operating menu via the<br>operating tool . . . . .                         | 44        |  |  |
| 8.5.1    | Connecting the operating tool . . . . .  | 44        |  |  |
| 8.5.2    | FieldCare . . . . .  | 45        |  |  |
| 8.5.3    | DeviceCare . . . . .   | 46        |  |  |
| <b>9</b> | <b>System integration</b> . . . . .  | <b>47</b> |  |  |
| 9.1      | Overview of device description files . . . . .   | 47        |  |  |
| 9.1.1    | Current version data for the device . . .  | 47        |  |  |
| 9.1.2    | Operating tools . . . . .  | 47        |  |  |
| 9.2      | Device master file (GSD) . . . . .   | 47        |  |  |
| 9.2.1    | Manufacturer-specific GSD . . . . .  | 48        |  |  |

|           |  |           |           |   |            |
|-----------|--|-----------|-----------|---|------------|
| 9.2.2     | Profile GSD .....  | 48        | 12.4      | Diagnostic information in FieldCare or DeviceCare ..... | 94         |
| 9.3       | Integration into a PROFIBUS network .....                      | 49        | 12.4.1    | Diagnostic options .....                                | 94         |
| 9.3.1     | Block model .....  | 49        | 12.4.2    | Calling up remedy information .....                     | 95         |
| 9.3.2     | Assignment of the measured values in the function blocks ..... | 49        | 12.5      | Adapting the diagnostic information .....               | 95         |
| 9.3.3     | Totalizer control SET_TOT .....                                | 50        | 12.5.1    | Adapting the diagnostic behavior .....                  | 95         |
| 9.4       | Cyclic data transmission .....                                 | 51        | 12.6      | Overview of diagnostic information .....                | 98         |
| 9.4.1     | Block model .....  | 51        | 12.6.1    | Diagnostic of sensor .....                              | 98         |
| 9.4.2     | Description of the modules .....                               | 51        | 12.6.2    | Diagnostic of electronic .....                          | 102        |
| <b>10</b> | <b>Commissioning .....</b>                                     | <b>57</b> | 12.6.3    | Diagnostic of configuration .....                       | 110        |
| 10.1      | Post-mounting and post-connection check .....                  | 57        | 12.6.4    | Diagnostic of process .....                             | 116        |
| 10.2      | Connecting via FieldCare .....                                 | 57        | 12.7      | Pending diagnostic events .....                         | 123        |
| 10.3      | Setting the operating language .....                           | 57        | 12.8      | Diagnostics list .....                                  | 124        |
| 10.4      | Configuring the measuring instrument .....                     | 57        | 12.9      | Event logbook .....                                     | 124        |
| 10.4.1    | Defining the tag name .....                                    | 58        | 12.9.1    | Reading out the event logbook .....                     | 124        |
| 10.4.2    | Setting the system units .....                                 | 58        | 12.9.2    | Filtering the event logbook .....                       | 125        |
| 10.4.3    | Selecting and setting the medium .....                         | 61        | 12.9.3    | Overview of information events .....                    | 125        |
| 10.4.4    | Configuring communication interface .....                      | 62        | 12.10     | Resetting the measuring device .....                    | 126        |
| 10.4.5    | Configuration of the Analog Inputs .....                       | 63        | 12.10.1   | Function range of "Device reset" parameter .....        | 126        |
| 10.4.6    | Configuring the low flow cut off .....                         | 64        | 12.11     | Device information .....                                | 127        |
| 10.4.7    | Configuring partially filled pipe detection .....              | 65        | 12.12     | Firmware history .....                                  | 129        |
| 10.5      | Advanced settings .....  | 66        | <b>13</b> | <b>Maintenance .....</b>                                | <b>130</b> |
| 10.5.1    | Using the parameter to enter the access code .....             | 66        | 13.1      | Maintenance work .....                                  | 130        |
| 10.5.2    | Calculated process variables .....                             | 66        | 13.1.1    | Exterior cleaning .....                                 | 130        |
| 10.5.3    | Carrying out a sensor adjustment .....                         | 68        | 13.1.2    | Internal cleaning .....                                 | 130        |
| 10.5.4    | Configuring the totalizer .....                                | 72        | 13.2      | Measuring and test equipment .....                      | 130        |
| 10.5.5    | Using parameters for device administration .....               | 73        | 13.3      | Endress+Hauser services .....                           | 130        |
| 10.6      | Simulation .....   | 74        | <b>14</b> | <b>Repair .....</b>                                     | <b>131</b> |
| 10.7      | Protecting settings from unauthorized access .....             | 75        | 14.1      | General notes .....                                     | 131        |
| 10.7.1    | Write protection via access code .....                         | 75        | 14.1.1    | Repair and conversion concept .....                     | 131        |
| 10.7.2    | Write protection via write protection switch .....             | 76        | 14.1.2    | Notes for repair and conversion .....                   | 131        |
| <b>11</b> | <b>Operation .....</b>   | <b>77</b> | 14.2      | Spare parts .....                                       | 131        |
| 11.1      | Reading the device locking status .....                        | 77        | 14.3      | Endress+Hauser services .....                           | 131        |
| 11.2      | Adjusting the operating language .....                         | 77        | 14.4      | Return .....  | 131        |
| 11.3      | Configuring the display .....                                  | 77        | 14.5      | Disposal .....  | 132        |
| 11.4      | Reading off measured values .....                              | 77        | 14.5.1    | Removing the measuring device .....                     | 132        |
| 11.4.1    | "Measured variables" submenu .....                             | 77        | 14.5.2    | Disposing of the measuring device .....                 | 132        |
| 11.4.2    | "Totalizer" submenu .....                                      | 87        | <b>15</b> | <b>Accessories .....</b>                                | <b>133</b> |
| 11.5      | Adapting the measuring device to the process conditions .....  | 88        | 15.1      | Device-specific accessories .....                       | 133        |
| 11.6      | Performing a totalizer reset .....                             | 88        | 15.1.1    | For the sensor .....                                    | 133        |
| <b>12</b> | <b>Diagnostics and troubleshooting .....</b>                   | <b>90</b> | 15.2      | Communication-specific accessories .....                | 133        |
| 12.1      | General troubleshooting .....                                  | 90        | 15.3      | Service-specific accessories .....                      | 134        |
| 12.2      | Diagnostic information via LEDs .....                          | 91        | 15.4      | System components .....                                 | 135        |
| 12.2.1    | Transmitter .....  | 91        | <b>16</b> | <b>Technical data .....</b>                             | <b>136</b> |
| 12.3      | Diagnostic information in the web browser .....                | 92        | 16.1      | Application .....                                       | 136        |
| 12.3.1    | Diagnostic options .....                                       | 92        | 16.2      | Function and system design .....                        | 136        |
| 12.3.2    | Calling up remedy information .....                            | 94        | 16.3      | Input .....   | 137        |
|           |  |           | 16.4      | Output .....  | 138        |
|           |  |           | 16.5      | Power supply .....                                      | 140        |
|           |  |           | 16.6      | Performance characteristics .....                       | 141        |
|           |  |           | 16.7      | Mounting .....  | 145        |

|   |            |
|---|------------|
| 16.8 Environment .....                  | 145        |
| 16.9 Process .....                      | 146        |
| 16.10 Mechanical construction .....     | 148        |
| 16.11 Operability .....                 | 151        |
| 16.12 Certificates and approvals .....  | 153        |
| 16.13 Application packages .....        | 155        |
| 16.14 Accessories .....                 | 156        |
| 16.15 Supplementary documentation ..... | 156        |
| <b>Index .....</b>                      | <b>158</b> |

# 1 About this document

## 1.1 Document function

These Operating Instructions contain all the information required in the various life cycle phases of the device: from product identification, incoming acceptance and storage, to installation, connection, operation and commissioning, through to troubleshooting, maintenance and disposal.

## 1.2 Symbols

### 1.2.1 Safety symbols

#### DANGER

This symbol alerts you to a dangerous situation. Failure to avoid this situation will result in serious or fatal injury.

#### WARNING

This symbol alerts you to a potentially dangerous situation. Failure to avoid this situation can result in serious or fatal injury.






#### CAUTION

This symbol alerts you to a potentially dangerous situation. Failure to avoid this situation can result in minor or medium injury.



#### NOTICE

This symbol alerts you to a potentially harmful situation. Failure to avoid this situation can result in damage to the product or something in its vicinity.













### 1.2.2 Electrical symbols

| Symbol  | Meaning  |
|---|--|
|  | Direct current   |
|  | Alternating current  |
|  | Direct current and alternating current   |
|  | <b>Ground connection</b><br>A grounded terminal which, as far as the operator is concerned, is grounded via a grounding system.  |
|  | <b>Potential equalization connection (PE: protective earth)</b><br>Ground terminals that must be connected to ground prior to establishing any other connections.<br><br>The ground terminals are located on the interior and exterior of the device: <ul style="list-style-type: none"> <li>▪ Interior ground terminal: potential equalization is connected to the supply network.</li> <li>▪ Exterior ground terminal: device is connected to the plant grounding system.</li> </ul> |








### 1.2.3 Tool symbols

| Symbol  | Meaning           |
|---|-------------------|
|  | Allen key         |
|  | Open-ended wrench |


### 1.2.4 Symbols for certain types of information

| Symbol  | Meaning  |
|---|--|
|    | <b>Permitted</b><br>Procedures, processes or actions that are permitted. |
|    | <b>Preferred</b><br>Procedures, processes or actions that are preferred. |
|    | <b>Forbidden</b><br>Procedures, processes or actions that are forbidden. |
|    | <b>Tip</b><br>Indicates additional information.                          |
|    | Reference to documentation   |
|    | Reference to page  |
|    | Reference to graphic   |
|    | Notice or individual step to be observed                                 |
|    | Series of steps  |
|    | Result of a step   |
|    | Help in the event of a problem   |
|  | Visual inspection  |

### 1.2.5 Symbols in graphics


| Symbol  | Meaning                        |
|---|--------------------------------|
|  | Item numbers                   |
|  | Series of steps                |
|  | Views                          |
|  | Sections                       |
|  | Hazardous area                 |
|  | Safe area (non-hazardous area) |
|  | Flow direction                 |

## 1.3 Documentation

 For an overview of the scope of the associated Technical Documentation, refer to the following:

- *Device Viewer* ([www.endress.com/deviceviewer](http://www.endress.com/deviceviewer)): Enter the serial number from the nameplate
- *Endress+Hauser Operations app*: Enter serial number from nameplate or scan matrix code on nameplate.

The following documentation may be available depending on the device version ordered:

| Document type  | Purpose and content of the document   |
|--|---|
| Technical Information (TI)                           | <b>Planning aid for your device</b><br>The document contains all the technical data on the device and provides an overview of the accessories and other products that can be ordered for the device.  |
| Brief Operating Instructions (KA)                    | <b>Guide that takes you quickly to the 1st measured value</b><br>The Brief Operating Instructions contain all the essential information from incoming acceptance to initial commissioning.  |
| Operating Instructions (BA)                          | <b>Your reference document</b><br>These Operating Instructions contain all the information that is required in the various life cycle phases of the device: from product identification, incoming acceptance and storage, to mounting, connection, operation and commissioning, through to troubleshooting, maintenance and disposal.   |
| Description of Device Parameters (GP)                | <b>Reference for your parameters</b><br>The document provides a detailed explanation of each individual parameter. The description is aimed at those who work with the device over the entire life cycle and perform specific configurations.   |
| Safety Instructions (XA)                             | Depending on the approval, safety instructions for electrical equipment in hazardous areas are also supplied with the device. The Safety Instructions are a constituent part of the Operating Instructions.<br> Information on the Safety Instructions (XA) that are relevant for the device is provided on the nameplate. |
| Supplementary device-dependent documentation (SD/FY) | Always comply strictly with the instructions in the relevant supplementary documentation. The supplementary documentation is a constituent part of the device documentation.  |

## 1.4 Registered trademarks

### PROFIBUS®

Registered trademark of the PROFIBUS Nutzerorganisation e.V. (PROFIBUS User Organization), Karlsruhe, Germany

### TRI-CLAMP®

Registered trademark of Ladish & Co., Inc., Kenosha, USA



## 2 Safety instructions

### 2.1 Requirements for the personnel

The personnel for installation, commissioning, diagnostics and maintenance must fulfill the following requirements:

- ▶ Trained, qualified specialists must have a relevant qualification for this specific function and task.
- ▶ Are authorized by the plant owner/operator.
- ▶ Are familiar with federal/national regulations.
- ▶ Before starting work, read and understand the instructions in the manual and supplementary documentation as well as the certificates (depending on the application).
- ▶ Follow instructions and comply with basic conditions.

The operating personnel must fulfill the following requirements:

- ▶ Are instructed and authorized according to the requirements of the task by the facility's owner-operator.
- ▶ Follow the instructions in this manual.

### 2.2 Intended use

#### Application and media

The measuring instrument described in this manual is intended only for the flow measurement of liquids and gases.

Depending on the version ordered, the measuring instrument can also be used to measure potentially explosive <sup>1)</sup>, flammable, toxid and oxidizing media.

Measuring instruments for use in hazardous areas, in hygienic applications, or where there is an increased risk due to pressure, are specially labeled on the nameplate.

To ensure that the measuring instrument is in perfect condition during operation:

- ▶ Only use the measuring instrument in full compliance with the data on the nameplate and the general conditions listed in the Operating Instructions and supplementary documentation.
- ▶ Using the nameplate, check whether the ordered device is permitted for the intended use in the hazardous area (e.g. explosion protection, pressure vessel safety).
- ▶ Use the measuring instrument only for media to which the process-wetted materials are sufficiently resistant.
- ▶ Keep within the specified pressure and temperature range.
- ▶ Keep within the specified ambient temperature range.
- ▶ Protect the measuring instrument permanently against corrosion from environmental influences.

#### Incorrect use

Non-designated use can compromise safety. The manufacturer is not liable for damage caused by improper or non-designated use.

#### **WARNING**

#### **Danger of breakage due to corrosive or abrasive fluids and ambient conditions!**

- ▶ Verify the compatibility of the process fluid with the sensor material.
- ▶ Ensure the resistance of all fluid-wetted materials in the process.
- ▶ Keep within the specified pressure and temperature range.

1) Not applicable for IO-Link measuring instruments

**NOTICE****Verification for borderline cases:**

- ▶ For special fluids and fluids for cleaning, Endress+Hauser is glad to provide assistance in verifying the corrosion resistance of fluid-wetted materials, but does not accept any warranty or liability as minute changes in the temperature, concentration or level of contamination in the process can alter the corrosion resistance properties.

**Residual risks****⚠ CAUTION****Risk of hot or cold burns! The use of media and electronics with high or low temperatures can produce hot or cold surfaces on the device.**

- ▶ Mount suitable touch protection.

**⚠ WARNING****Danger of housing breaking due to measuring tube breakage!**

If a measuring tube ruptures, the pressure inside the sensor housing will rise according to the operating process pressure.

- ▶ Use a rupture disk.

**⚠ WARNING****Danger from medium escaping!**

For device versions with a rupture disk: medium escaping under pressure can cause injury or material damage.

- ▶ Take precautions to prevent injury and material damage if the rupture disk is actuated.

## 2.3 Workplace safety

When working on and with the device:

- ▶ Wear the required personal protective equipment as per national regulations.

## 2.4 Operational safety

Damage to the device!

- ▶ Operate the device in proper technical condition and fail-safe condition only.
- ▶ The operator is responsible for the interference-free operation of the device.

**Modifications to the device**

Unauthorized modifications to the device are not permitted and can lead to unforeseeable dangers!

- ▶ If modifications are nevertheless required, consult with the manufacturer.

**Repair**

To ensure continued operational safety and reliability:

- ▶ Carry out repairs on the device only if they are expressly permitted.
- ▶ Observe federal/national regulations pertaining to the repair of an electrical device.
- ▶ Use only original spare parts and accessories.

## 2.5 Product safety

This measuring device is designed in accordance with good engineering practice to meet state-of-the-art safety requirements, has been tested, and left the factory in a condition in which it is safe to operate.

It meets general safety standards and legal requirements. It also complies with the EU directives listed in the device-specific EU Declaration of Conformity. The manufacturer confirms this by affixing the CE mark to the device..

## **2.6 IT security**

Our warranty is valid only if the product is installed and used as described in the Operating Instructions. The product is equipped with security mechanisms to protect it against any inadvertent changes to the settings.

IT security measures, which provide additional protection for the product and associated data transfer, must be implemented by the operators themselves in line with their security standards.

### 3 Product description


The device consists of a transmitter and a sensor.

The device is available as a compact version:

The transmitter and sensor form a mechanical unit.

#### 3.1 Product design

##### 3.1.1 Device version with PROFIBUS DP communication protocol



A0023153

1 Important components of a measuring device

- 1 Sensor
- 2 Transmitter housing
- 3 Main electronics module
- 4 Transmitter housing cover
- 5 Transmitter housing cover (version for optional local display)
- 6 Local display (optional)
- 7 Main electronics module (with bracket for optional local display)

## 4 Incoming acceptance and product identification

### 4.1 Incoming acceptance

On receipt of the delivery:

1. Check the packaging for damage.
  - ↳ Report all damage immediately to the manufacturer.  
Do not install damaged components.
2. Check the scope of delivery using the delivery note.
3. Compare the data on the nameplate with the order specifications on the delivery note.
4. Check the technical documentation and all other necessary documents, e.g. certificates, to ensure they are complete.



If one of the conditions is not satisfied, contact the manufacturer.

### 4.2 Product identification


The device can be identified in the following ways:

- Nameplate
- Order code with details of the device features on the delivery note
- Enter the serial numbers from the nameplates in the *Device Viewer* ([www.endress.com/deviceviewer](http://www.endress.com/deviceviewer)): all the information about the device is displayed.
- Enter the serial numbers from the nameplates into the *Endress+Hauser Operations app* or scan the DataMatrix code on the nameplate with the *Endress+Hauser Operations app*: all the information about the device is displayed.

For an overview of the scope of the associated Technical Documentation, refer to the following:

- The "Additional standard device documentation" and "Supplementary device-dependent documentation" sections
- The *Device Viewer*: Enter the serial number from the nameplate ([www.endress.com/deviceviewer](http://www.endress.com/deviceviewer))
- The *Endress+Hauser Operations app*: Enter the serial number from the nameplate or scan the DataMatrix code on the nameplate.

### 4.2.1 Transmitter nameplate




A0030222

2 Example of a transmitter nameplate

- 1 Manufacturer address/certificate holder
- 2 Name of the transmitter
- 3 Order code
- 4 Serial number
- 5 Extended order code
- 6 Electrical connection data, e.g. available inputs and outputs, supply voltage
- 7 Permitted ambient temperature ( $T_a$ )
- 8 Degree of protection
- 9 2-D matrix code
- 10 Document number of safety-related supplementary documentation → 157
- 11 Date of manufacture: year-month
- 12 CE mark, RCM-Tick mark
- 13 Firmware version (FW)


### 4.2.2 Sensor nameplate



A0029206

3 Example of a sensor nameplate, part 1

- 1 Name of the sensor
- 2 Manufacturer address/certificate holder
- 3 Nominal diameter of the sensor; flange nominal diameter/nominal pressure; sensor test pressure; medium temperature range; material of measuring tube and manifold
- 4 Sensor-specific information
- 5 CE mark, RCM-Tick mark
- 6 Order code
- 7 Serial number (Ser. no.)
- 8 Extended order code (Ext. ord. cd.)



A0029207

4 Example of a sensor nameplate, part 2

- 1 Approval information for explosion protection, Pressure Equipment Directive and degree of protection
- 2 Allowable ambient temperature ( $T_a$ )
- 3 Document number of safety-related supplementary documentation
- 4 2-D matrix code
- 5 Flow direction
- 6 Date of manufacture: year-month



**Order code**

The measuring device is reordered using the order code.

**Extended order code**

- The device type (product root) and basic specifications (mandatory features) are always listed.
- Of the optional specifications (optional features), only the safety and approval-related specifications are listed (e.g. LA). If other optional specifications are also ordered, these are indicated collectively using the # placeholder symbol (e.g. #LA#).
- If the ordered optional specifications do not include any safety and approval-related specifications, they are indicated by the + placeholder symbol (e.g. XXXXXX-ABCDE+).

**4.2.3 Symbols on the device**

| Symbol | Meaning   |
|--------|---|
|        | <b>WARNING!</b><br>This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in serious or fatal injury. Please consult the documentation for the measuring instrument to discover the type of potential danger and measures to avoid it. |
|        | <b>Reference to documentation</b><br>Refers to the corresponding device documentation.  |
|        | <b>Protective ground connection</b><br>A terminal that must be connected to the ground prior to establishing any other connections.   |

## 5 Storage and transport

### 5.1 Storage conditions


Observe the following notes for storage:

- ▶ Store in the original packaging to ensure protection from shock.
- ▶ Do not remove protective covers or protective caps installed on process connections. They prevent mechanical damage to the sealing surfaces and contamination in the measuring tube.
- ▶ Protect from direct sunlight. Avoid unacceptably high surface temperatures.
- ▶ Store in a dry and dust-free place.
- ▶ Do not store outdoors.

Storage temperature → 📄 145

### 5.2 Transporting the product

Transport the measuring device to the measuring point in the original packaging.



A0029252

- i** Do not remove protective covers or caps installed on process connections. They prevent mechanical damage to the sealing surfaces and contamination in the measuring tube.


#### 5.2.1 Measuring devices without lifting lugs

##### **⚠ WARNING**

**Center of gravity of the measuring device is higher than the suspension points of the webbing slings.**

Risk of injury if the measuring device slips.

- ▶ Secure the measuring device against slipping or turning.
- ▶ Observe the weight specified on the packaging (stick-on label).



A0029214



### 5.2.2 Measuring devices with lifting lugs

**⚠ CAUTION**

**Special transportation instructions for devices with lifting lugs**

- ▶ Only use the lifting lugs fitted on the device or flanges to transport the device.
- ▶ The device must always be secured at two lifting lugs at least.

### 5.2.3 Transporting with a fork lift

If transporting in wood crates, the floor structure enables the crates to be lifted lengthwise or at both sides using a forklift.

## 5.3 Packaging disposal

All packaging materials are environmentally friendly and 100% recyclable:


- Outer packaging of device
  - Stretch wrap made of polymer in accordance with EU Directive 2002/95/EC (RoHS)
- Packaging
  - Wood crate treated in accordance with ISPM 15 standard, confirmed by IPPC logo
  - Cardboard box in accordance with European packaging guideline 94/62/EC, recyclability confirmed by Resy symbol
- Transport material and fastening fixtures
  - Disposable plastic pallet
  - Plastic straps
  - Plastic adhesive strips
- Filler material
  - Paper pads

## 6 Installation

### 6.1 Installation requirements

#### 6.1.1 Installation position

##### Installation point




A0028772

To prevent measuring errors arising from accumulation of gas bubbles in the measuring pipe, avoid the following mounting locations in the piping:


- Highest point of a pipeline.
- Directly upstream of a free pipe outlet in a down pipe.

##### *Installation in down pipes*

However, the following installation suggestion allows for installation in an open vertical pipeline. Pipe restrictions or the use of an orifice with a smaller cross-section than the nominal diameter prevent the sensor running empty while measurement is in progress.



A0028773





 5 Installation in a down pipe (e.g. for batching applications)

- 1 Supply tank
- 2 Sensor
- 3 Orifice plate, pipe restriction
- 4 Valve
- 5 Filling vessel

| DN   |       | Ø orifice plate, pipe restriction |      |
|------|-------|-----------------------------------|------|
| [mm] | [in]  | [mm]                              | [in] |
| 8    | 3/8   | 6                                 | 0.24 |
| 15   | 1/2   | 10                                | 0.40 |
| 25   | 1     | 14                                | 0.55 |
| 40   | 1 1/2 | 22                                | 0.87 |
| 50   | 2     | 28                                | 1.10 |
| 80   | 3     | 50                                | 1.97 |


**Orientation**

The direction of the arrow on the sensor nameplate helps you to install the sensor according to the flow direction (direction of medium flow through the piping).

| Orientation |  | Recommendation                            |
|-------------|--|---|
| <b>A</b>    | Vertical orientation<br>                            | ✓✓ <sup>1)</sup>                          |
| <b>B</b>    | Horizontal orientation, transmitter at top<br>     | ✓✓ <sup>2)</sup><br>Exception:<br>→ 6, 19 |
| <b>C</b>    | Horizontal orientation, transmitter at bottom<br> | ✓✓ <sup>3)</sup><br>Exception:<br>→ 6, 19 |
| <b>D</b>    | Horizontal orientation, transmitter at side<br>   | ✗   |

- 1) This orientation is recommended to ensure self-draining.
- 2) Applications with low process temperatures may reduce the ambient temperature. To maintain the minimum ambient temperature for the transmitter, this orientation is recommended.
- 3) Applications with high process temperatures may increase the ambient temperature. To maintain the maximum ambient temperature for the transmitter, this orientation is recommended.

If a sensor is installed horizontally with a curved measuring tube, match the position of the sensor to the fluid properties.




6 Orientation of sensor with curved measuring tube


- 1 Avoid this orientation for fluids with entrained solids: Risk of solids accumulating
- 2 Avoid this orientation for outgassing fluids: Risk of gas accumulating

**Inlet and outlet runs**

No special precautions need to be taken for fittings that create turbulence, such as valves, elbows or T-pieces, as long as no cavitation occurs → 20.



*Installation dimensions*

 For the dimensions and installation lengths of the device, see the "Technical Information" document, "Mechanical construction" section

**6.1.2 Environmental and process requirements**

**Ambient temperature range**

|                         |   |
|-------------------------|---|
| <b>Measuring device</b> | <ul style="list-style-type: none"> <li>■ -40 to +60 °C (-40 to +140 °F)</li> <li>■ Order code for "Test, certificate", option JM: -50 to +60 °C (-58 to +140 °F)</li> </ul> |
|-------------------------|---|

- ▶ If operating outdoors:  
Avoid direct sunlight, particularly in warm climatic regions.

**Static pressure**

It is important that cavitation does not occur, or that gases entrained in the liquids do not outgas.


Cavitation is caused if the pressure drops below the vapor pressure:

- In liquids that have a low boiling point (e.g. hydrocarbons, solvents, liquefied gases)
- In suction lines

- ▶ Ensure the static pressure is sufficiently high to prevent cavitation and outgassing.

For this reason, the following mounting locations are recommended:

- At the lowest point in a vertical pipe
- Downstream from pumps (no danger of vacuum)




**Thermal insulation**


In the case of some fluids, it is important to keep the heat radiated from the sensor to the transmitter to a low level. A wide range of materials can be used for the required insulation.

**NOTICE****Electronics overheating on account of thermal insulation!**

- ▶ Recommended orientation: horizontal orientation, transmitter housing pointing downwards.
- ▶ Do not insulate the transmitter housing .
- ▶ Maximum permissible temperature at the lower end of the transmitter housing: 80 °C (176 °F)
- ▶ Regarding thermal insulation with an exposed extended neck: We advise against insulating the extended neck to ensure optimal heat dissipation.



A0034391

 7 Thermal insulation with exposed extended neck

**Heating****NOTICE****Electronics can overheat due to elevated ambient temperature!**

- ▶ Observe maximum permitted ambient temperature for the transmitter.
- ▶ Depending on the medium temperature, take the device orientation requirements into account.

**NOTICE****Danger of overheating when heating**

- ▶ Ensure that the temperature at the lower end of the transmitter housing does not exceed 80 °C (176 °F).
- ▶ Ensure that sufficient convection takes place at the transmitter neck.
- ▶ Ensure that a sufficiently large area of the transmitter neck remains exposed. The uncovered part serves as a radiator and protects the electronics from overheating and excessive cooling.
- ▶ When using in potentially explosive atmospheres, observe the information in the device-specific Ex documentation. For detailed information on the temperature tables, see the separate document entitled "Safety Instructions" (XA) for the device.
- ▶ Consider the "830 ambient temperature too high" and "832 electronics temperature too high" process diagnostics if overheating cannot be ruled out based on a suitable system design.

*Heating options*

If a fluid requires that no heat loss should occur at the sensor, users can avail of the following heating options:

- Electrical heating, e.g. with electric band heaters <sup>2)</sup>
- Via pipes carrying hot water or steam
- Via heating jackets

**Vibrations**

The high oscillation frequency of the measuring tubes ensures that the correct operation of the measuring system is not influenced by plant vibrations.


2) The use of parallel electric band heaters is generally recommended (bidirectional electricity flow). Particular considerations must be made if a single-wire heating cable is to be used. For additional information, refer to EA01339D "Installation Instructions for Electrical Trace Heating Systems".

### 6.1.3 Special installation instructions

#### Drainability

When installed vertically, the measuring tubes can be drained completely and protected against buildup.

#### Hygienic compatibility

**i** When installing in hygienic applications, please refer to the information in the "Certificates and approvals/hygienic compatibility" section →  153

#### Rupture disk

Process-related information: →  147.


#### **⚠ WARNING**

#### **Danger from medium escaping!**

Medium escaping under pressure can cause injury or material damage.


- ▶ Take precautions to prevent danger to persons and damage if the rupture disk is actuated.
- ▶ Observe the information on the rupture disk sticker.
- ▶ Make sure that the function and operation of the rupture disk is not impeded through the installation of the device.
- ▶ Do not use a heating jacket.
- ▶ Do not remove or damage the rupture disk.
  
- ▶ After the rupture disk is actuated, do not operate the measuring device any more.

The position of the rupture disk is indicated on a sticker applied over it. If the rupture disk is triggered, the sticker is destroyed. The disk can therefore be visually monitored.



1 Rupture disk label

#### Zero verification and zero adjustment

All measuring instruments are calibrated in accordance with state-of-the-art technology. Calibration takes place under reference conditions →  141. Therefore, a zero adjustment in the field is generally not required.

Experience shows that zero adjustment is advisable only in special cases:

- To achieve maximum measurement accuracy even with low flow rates.
- Under extreme process or operating conditions (e.g. very high process temperatures or very high-viscosity fluids).
- For gas applications with low pressure

**i** To achieve the highest possible measurement accuracy at low flow rates, the installation must protect the sensor from mechanical stresses during operation.

To get a representative zero point, ensure that:

- any flow in the device is prevented during the adjustment
- the process conditions (e.g. pressure, temperature) are stable and representative

Verification and adjustment cannot be carried out if the following process conditions are present:

- Gas pockets

Ensure that the system has been sufficiently flushed with the medium. Repeat flushing can help to eliminate gas pockets

- Thermal circulation

In the event of temperature differences (e.g. between the measuring tube inlet and outlet section), induced flow can occur even if the valves are closed due to thermal circulation in the device

- Leaks at the valves

If the valves are not leak-tight, flow is not sufficiently prevented when determining the zero point

If these conditions cannot be avoided, it is advisable to keep the factory setting for the zero point.

## 6.2 Installing the measuring instrument

### 6.2.1 Required tools

**For sensor**

For flanges and other process connections: Use a suitable mounting tool.

### 6.2.2 Preparing the measuring instrument

1. Remove all remaining transport packaging.
2. Remove any protective covers or protective caps present from the sensor.
3. If present, remove transport protection of the rupture disk.
4. Remove stick-on label on the electronics compartment cover.

### 6.2.3 Mounting the measuring device


#### **WARNING**

**Danger due to improper process sealing!**

- ▶ Ensure that the inside diameters of the gaskets are greater than or equal to that of the process connections and piping.
- ▶ Ensure that the seals are clean and undamaged.
- ▶ Secure the seals correctly.

1. Ensure that the direction of the arrow on the nameplate of the sensor matches the flow direction of the medium.

2. Install the measuring device or turn the transmitter housing so that the cable entries do not point upwards.



A0029263

### 6.3 Post-installation check

|  |                          |
|--|--------------------------|
| Is the device undamaged (visual inspection)?   | <input type="checkbox"/> |
| Does the measuring instrument correspond to the measuring point specifications?<br>For example: <ul style="list-style-type: none"> <li>▪ Process temperature → 146</li> <li>▪ Pressure (refer to the "Pressure-temperature ratings" section of the "Technical Information" document).</li> <li>▪ Ambient temperature → 145</li> <li>▪ Measuring range</li> </ul> | <input type="checkbox"/> |
| Has the correct orientation for the sensor been selected → 19? <ul style="list-style-type: none"> <li>▪ According to sensor type</li> <li>▪ According to medium temperature</li> <li>▪ According to medium properties (outgassing, with entrained solids)</li> </ul>   | <input type="checkbox"/> |
| Does the arrow on the sensor match the direction of flow of the medium? → 19?  | <input type="checkbox"/> |
| Is the tag name and labeling correct (visual inspection)?  | <input type="checkbox"/> |
| Is the device sufficiently protected from precipitation and direct sunlight?   | <input type="checkbox"/> |
| Are the securing screw and securing clamp tightened securely?  | <input type="checkbox"/> |



## 7 Electrical connection

### WARNING

**Live parts! Incorrect work performed on the electrical connections can result in an electric shock.**

- ▶ Set up a disconnecting device (switch or power-circuit breaker) to easily disconnect the device from the supply voltage.
- ▶ In addition to the device fuse, include an overcurrent protection unit with max. 16 A in the plant installation.

### 7.1 Electrical safety

In accordance with applicable national regulations.

### 7.2 Connecting requirements

#### 7.2.1 Required tools

- For cable entries: Use corresponding tools
- For securing clamp (on aluminum housing): Allen screw 3 mm
- For securing screw (for stainless steel housing): open-ended wrench 8 mm
- Wire stripper
- When using stranded cables: crimper for wire end ferrule

#### 7.2.2 Requirements for connecting cable

The connecting cables provided by the customer must fulfill the following requirements.


##### Permitted temperature range

- The installation guidelines that apply in the country of installation must be observed.
- The cables must be suitable for the minimum and maximum temperatures to be expected.

##### Power supply cable (incl. conductor for the inner ground terminal)

Standard installation cable is sufficient.

##### Signal cable

-  For custody transfer, all signal lines must be shielded cables (tinned copper braiding, optical coverage  $\geq 85\%$ ). The cable shield must be connected on both sides.

##### PROFIBUS DP

Shielded twisted-pair cable. Cable type A is recommended.

-  See <https://www.profibus.com> "PROFIBUS Installation Guidelines".

##### Cable diameter

- Cable glands supplied:  
M20  $\times$  1.5 with cable  $\varnothing$  6 to 12 mm (0.24 to 0.47 in)
- Spring terminals:  
Wire cross-sections 0.5 to 2.5 mm<sup>2</sup> (20 to 14 AWG)

### 7.2.3 Terminal assignment




#### Transmitter


PROFIBUS DP connection version

 For use in the non-hazardous area and Zone 2/Div. 2

Order code for "Output", option L

Depending on the housing version, the transmitters can be ordered with terminals or device plugs.

| Order code "Housing"   | Connection methods available  |   | Possible options for order code "Electrical connection"  |
|--|---|---|--|
|  | Output  | Power supply  |  |
| Options A, B   | Terminals   | Terminals   | <ul style="list-style-type: none"> <li>▪ Option A: coupling M20x1</li> <li>▪ Option B: thread M20x1</li> <li>▪ Option C: thread G ½"</li> <li>▪ Option D: thread NPT ½"</li> </ul>   |
| Options A, B   | Device plug connectors<br>→  27  | Terminals   | <ul style="list-style-type: none"> <li>▪ Option L: plug M12x1 + thread NPT ½"</li> <li>▪ Option N: plug M12x1 + coupling M20</li> <li>▪ Option P: plug M12x1 + thread G ½"</li> <li>▪ Option U: plug M12x1 + thread M20</li> </ul> |
| Options A, B, C  | Device plug connectors<br>→  27 | Device plug connectors<br>→  27 | Option Q: 2 x plug M12x1   |
| Order code for "Housing": <ul style="list-style-type: none"> <li>▪ Option A: compact, coated aluminum</li> <li>▪ Option B: compact, hygienic, stainless</li> <li>▪ Option C: ultra-compact, hygienic, stainless</li> </ul> |   |   |  |



A0022716

 8 PROFIBUS DP terminal assignment


- 1 Power supply: DC 24 V
- 2 PROFIBUS DP

| Order code "Output"   | Terminal number |        |                |                |
|---|-----------------|--------|----------------|----------------|
|   | Power supply    |        | Output         |                |
|   | 2 (L-)          | 1 (L+) | 26 (RxD/TxD-P) | 27 (RxD/TxD-N) |
| Option L  | DC 24 V         |        | B              | A              |
| Order code for "Output":<br>Option L: PROFIBUS DP, for use in non-hazardous areas and Zone 2/Div. 2 |                 |        |                |                |


### 7.2.4 Pin assignment, device plug

#### Supply voltage

**i** For use in the non-hazardous area and Zone 2/Div. 2.

|  | Pin | Assignment  |                     |
|---|-----|-------------|---------------------|
|   | 1   | L+          | DC 24 V             |
|   | 2   |             | Not assigned        |
|   | 3   |             | Not assigned        |
|   | 4   | L-          | DC 24 V             |
|   | 5   |             | Grounding/shielding |
| Coding  |     | Plug/socket |                     |
| A   |     | Plug        |                     |

#### Device plug for signal transmission (device side)

|  | Pin | Assignment  |                     |
|--|-----|-------------|---------------------|
|  | 1   |             | Not assigned        |
|  | 2   | A           | PROFIBUS DP         |
|  | 3   |             | Not assigned        |
|  | 4   | B           | PROFIBUS DP         |
|  | 5   |             | Grounding/shielding |
| Coding   |     | Plug/socket |                     |
| B  |     | Socket      |                     |


### 7.2.5 Preparing the measuring device

#### NOTICE

#### Insufficient sealing of the housing!

Operational reliability of the measuring device could be compromised.


► Use suitable cable glands corresponding to the degree of protection.

1. Remove dummy plug if present.
2. If the measuring device is supplied without cable glands:  
Provide suitable cable gland for corresponding connecting cable.
3. If the measuring device is supplied with cable glands:  
Observe requirements for connecting cables →  25.

## 7.3 Connecting the measuring instrument

#### NOTICE


#### An incorrect connection compromises electrical safety!

- Only properly trained specialist staff may perform electrical connection work.
- Observe applicable federal/national installation codes and regulations.
- Comply with local workplace safety regulations.
- Always connect the protective ground cable  before connecting additional cables.
- When using in potentially explosive atmospheres, observe the information in the device-specific Ex documentation.

### 7.3.1 Connecting the transmitter

The connection of the transmitter depends on the following order codes:


- Housing version: compact or ultra-compact
- Connection version: device plug or terminals



A0016924

9 Housing versions and connection versions

- A Housing version: compact, coated, aluminum
- B Housing version: compact, hygienic, stainless
- 1 Cable entry or device plug for signal transmission
- 2 Cable entry or device plug for supply voltage
- C Housing version: ultra-compact, hygienic, stainless
- 3 Device plug for signal transmission
- 4 Device plug for supply voltage





A0017844

10 Device versions with connection examples

- 1 Cable
- 2 Device plug for signal transmission
- 3 Device plug for supply voltage

For device version with device plug: follow step 6 only.

1. Depending on the housing version, loosen the securing clamp or fixing screw of the housing cover.
2. Depending on the housing version, unscrew or open the housing cover and disconnect the local display from the main electronics module where necessary  
→  151.
3. Push the cable through the cable entry . To ensure tight sealing, do not remove the sealing ring from the cable entry.
4. Strip the cable and cable ends. In the case of stranded cables, also fit ferrules.
5. Connect the cable in accordance with the terminal assignment or the device plug pin assignment .
6. Depending on the device version, tighten the cable glands or plug in the device plug and tighten .
7.  **WARNING**  
**Housing degree of protection may be voided due to insufficient sealing of the housing.**
  - ▶ Screw in the screw without using any lubricant. The threads on the cover are coated with a dry lubricant.

Reverse the removal procedure to reassemble the transmitter.

## 7.4 Potential equalization

### 7.4.1 Requirements


For potential equalization:

- Pay attention to in-house grounding concepts
- Take account of operating conditions, such as the pipe material and grounding
- Connect the medium, sensor and transmitter to the same electric potential
- Use a ground cable with a minimum cross-section of 6 mm<sup>2</sup> (10 AWG) and a cable lug for potential equalization connections

## 7.5 Special connection instructions

### 7.5.1 Connection examples

#### PROFIBUS DP



11 Connection example for PROFIBUS DP, non-hazardous area and Zone 2/Div. 2

- 1 Control system (e.g. PLC)
- 2 Cable shield provided at one end. The cable shield must be grounded at both ends to comply with EMC requirements; observe cable specifications
- 3 Distribution box
- 4 Transmitter

**i** If baud rates > 1.5 MBaud an EMC cable entry must be used and the cable shield must continue as far as the terminal wherever possible.


## 7.6 Hardware settings

### 7.6.1 Setting the device address

#### PROFIBUS DP

The address must always be configured for a PROFIBUS DP/PA device. The valid address range is between 1 and 126. In a PROFIBUS DP/PA network, each address can only be assigned once. If an address is not configured correctly, the device is not recognized by the master. All measuring devices are delivered from the factory with the device address 126 and with the software addressing method.

### Setting the address



12 Addressing using DIP switches on the I/O electronics module

1. Depending on the housing version, loosen the securing clamp or fixing screw of the housing cover.
2. Depending on the housing version, unscrew or open the housing cover and disconnect the local display from the main electronics module where necessary → 151.
3. Disable software addressing via DIP switch 8 (OFF).
4. Set the desired device address via the corresponding DIP switches.
  - ↳ Example → 12, 31:  $1 + 16 + 32 =$  device address 49  
The device demands rebooting after 10 s. After rebooting, hardware addressing is enabled with the configured IP address.
5. Reverse the removal procedure to reassemble the transmitter.


## 7.6.2 Enabling the terminating resistor

### PROFIBUS DP

To avoid incorrect communication transmission caused by impedance mismatch, terminate the PROFIBUS DP cable correctly at the start and end of the bus segment.

- If the device is operated with a baud rate of 1.5 MBaud and under:  
For the last transmitter on the bus, terminate via DIP switch 2 (bus termination) and DIP switch 1 and 3 (bus polarization). Setting: ON – ON – ON → 13, 32.
- For baud rates > 1.5 MBaud:  
Due to the capacitance load of the user and the line reflections generated as a result, ensure that an external bus terminator is used.

**i** It is generally advisable to use an external bus terminator as the entire segment can fail if a device that is terminated internally is defective.




13 Termination using DIP switches on the I/O electronics module (for baud rates < 1.5 Mbaud)

### 7.7 Ensuring the degree of protection

The measuring instrument fulfills all the requirements for the degree of protection IP66/67, Type 4X enclosure.

To guarantee the degree of protection IP66/67, Type 4X enclosure, carry out the following steps after the electrical connection:

1. Check that the housing seals are clean and fitted correctly.
2. Dry, clean or replace the seals if necessary.
3. Tighten all housing screws and screw covers.
4. Firmly tighten the cable glands.
5. To ensure that moisture does not enter the cable entry:  
Route the cable so that it loops down before the cable entry ("water trap").









6. The cable glands supplied do not ensure housing protection when not in use. They must therefore be replaced by dummy plugs corresponding to the housing protection.

### 7.8 Post-connection check


|   |                          |
|---|--------------------------|
| Are the device and cable undamaged (visual inspection)? | <input type="checkbox"/> |
| Do the cables used comply with the requirements → 25?   | <input type="checkbox"/> |



|   |                          |
|---|--------------------------|
| Are the installed cables strain-relieved and securely routed?   | <input type="checkbox"/> |
| Are all cable glands installed, securely tightened and leak-tight? Cable run with "water trap" →  32?  | <input type="checkbox"/> |
| Depending on the device version:<br>Are all connectors securely tightened →  28?   | <input type="checkbox"/> |
| Does the supply voltage match the specifications on the transmitter nameplate →  140?  | <input type="checkbox"/> |
| Is the terminal assignment →  26 or the device plug pin assignment →  27 correct? | <input type="checkbox"/> |
| If supply voltage is present:<br>Is the power LED on the transmitter electronics module lit in green →  12?  | <input type="checkbox"/> |
| Depending on the device version:<br><ul style="list-style-type: none"> <li>▪ Have the fixing screws been tightened with the correct tightening torque?</li> <li>▪ Is the securing clamp securely tightened?</li> </ul>                              | <input type="checkbox"/> |

## 8 Operation options

### 8.1 Overview of operation options






A0017760


- 1 Computer with web browser or with "FieldCare" operating tool
- 2 Automation system, e.g. "RSLogix" (Rockwell Automation) and work station for measuring instrument operation with Add-on Profile Level 3 for "RSLogix 5000" software (Rockwell Automation)

## 8.2 Structure and function of the operating menu

### 8.2.1 Structure of the operating menu

 For an overview of the operating menu for experts: see the "Description of Device Parameters" document supplied with the device →  156



 14 Schematic structure of the operating menu

A0018237-EN


### 8.2.2 Operating philosophy


The individual parts of the operating menu are assigned to certain user roles (e.g. operator, maintenance etc.). Each user role contains typical tasks within the device life cycle.

| Menu/parameter |                   | User role and tasks  | Content/meaning  |
|----------------|-------------------|--|--|
| Language       | Task-oriented     | <b>Role "Operator", "Maintenance"</b><br>Tasks during operation: <ul style="list-style-type: none"> <li>▪ Configuration of the operational display</li> <li>▪ Reading measured values</li> </ul>   | <ul style="list-style-type: none"> <li>▪ Defining the operating language</li> <li>▪ Defining the Web server operating language</li> <li>▪ Resetting and controlling totalizers</li> </ul>  |
| Operation      |                   |  | <ul style="list-style-type: none"> <li>▪ Configuration of the operational display (e.g. display format, display contrast)</li> <li>▪ Resetting and controlling totalizers</li> </ul>   |
| Setup          |                   | <b>"Maintenance" role</b><br>Commissioning:<br>Configuration of the measurement  | Submenus for fast commissioning: <ul style="list-style-type: none"> <li>▪ Configuring the system units</li> <li>▪ Definition of the medium</li> <li>▪ Configuration of the operational display</li> <li>▪ Configuring the low flow cut off</li> <li>▪ Configuring partial and empty pipe detection</li> </ul> Advanced setup <ul style="list-style-type: none"> <li>▪ For more customized configuration of the measurement (adaptation to special measuring conditions)</li> <li>▪ Configuration of totalizers</li> <li>▪ Administration (define access code, reset measuring device)</li> </ul>   |
| Diagnostics    |                   | <b>"Maintenance" role</b><br>Troubleshooting: <ul style="list-style-type: none"> <li>▪ Diagnostics and elimination of process and device errors</li> <li>▪ Measured value simulation</li> </ul>  | Contains all parameters for error detection and analyzing process and device errors: <ul style="list-style-type: none"> <li>▪ Diagnostic list<br/>Contains up to 5 currently pending diagnostic messages.</li> <li>▪ Event logbook<br/>Contains event messages that have occurred.</li> <li>▪ Device information<br/>Contains information for identifying the device</li> <li>▪ Measured values<br/>Contains all current measured values.</li> <li>▪ Analog inputs<br/>Is used to display the analog input.</li> <li>▪ Heartbeat Technology<br/>Verification of device functionality on request and documentation of verification results</li> <li>▪ Simulation<br/>Used to simulate measured values or output values.</li> </ul>  |
| Expert         | Function-oriented | Tasks that require detailed knowledge of the function of the device: <ul style="list-style-type: none"> <li>▪ Commissioning measurements under difficult conditions</li> <li>▪ Optimal adaptation of the measurement to difficult conditions</li> <li>▪ Detailed configuration of the communication interface</li> <li>▪ Error diagnostics in difficult cases</li> </ul> | Contains all of the device parameters and allows direct access to these by means of an access code. The structure of this menu is based on the function blocks of the device: <ul style="list-style-type: none"> <li>▪ System<br/>Contains all higher-level device parameters that do not affect measurement or measured value communication</li> <li>▪ Sensor<br/>Configuration of the measurement.</li> <li>▪ Communication<br/>Configuration of the digital communication interface and the Web server</li> <li>▪ Submenus for function blocks (e.g. "Analog Inputs")<br/>Configuration of function blocks</li> <li>▪ Application<br/>Configuration of the functions that go beyond the actual measurement (e.g. totalizer)</li> <li>▪ Diagnostics<br/>Error detection and analysis of process and device errors and for device simulation and Heartbeat Technology.</li> </ul> |

## 8.3 Displaying the measured values via the local display (optionally available)

### 8.3.1 Operational display

 The local display is optionally available:  
Order code for "Display; operation", option B "4-line, illuminated; via communication".







A0037831

- 1 Operational display
- 2 Tag name
- 3 Status area
- 4 Display area for measured values (4-line)


#### Status area

The following symbols appear in the status area of the operational display at the top right:

- Status signals
  - **F**: Failure
  - **C**: Function check
  - **S**: Out of specification
  - **M**: Maintenance required
- Diagnostic behavior
  - : Alarm
  - : Warning
  - : Locking (the device is locked via the hardware )
  - : Communication (communication via remote operation is active)



#### Display area





In the display area, each measured value is prefaced by certain symbol types for further description:




Appears only if a diagnostics event is present for this measured variable.

#### Measured variables

| Symbol  | Meaning  |
|---|--|
|  | Mass flow  |
|  | <ul style="list-style-type: none"> <li>▪ Volume flow</li> <li>▪ Corrected volume flow</li> </ul> |


|   |   |
|---|---|
|  | <ul style="list-style-type: none"> <li>▪ Density</li> <li>▪ Reference density</li> </ul>  |
|  | Temperature   |
|  | Totalizer<br> The measurement channel number indicates which of the three totalizers is displayed. |

*Measurement channel numbers*

| Symbol  | Meaning                    |
|---|----------------------------|
|    | Measurement channel 1 to 4 |
| The measurement channel number is displayed only if more than one channel is present for the same measured variable type (e.g. Totalizer 1 to 3). |                            |

*Diagnostic behavior*

The diagnostic behavior pertains to a diagnostic event that is relevant to the displayed measured variable. For information on the symbols

 The number and display format of the measured values can only be configured via the control system or Web server.

### 8.3.2 User roles and related access authorization

The two user roles "Operator" and "Maintenance" have different write access to the parameters if the customer defines a user-specific access code. This protects the device configuration from unauthorized access .

#### Defining access authorization for user roles

An access code is not yet defined when the device is delivered from the factory. Access authorization (read and write access) to the device is not restricted and corresponds to the "Maintenance" user role.

- ▶ Define the access code.
  - ↳ The "Operator" user role is redefined in addition to the "Maintenance" user role. Access authorization differs for the two user roles.

*Access authorization to parameters: "Maintenance" user role*


| Access code status   | Read access | Write access    |
|--|-------------|-----------------|
| An access code has not yet been defined (factory setting). | ✓           | ✓               |
| After an access code has been defined.                     | ✓           | ✓ <sup>1)</sup> |

1) The user only has write access after entering the access code.

*Access authorization to parameters: "Operator" user role*

| Access code status                     | Read access | Write access    |
|--|-------------|-----------------|
| After an access code has been defined. | ✓           | – <sup>1)</sup> |

1) Despite the defined access code, certain parameters can always be modified and thus are excluded from the write protection as they do not affect the measurement: write protection via access code

 The user role with which the user is currently logged on is indicated by the .  
 Navigation path:

## 8.4 Access to operating menu via web browser

### 8.4.1 Function range

With the integrated web server, the device can be operated and configured via a web browser service interface (CDI-RJ45) WLAN interface. In addition to the measured values, status information on the device is displayed and can be used to monitor device health. Furthermore the device data can be managed and the network parameters can be configured.



For additional information on the web server, see the Special Documentation for the device.

### 8.4.2 Prerequisites

#### Computer hardware

| Hardware   | Interface   |  |
|------------|---|--|
|            | CDI-RJ45  | WLAN   |
| Interface  | The computer must have an RJ45 interface.                 | The operating unit must have a WLAN interface. |
| Connection | Standard Ethernet cable with RJ45 connector.              | Connection via Wireless LAN.                   |
| Display    | Recommended size: ≥12" (depends on the screen resolution) |  |

#### Computer software

| Software                      | Interface  |      |
|-------------------------------|--|------|
|                               | CDI-RJ45   | WLAN |
| Recommended operating systems | <ul style="list-style-type: none"> <li>▪ Microsoft Windows 8 or higher.</li> <li>▪ Mobile operating systems:                             <ul style="list-style-type: none"> <li>▪ iOS</li> <li>▪ Android</li> </ul> </li> </ul> <p> Microsoft Windows XP is supported.</p> <p> Microsoft Windows 7 is supported.</p> |      |
| Web browsers supported        | <ul style="list-style-type: none"> <li>▪ Microsoft Internet Explorer 8 or higher</li> <li>▪ Microsoft Edge</li> <li>▪ Mozilla Firefox</li> <li>▪ Google Chrome</li> <li>▪ Safari</li> </ul>  |      |



#### Computer settings

|  |  |
|--|--|
| User rights                              | Appropriate user rights (e.g. administrator rights) for TCP/IP and proxy server settings are necessary (for adjusting the IP address, subnet mask etc.).   |
| Proxy server settings of the Web browser | The web browser setting <i>Use a Proxy Server for Your LAN</i> must be <b>deselected</b> .   |
| JavaScript                               | <p>JavaScript must be enabled.</p> <p> If JavaScript cannot be enabled:<br/>Enter <code>http://XXX.XXX.X.XX/servlet/basic.html</code> in the address bar of the web browser, e.g. <code>http://192.168.1.212/servlet/basic.html</code>. A fully functional but simplified version of the operating menu structure starts in the web browser.</p> |

|                     |   |
|---------------------|---|
| Network connections | Only the active network connections to the measuring device should be used. |
|                     | Switch off all other network connections.                                   |

 In the event of connection problems: →  90

*Measuring device: Via CDI-RJ45 service interface*

| Device           | CDI-RJ45 service interface   |
|------------------|--|
| Measuring device | The measuring device has an RJ45 interface.  |
| Web server       | Web server must be enabled; factory setting: ON<br> For information on enabling the Web server →  43 |

### 8.4.3 Connecting the device


#### Via service interface (CDI-RJ45)

##### *Preparing the measuring device*

##### *Configuring the Internet protocol of the computer*

The following information refers to the default Ethernet settings of the device.

IP address of the device: 192.168.1.212 (factory setting)

1. Switch on the measuring device.
2. Connect the computer to the RJ45 plug via the standard Ethernet cable →  152.
3. If a 2nd network card is not used, close all the applications on the notebook.
  - ↳ Applications requiring Internet or a network, such as e-mail, SAP applications, Internet or Windows Explorer.
4. Close any open Internet browsers.
5. Configure the properties of the Internet protocol (TCP/IP) as defined in the table:


|                 |  |
|-----------------|--|
| IP address      | 192.168.1.XXX; for XXX all numerical sequences except: 0, 212 and 255 → e.g. 192.168.1.213 |
| Subnet mask     | 255.255.255.0  |
| Default gateway | 192.168.1.212 or leave cells empty   |

#### Starting the web browser

1. Start the web browser on the computer.





2. Enter the IP address of the web server in the address line of the web browser:  
192.168.1.212  
↳ The login page appears.



A0053670


- 1 Picture of device
- 2 Device name
- 3 Device tag
- 4 Status signal
- 5 Current measured values
- 6 Operating language
- 7 User role
- 8 Access code
- 9 Login
- 10 Reset access code

 If a login page does not appear, or if the page is incomplete →  90


### 8.4.4 Logging on

1. Select the preferred operating language for the Web browser.
2. Enter the user-specific access code.
3. Press **OK** to confirm your entry.

|                    |  |
|--------------------|--|
| <b>Access code</b> | 0000 (factory setting); can be changed by customer |
|--------------------|--|

 If no action is performed for 10 minutes, the Web browser automatically returns to the login page.

### 8.4.5 User interface



A0032879

- 1 Picture of device
- 2 Device name
- 3 Device tag
- 4 Status signal
- 5 Current measured values
- 6 Navigation area
- 7 Local display language

#### Header

The following information appears in the header:

- Device name
- Device tag
- Device status with status signal → 📄 93
- Current measured values

#### Function row

| Functions       | Meaning   |
|-----------------|---|
| Measured values | Displays the measured values of the device  |
| Menu            | <ul style="list-style-type: none"> <li>■ Access to the operating menu from the measuring device</li> <li>■ The structure of the operating menu is the same as for the operating tools</li> <li>📄 Detailed information on the operating menu structure: Description of Device Parameters</li> </ul>  |
| Device status   | Displays the diagnostic messages currently pending, listed in order of priority   |
| Data management | <p>Data exchange between computer and measuring device:</p> <ul style="list-style-type: none"> <li>■ Device configuration:                             <ul style="list-style-type: none"> <li>■ Load settings from the device (XML format, save configuration)</li> <li>■ Save settings to the device (XML format, restore configuration)</li> </ul> </li> <li>■ Logbook - Export Event logbook (.csv file)</li> <li>■ Documents - Export documents:                             <ul style="list-style-type: none"> <li>■ Export backup data record (.csv file, create documentation of the measuring point configuration)</li> <li>■ Verification report (PDF file, only available with the "Heartbeat Verification" application package)</li> </ul> </li> <li>■ File for system integration - If using fieldbuses, upload device drivers for system integration from the measuring device: PROFIBUS DP: GSD file</li> </ul> |

| Functions | Meaning   |
|-----------|---|
| Network   | Configuration and checking of all the parameters required for establishing the connection to the measuring device: <ul style="list-style-type: none"> <li>▪ Network settings (e.g. IP address, MAC address)</li> <li>▪ Device information (e.g. serial number, firmware version)</li> </ul> |
| Logout    | End the operation and call up the login page  |

### Navigation area

The menus, the associated submenus and parameters can be selected in the navigation area.

### Working area

Depending on the selected function and the related submenus, various actions can be performed in this area:

- Configuring parameters
- Reading measured values
- Calling up help text
- Starting an upload/download

## 8.4.6 Disabling the Web server

The Web server of the measuring device can be switched on and off as required using the **Web server functionality** parameter.

### Navigation

"Expert" menu → Communication → Web server

### Parameter overview with brief description

| Parameter                | Description                       | Selection   |
|--------------------------|-----------------------------------|---|
| Web server functionality | Switch the Web server on and off. | <ul style="list-style-type: none"> <li>▪ Off</li> <li>▪ On</li> </ul> |

### Function scope of the "Web server functionality" parameter

| Option | Description   |
|--------|---|
| Off    | <ul style="list-style-type: none"> <li>▪ The Web server is completely disabled.</li> <li>▪ Port 80 is locked.</li> </ul>  |
| On     | <ul style="list-style-type: none"> <li>▪ The complete Web server functionality is available.</li> <li>▪ JavaScript is used.</li> <li>▪ The password is transferred in an encrypted state.</li> <li>▪ Any change to the password is also transferred in an encrypted state.</li> </ul> |

### Enabling the Web server

If the Web server is disabled it can only be re-enabled with the **Web server functionality** parameter via the following operating options:

- Via Bedientool "FieldCare"
- Via "DeviceCare" operating tool

## 8.4.7 Logging out



Before logging out, perform a data backup via the **Data management** function (upload configuration from device) if necessary.


1. Select the **Logout** entry in the function row.  
↳ The home page with the Login box appears.
2. Close the Web browser.
3. If no longer needed:  
Reset the modified properties of the Internet protocol (TCP/IP) → 40.

## 8.5 Access to the operating menu via the operating tool

### 8.5.1 Connecting the operating tool

#### Via PROFIBUS DP network

This communication interface is available in device versions with PROFIBUS DP.




A0020903

15 Options for remote operation via PROFIBUS DP network

- 1 Automation system
- 2 Computer with PROFIBUS network card
- 3 PROFIBUS DP network
- 4 Measuring device

#### Via service interface (CDI-RJ45)

*PROFIBUS DP*

16 Connection for order code for "Output", option L: PROFIBUS DP

- 1 Service interface (CDI-RJ45) of the measuring device with access to the integrated web server
- 2 Computer with web browser (e.g. Internet Explorer) for accessing the integrated web server or with 'FieldCare' operating tool with COM DTM "CDI Communication TCP/IP"
- 3 Standard Ethernet connecting cable with RJ45 plug

## 8.5.2 FieldCare

### Function range


FDT-based (Field Device Technology) plant asset management tool from Endress+Hauser. It can configure all smart field units in a system and helps you manage them. By using the status information, it is also a simple but effective way of checking their status and condition.

Access is via:  
CDI-RJ45 service interface

Typical functions:

- Transmitter parameter configuration
- Loading and saving of device data (upload/download)
- Documentation of the measuring point
- Visualization of the measured value memory (line recorder) and event logbook



- Operating Instructions BA00027S
- Operating Instructions BA00059S

 Source for device description files →  47


### Establishing a connection

1. Start FieldCare and launch the project.
2. In the network: Add a device.
  - ↳ The **Add device** window opens.
3. Select the **CDI Communication TCP/IP** option from the list and press **OK** to confirm.
4. Right-click **CDI Communication TCP/IP** and select the **Add device** option in the context menu that opens.
5. Select the desired device from the list and press **OK** to confirm.
  - ↳ The **CDI Communication TCP/IP (Configuration)** window opens.
6. Enter the device address in the **IP address** field and press **Enter** to confirm: 192.168.1.212 (factory setting); if the IP address is not known .


7. Establish the online connection to the device.

-  Operating Instructions BA00027S
-  Operating Instructions BA00059S

User interface



A0021051-EN

- 1 Header
- 2 Picture of device
- 3 Device name
- 4 Device tag
- 5 Status area with status signal →  93
- 6 Display area for current measured values
- 7 Editing toolbar with additional functions such as save/load, event list and create documentation
- 8 Navigation area with operating menu structure
- 9 Work area
- 10 Action area
- 11 Status area



### 8.5.3 DeviceCare

#### Function range

Tool for connecting and configuring Endress+Hauser field devices.

The fastest way to configure Endress+Hauser field devices is with the dedicated "DeviceCare" tool. Together with the device type managers (DTMs) it presents a convenient, comprehensive solution.

-  Innovation brochure IN01047S


-  Source for device description files →  47

## 9 System integration

### 9.1 Overview of device description files

#### 9.1.1 Current version data for the device

|                                  |          |   |
|----------------------------------|----------|---|
| Firmware version                 | 01.01.zz | <ul style="list-style-type: none"> <li>▪ On the title page of the manual</li> <li>▪ On the transmitter nameplate</li> <li>▪ Parameter: <b>Firmware version</b> parameter<br/>Diagnostics → Device information → Firmware version</li> </ul> |
| Release date of firmware version | 10.2014  | ---   |
| Manufacturer ID                  | 0x11     | Parameter: <b>Manufacturer ID</b> parameter<br>Diagnostics → Device information → Manufacturer ID   |
| Device type ID                   | 0x1561   | Parameter: <b>Device type</b> parameter<br>Diagnostics → Device information → Device type   |
| Profile version                  | 3.02     | ---   |

 For an overview of the various firmware versions for the device

#### 9.1.2 Operating tools

The suitable device description file for the individual operating tools is listed in the table below, along with information on where the file can be acquired.

| Operating tool via PROFIBUS protocol | Sources for obtaining device descriptions   |
|--------------------------------------|---|
| FieldCare                            | <ul style="list-style-type: none"> <li>▪ <a href="http://www.endress.com">www.endress.com</a> → Downloads area</li> <li>▪ USB stick (contact Endress+Hauser)</li> <li>▪ DVD (contact Endress+Hauser)</li> </ul> |
| DeviceCare                           | <ul style="list-style-type: none"> <li>▪ <a href="http://www.endress.com">www.endress.com</a> → Downloads area</li> <li>▪ CD-ROM (contact Endress+Hauser)</li> <li>▪ DVD (contact Endress+Hauser)</li> </ul>    |


## 9.2 Device master file (GSD)

In order to integrate field devices into a bus system, the PROFIBUS system needs a description of the device parameters, such as output data, input data, data format, data volume and supported transmission rate.

These data are available in the device master file (GSD) which is provided to the PROFIBUS master when the communication system is commissioned. In addition device bit maps, which appear as icons in the network structure, can also be integrated.

With the Profile 3.02 device master file (GSD) it is possible to exchange field devices made by different manufacturers without having to reconfigure.

Generally speaking, it is possible to use two different GSDs with Profile 3.02 and higher: the manufacturer-specific GSD and the Profile GSD.

-  Before configuring, the user must decide which GSD should be used to operate the system.
  - The setting can be changed via a class 2 master.

### 9.2.1 Manufacturer-specific GSD

This GSD guarantees the unrestricted functionality of the measuring device. Device-specific process parameters and functions are therefore available.

| Manufacturer-specific GSD | ID number | File name    |
|---------------------------|-----------|--------------|
| PROFIBUS DP               | 0x1561    | EH3x1561.gsd |

The fact that the manufacturer-specific GSD should be used is specified in the **Ident number selector** parameter by selecting the **Manufacturer** option.



Where to acquire the manufacturer-specific GSD:

[www.endress.com](http://www.endress.com) → Download Area

### 9.2.2 Profile GSD

Differs in terms of the number of Analog Input blocks (AI) and the measured values. If a system is configured with a Profile GSD, it is possible to exchange devices made by different manufacturers. However, it is essential to ensure that the order of the cyclic process values is correct.

| ID number | Supported blocks  | Supported channels  |
|-----------|---|---|
| 0x9740    | <ul style="list-style-type: none"> <li>▪ 1 Analog Input</li> <li>▪ 1 Totalizer</li> </ul> | <ul style="list-style-type: none"> <li>▪ Channel Analog Input: volume flow</li> <li>▪ Channel totalizer: volume flow</li> </ul>   |
| 0x9741    | <ul style="list-style-type: none"> <li>▪ 2 Analog Input</li> <li>▪ 1 Totalizer</li> </ul> | <ul style="list-style-type: none"> <li>▪ Channel Analog Input 1: volume flow</li> <li>▪ Channel Analog Input 2: mass flow</li> <li>▪ Channel totalizer: volume flow</li> </ul>  |
| 0x9742    | <ul style="list-style-type: none"> <li>▪ 3 Analog Input</li> <li>▪ 1 Totalizer</li> </ul> | <ul style="list-style-type: none"> <li>▪ Channel Analog Input 1: volume flow</li> <li>▪ Channel Analog Input 2: mass flow</li> <li>▪ Channel Analog Input 3: corrected volume flow</li> <li>▪ Channel totalizer: volume flow</li> </ul> |

The Profile GSD that is to be used is specified in the **Ident number selector** parameter by selecting the **Profile 0x9740** option, **Profile 0x9741** option or **Profile 0x9742** option.



## 9.3 Integration into a PROFIBUS network

### 9.3.1 Block model

- Physical block
- Function blocks
  - Analog Input Block
  - Analog Output Block
  - Discrete Input Block
  - Discrete Output Block
  - Totalizer Block



Technical values for the individual blocks → 139

### 9.3.2 Assignment of the measured values in the function blocks

The input value of a function block is defined via the CHANNEL parameter.

#### Analog Input 1 to 8 (AI)

| Channel | Measured variable                           |
|---------|---|
| 33122   | Volume flow                                 |
| 32961   | Mass flow                                   |
| 33093   | Corrected volume flow                       |
| 708     | Flow velocity                               |
| 901     | Target mass flow                            |
| 793     | Carrier mass flow                           |
| 32850   | Density                                     |
| 33092   | Reference density                           |
| 794     | Concentration                               |
| 1039    | Dynamic viscosity                           |
| 1032    | Kinematic viscosity                         |
| 904     | Temperature compensated dynamic viscosity   |
| 905     | Temperature compensated kinematic viscosity |
| 33101   | Temperature                                 |
| 263     | Carrier pipe temperature                    |
| 1042    | Electronics temperature                     |
| 1066    | Oscillation frequency 0                     |
| 1067    | Oscillation frequency 1                     |
| 1124    | Oscillation amplitude 0                     |
| 876     | Oscillation amplitude 1                     |
| 1062    | Frequency fluctuation 0                     |
| 1063    | Frequency fluctuation 1                     |
| 1117    | Oscillation damping 0                       |
| 1118    | Oscillation damping 1                       |
| 1054    | Tube damping fluctuation 0                  |
| 1055    | Tube damping fluctuation 1                  |
| 1125    | Signal asymmetry                            |

| Channel | Measured variable |
|---------|-------------------|
| 1056    | Exciter current 0 |
| 1057    | Exciter current 1 |
| 1440    | HBSI              |

### Analog Output 1 to 3 (AO)

| Channel | Measured variable               |
|---------|---------------------------------|
| 306     | External pressure <sup>1)</sup> |
| 307     | External temperature            |
| 488     | External reference density      |

1) The compensation variables must be transmitted to the device in the SI basic unit.

The measured variable is accessed via Expert → Sensor → External compensation

### Digital Input 1 to 2 (DI)

| Channel | Signal               |
|---------|----------------------|
| 894     | Empty pipe detection |
| 895     | Low flow cut off     |
| 1430    | Verification status  |

### Digital Output 1 to 3 (DO)

| Channel | Signal                 |
|---------|------------------------|
| 890     | Zero adjustment        |
| 891     | Flow override          |
| 1429    | Start the verification |

### Totalizer 1 to 3 (TOT)

| Channel | Signal                |
|---------|-----------------------|
| 33122   | Volume flow           |
| 32961   | Mass flow             |
| 33093   | Corrected volume flow |
| 901     | Target mass flow      |
| 793     | Carrier mass flow     |

### 9.3.3 Totalizer control SET\_TOT

| Value | Behavior      |
|-------|---------------|
| 0     | Totalize      |
| 1     | Reset + hold  |
| 2     | Preset + hold |

## 9.4 Cyclic data transmission

Cyclic data transmission when using the device master file (GSD).

### 9.4.1 Block model

The block model shows which input and output data the measuring device makes available for cyclic data exchange. Cyclic data exchange takes place with a PROFIBUS master (Class 1), e.g. a control system.

| Measuring device        |                             |   |                                | Control system          |
|-------------------------|-----------------------------|---|--------------------------------|-------------------------|
| <b>Transducer Block</b> | Analog Input block 1 to 8   | → | 📄 52                           | Output value AI →       |
|                         |                             |   |                                | Output value TOTAL →    |
|                         | Totalizer block 1 to 3      | → | 📄 53                           | Controller SETTOT ←     |
|                         |                             |   |                                | Configuration MODETOT ← |
|                         | Analog Output block 1 to 3  | → | 📄 54                           | Input values AO ←       |
|                         | Discrete Input block 1 to 2 | → | 📄 55                           | Output values DI →      |
|                         |                             |   | Discrete Output block 1 to 3 ← |                         |
|                         |                             |   |                                | <b>PROFIBUS DP</b>      |

### Defined order of modules

The measuring device works as a modular PROFIBUS slave. In contrast to a compact slave, a modular slave has a variable design and consists of several individual modules. The device master file (GSD) contains a description of the individual modules (input and output data) along with their individual properties.

The modules are permanently assigned to the slots, i.e. when configuring the modules, the order and the arrangement of the modules must be respected.

| Slot    | Module  | Function block               |
|---------|---|------------------------------|
| 1...8   | AI  | Analog Input block 1 to 8    |
| 9       | TOTAL or<br>SETTOT_TOTAL or<br>SETTOT_MODETOT_TOTAL | Totalizer block 1            |
| 10      |   | Totalizer block 2            |
| 11      |   | Totalizer block 3            |
| 12...14 | AO  | Analog Output block 1 to 3   |
| 15...16 | DI  | Discrete Input block 1 to 2  |
| 17...19 | DO  | Discrete Output block 1 to 3 |

To optimize the data throughput rate of the PROFIBUS network, it is advisable to only configure modules that are processed in the PROFIBUS master system. If this results in gaps between the configured modules, these gaps must be assigned to the EMPTY\_MODULE.

### 9.4.2 Description of the modules

The data structure is described from the perspective of the PROFIBUS master:

- Input data: Are sent from the measuring device to the PROFIBUS master.
- Output data: Are sent from the PROFIBUS master to the measuring device.

### AI module (Analog Input)

Transmit an input variable from the measuring device to the PROFIBUS master (Class 1).

The selected input variable including its status is cyclically transmitted to the PROFIBUS master (Class 1) via the AI module. The input variable is depicted in the first four bytes in the form of a floating point number as per the IEEE 754 standard. The fifth byte contains standardized status information pertaining to the input variable.

Eight Analog Input blocks are available (slot 1 to 8).

*Selection: input variable*

The input variable can be specified using the CHANNEL parameter.

| CHANNEL | Input variable                         |
|---------|--|
| 32961   | Mass flow                              |
| 33122   | Volume flow                            |
| 33093   | Corrected volume flow                  |
| 708     | Flow velocity                          |
| 32850   | Density                                |
| 33092   | Reference density                      |
| 33101   | Temperature                            |
| 1042    | Electronics temperature                |
| 901     | Target mass flow <sup>1)</sup>         |
| 793     | Carrier mass flow <sup>1)</sup>        |
| 794     | Concentration <sup>1)</sup>            |
| 263     | Carrier tube temperature <sup>2)</sup> |

1) Only available with the Concentration application package

2) Only available with the Heartbeat Verification application package

*Factory setting*

| Function block | Factory setting       |
|----------------|-----------------------|
| AI 1           | Mass flow             |
| AI 2           | Density               |
| AI 3           | Temperature           |
| AI 4           | Volume flow           |
| AI 5           | Corrected volume flow |
| AI 6           | Reference density     |
| AI 7           | Mass flow             |
| AI 8           | Mass flow             |

*Data structure*

*Input data of Analog Input*

| Byte 1   | Byte 2 | Byte 3 | Byte 4 | Byte 5 |
|--|--------|--------|--------|--------|
| Measured value: floating point number (IEEE 754) |        |        |        | Status |

**TOTAL module**

Transmit a totalizer value from the measuring device to the PROFIBUS master (Class 1).

A selected totalizer value, along with the status, is cyclically transmitted to a PROFIBUS Master (Class 1) via the TOTAL module. The totalizer value is depicted in the first four bytes in the form of a floating point number as per the IEEE 754 standard. The fifth byte contains standardized status information pertaining to the totalizer value.

Three Totalizer blocks are available (slot 9 to 11).

*Selection: totalizer value*

The totalizer value can be specified using the CHANNEL parameter.

| CHANNEL | Input variable                       |
|---------|--------------------------------------|
| 32961   | Mass flow                            |
| 33122   | Volume flow                          |
| 33093   | Corrected volume flow                |
| 901     | Target fluid mass flow <sup>1)</sup> |
| 793     | Carrier mass flow <sup>1)</sup>      |

1) Only available with the "Concentration" application package

*Factory setting*

| Function block       | Factory setting: TOTAL |
|----------------------|------------------------|
| Totalizer 1, 2 and 3 | Mass flow              |

*Data structure*

*Input data of TOTAL*

| Byte 1   | Byte 2 | Byte 3 | Byte 4 | Byte 5 |
|--|--------|--------|--------|--------|
| Measured value: floating point number (IEEE 754) |        |        |        | Status |

**SETTOT\_TOTAL module**

The module combination consists of the SET\_TOT and TOTAL functions:

- SETTOT: Control the totalizers via the PROFIBUS master.
- TOTAL: Transmit totalizer value incl. status to PROFIBUS master.

Three Totalizer blocks are available (slot 9 to 11).

*Selection: control totalizer*

| Value SETTOT | Control totalizer |
|--------------|-------------------|
| 0            | Totalize          |
| 1            | Reset + hold      |
| 2            | Preset + hold     |

*Factory setting*

| Function block       | Factory setting: Value SETTOT (meaning) |
|----------------------|---|
| Totalizer 1, 2 and 3 | 0 (totalizing)                          |

*Data structure**Output data of SETTOT*

| Byte 1             |
|--------------------|
| Control variable 1 |

*Input data of TOTAL*

| Byte 1   | Byte 2 | Byte 3 | Byte 4 | Byte 5 |
|--|--------|--------|--------|--------|
| Measured value: floating point number (IEEE 754) |        |        |        | Status |

**SETTOT\_MODETOT\_TOTAL module**

The module combination consists of the SETTOT, MODETOT and TOTAL functions:

- SETTOT: Control the totalizers via the PROFIBUS master.
- MODETOT: Configure the totalizers via the PROFIBUS master.
- TOTAL: Transmit totalizer value, along with the status, to the PROFIBUS master.

Three Totalizer blocks are available (slot 9 to 11).

*Selection: totalizer configuration*

| MODETOT value | Totalizer configuration   |
|---------------|---------------------------|
| 0             | Balancing                 |
| 1             | Balance the positive flow |
| 2             | Balance the negative flow |
| 3             | Stop totalizing           |

*Factory setting*

| Function block       | Factory setting: Value MODETOT (meaning) |
|----------------------|--|
| Totalizer 1, 2 and 3 | 0 (balancing)                            |

*Data structure**Output data of SETTOT and MODETOT*

| Byte 1                     | Byte 2                      |
|----------------------------|-----------------------------|
| Control variable 1: SETTOT | Control variable 2: MODETOT |

*Input data of TOTAL*

| Byte 1   | Byte 2 | Byte 3 | Byte 4 | Byte 5 |
|--|--------|--------|--------|--------|
| Measured value: floating point number (IEEE 754) |        |        |        | Status |

**AO module (Analog Output)**

Transmit a compensation value from the PROFIBUS master (class 1) to the measuring device.

A compensation value, including the status, is cyclically transmitted from the PROFIBUS master (class 1) to the measuring device via the AO module. The compensation value is depicted in the first four bytes in the form of a floating point number as per the IEEE 754

standard. The fifth byte contains standardized status information pertaining to the compensation value.


Three Analog Output blocks are available (slot 12 to 14).

*Assigned compensation values*

A compensation value is permanently assigned to the individual Analog Output blocks.

| CHANNEL | Function block | Compensation value                 |
|---------|----------------|------------------------------------|
| 306     | AO 1           | External pressure <sup>1)</sup>    |
| 307     | AO 2           | External temperature <sup>1)</sup> |
| 488     | AO 3           | External reference density         |

1) The compensation values must be transmitted to the device in the SI basic unit

 The selection is made via: Expert → Sensor → External compensation

*Data structure*

*Output data of Analog Output*

| Byte 1   | Byte 2 | Byte 3 | Byte 4 | Byte 5               |
|--|--------|--------|--------|----------------------|
| Measured value: floating point number (IEEE 754) |        |        |        | Status <sup>1)</sup> |

1) Status coding

**DI module (Discrete Input)**

Transmit discrete input values from the measuring device to the PROFIBUS master (class 1). Discrete input values are used by the measuring device to transmit the state of device functions to the PROFIBUS master (class 1).

The DI module cyclically transmits the discrete input value, including the status, to the PROFIBUS master (class 1). The discrete input value is depicted in the first byte. The second byte contains standardized status information pertaining to the input value.

Two Discrete Input blocks are available (slot 15 to 16).

*Selection: device function*

The device function can be specified using the CHANNEL parameter.

| CHANNEL | Device function                   | Factory setting: Status (meaning)  |
|---------|-----------------------------------|--|
| 893     | Status switch output              | <ul style="list-style-type: none"> <li>■ 0 (device function not active)</li> <li>■ 1 (device function active)</li> </ul> |
| 894     | Empty pipe detection              |  |
| 895     | Low flow cut off                  |  |
| 1430    | Verification status <sup>1)</sup> |  |

1) Only available with the Heartbeat Verification application package

*Factory setting*

| Function block | Factory setting      |
|----------------|----------------------|
| DI 1           | Empty pipe detection |
| DI 2           | Low flow cut off     |

*Data structure**Input data of Discrete Input*

| Byte 1   | Byte 2 |
|----------|--------|
| Discrete | Status |

**DO module (Discrete Output)**

Transmit discrete output values from the PROFIBUS master (class 1) to the measuring device. Discrete output values are used by the PROFIBUS master (class 1) to enable and disable device functions.

The DO module cyclically transmits the discrete output value, including the status, to the measuring device. The discrete output value is depicted in the first byte. The second byte contains standardized status information pertaining to the output value.

Three Discrete Output blocks are available (slot 17 to 19).

*Assigned device functions*

A device function is permanently assigned to the individual Discrete Output blocks.

| CHANNEL | Function block | Device function                  | Values: control (meaning)   |
|---------|----------------|----------------------------------|---|
| 891     | DO 1           | Flow override                    | <ul style="list-style-type: none"> <li>■ 0 (disable device function)</li> <li>■ 1 (enable device function)</li> </ul> |
| 890     | DO 2           | Zero adjustment                  |   |
| 1429    | DO 3           | Start verification <sup>1)</sup> |   |

1) Only available with the Heartbeat Verification application package

*Data structure**Output data of Discrete Output*

| Byte 1   | Byte 2 |
|----------|--------|
| Discrete | Status |

**EMPTY\_MODULE module**

This module is used to assign empty spaces arising from modules not being used in the slots .

The measuring device works as a modular PROFIBUS slave. In contrast to a compact slave, a modular PROFIBUS slave has a variable design and consists of several individual modules. The GSD file contains a description of the individual modules along with their individual properties.



The modules are permanently assigned to the slots. When configuring the modules, it is absolutely essential to observe the sequence/arrangement of the modules. Any gaps between the configured modules must be filled with the EMPTY\_MODULE.





## 10 Commissioning

### 10.1 Post-mounting and post-connection check

Before commissioning the device:

- ▶ Make sure that the post-installation and post-connection checks have been performed successfully.
- Checklist for "Post-installation" check →  24
- Checklist for "Post-connection" check →  32

### 10.2 Connecting via FieldCare

- For connecting FieldCare
- For connecting via FieldCare →  45
- For user interface of FieldCare →  46


### 10.3 Setting the operating language









Factory setting: English or ordered local language

The operating language can be set in FieldCare, DeviceCare or via the Web server:  
Operation → Display language

### 10.4 Configuring the measuring instrument



The **Setup** menu with its submenus contains all the parameters needed for standard operation.



| Menu Item                         | Page Number  |
|-----------------------------------|--|
| Device tag                        | →  58 |
| ▶ System units                    | →  58 |
| ▶ Medium selection                | →  61 |
| ▶ Communication                   | →  62 |
| ▶ Analog inputs                   | →  63 |
| ▶ Low flow cut off                | →  64 |
| ▶ Partially filled pipe detection | →  65 |
| ▶ Advanced setup                  | →  66 |

### 10.4.1 Defining the tag name

To enable fast identification of the measuring point within the system, you can enter a unique designation using the **Device tag** parameter and thus change the factory setting.

 Enter the tag name in the "FieldCare" operating tool →  46

#### Navigation


"Setup" menu → Device tag

#### Parameter overview with brief description

| Parameter  | Description                             | User entry   |
|------------|---|--|
| Device tag | Enter the name for the measuring point. | Max. 32 characters, such as letters, numbers or special characters (e.g. @, %, /). |









### 10.4.2 Setting the system units

In the **System units** submenu the units of all the measured values can be set.

 The number of submenus and parameters can vary depending on the device version. Certain submenus and parameters in these submenus are not described in the Operating Instructions. Instead a description is provided in the Special Documentation for the device ("Supplementary documentation").



#### Navigation

"Setup" menu → Advanced setup → System units

| ► System units             |  |
|----------------------------|--|
| Mass flow unit             | →  59 |
| Mass unit                  | →  59 |
| Volume flow unit           | →  59 |
| Volume unit                | →  59 |
| Corrected volume flow unit | →  59 |
| Corrected volume unit      | →  59 |
| Density unit               | →  59 |
| Reference density unit     | →  59 |
| Temperature unit           | →  60 |
| Pressure unit              | →  60 |

## Parameter overview with brief description

| Parameter                  | Description  | Selection        | Factory setting   |
|----------------------------|--|------------------|---|
| Mass flow unit             | Select mass flow unit.<br><i>Effect</i><br>The selected unit applies to:<br><ul style="list-style-type: none"> <li>▪ Output</li> <li>▪ Low flow cut off</li> <li>▪ Simulation process variable</li> </ul>                      | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ kg/h</li> <li>▪ lb/min</li> </ul>   |
| Mass unit                  | Select mass unit.  | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ kg</li> <li>▪ lb</li> </ul>   |
| Volume flow unit           | Select volume flow unit.<br><i>Effect</i><br>The selected unit applies to:<br><ul style="list-style-type: none"> <li>▪ Output</li> <li>▪ Low flow cut off</li> <li>▪ Simulation process variable</li> </ul>                    | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ l/h</li> <li>▪ gal/min (us)</li> </ul>                                    |
| Volume unit                | Select volume unit.  | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ l (DN &gt; 150 (6"): m<sup>3</sup> option)</li> <li>▪ gal (us)</li> </ul> |
| Corrected volume flow unit | Select corrected volume flow unit.<br><i>Effect</i><br>The selected unit applies to:<br><b>Corrected volume flow</b> parameter<br>(→ ⓘ 80)   | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ NI/h</li> <li>▪ Sft<sup>3</sup>/min</li> </ul>                            |
| Corrected volume unit      | Select corrected volume unit.  | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ NI</li> <li>▪ Sft<sup>3</sup></li> </ul>                                  |
| Density unit               | Select density unit.<br><i>Effect</i><br>The selected unit applies to:<br><ul style="list-style-type: none"> <li>▪ Output</li> <li>▪ Simulation process variable</li> <li>▪ Density adjustment (<b>Expert</b> menu)</li> </ul> | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ kg/l</li> <li>▪ lb/ft<sup>3</sup></li> </ul>                              |
| Reference density unit     | Select reference density unit.   | Unit choose list | Country-specific<br><ul style="list-style-type: none"> <li>▪ kg/NI</li> <li>▪ lb/Sft<sup>3</sup></li> </ul>                             |
| Density 2 unit             | Select second density unit.  | Unit choose list | Country-specific:<br><ul style="list-style-type: none"> <li>▪ kg/l</li> <li>▪ lb/ft<sup>3</sup></li> </ul>                              |


| Parameter        | Description   | Selection        | Factory setting   |
|------------------|---|------------------|---|
| Temperature unit | <p>Select temperature unit.</p> <p><i>Effect</i></p> <p>The selected unit applies to:</p> <ul style="list-style-type: none"> <li>▪ <b>Electronic temperature</b> parameter (6053)</li> <li>▪ <b>Maximum value</b> parameter (6051)</li> <li>▪ <b>Minimum value</b> parameter (6052)</li> <li>▪ <b>Maximum value</b> parameter (6108)</li> <li>▪ <b>Minimum value</b> parameter (6109)</li> <li>▪ <b>Maximum value</b> parameter (6029)</li> <li>▪ <b>Minimum value</b> parameter (6030)</li> <li>▪ <b>Reference temperature</b> parameter (1816)</li> <li>▪ <b>Temperature</b> parameter</li> </ul> | Unit choose list | <p>Country-specific:</p> <ul style="list-style-type: none"> <li>▪ °C</li> <li>▪ °F</li> </ul>       |
| Pressure unit    | <p>Select process pressure unit.</p> <p><i>Effect</i></p> <p>The unit is taken from:</p> <ul style="list-style-type: none"> <li>▪ <b>Pressure value</b> parameter (→  62)</li> <li>▪ <b>External pressure</b> parameter (→  62)</li> <li>▪ Pressure value</li> </ul>  | Unit choose list | <p>Country-specific:</p> <ul style="list-style-type: none"> <li>▪ bar a</li> <li>▪ psi a</li> </ul> |

### 10.4.3 Selecting and setting the medium

The **Select medium** wizard submenu contains parameters that must be configured in order to select and set the medium.

#### Navigation

"Setup" menu → Medium selection



#### Parameter overview with brief description

| Parameter       | Prerequisite   | Description  | Selection / User entry   |
|-----------------|--|--|--|
| Select medium   | –  | Use this function to select the type of medium: "Gas" or "Liquid". Select the "Other" option in exceptional cases in order to enter the properties of the medium manually (e.g. for highly compressive liquids such as sulfuric acid). | <ul style="list-style-type: none"> <li>■ Liquid</li> <li>■ Gas</li> </ul>  |
| Select gas type | In the <b>Medium selection</b> submenu, the <b>Gas</b> option is selected. | Select measured gas type.  | <ul style="list-style-type: none"> <li>■ Air</li> <li>■ Ammonia NH3</li> <li>■ Argon Ar</li> <li>■ Sulfur hexafluoride SF6</li> <li>■ Oxygen O2</li> <li>■ Ozone O3</li> <li>■ Nitrogen oxide NOx</li> <li>■ Nitrogen N2</li> <li>■ Nitrous oxide N2O</li> <li>■ Methane CH4</li> <li>■ Hydrogen H2</li> <li>■ Helium He</li> <li>■ Hydrogen chloride HCl</li> <li>■ Hydrogen sulfide H2S</li> <li>■ Ethylene C2H4</li> <li>■ Carbon dioxide CO2</li> <li>■ Carbon monoxide CO</li> <li>■ Chlorine Cl2</li> <li>■ Butane C4H10</li> <li>■ Propane C3H8</li> <li>■ Propylene C3H6</li> <li>■ Ethane C2H6</li> <li>■ Others</li> </ul> |

| Parameter                              | Prerequisite   | Description  | Selection / User entry   |
|--|--|--|--|
| Reference sound velocity               | In the <b>Select gas type</b> parameter, the <b>Others</b> option is selected.   | Enter sound velocity of gas at 0 °C (32 °F).               | 1 to 99 999.9999 m/s   |
| Temperature coefficient sound velocity | In the <b>Select gas type</b> parameter, the <b>Others</b> option is selected.   | Enter temperature coefficient for the gas sound velocity.  | Positive floating-point number   |
| Pressure compensation                  | –  | Select pressure compensation type.                         | <ul style="list-style-type: none"> <li>■ Off</li> <li>■ Fixed value</li> <li>■ External value</li> </ul> |
| Pressure value                         | In the <b>Pressure compensation</b> parameter, the <b>Fixed value</b> option or the <b>Current input 1...n</b> option is selected. | Enter process pressure to be used for pressure correction. | Positive floating-point number   |
| External pressure                      | In the <b>Pressure compensation</b> parameter, the <b>External value</b> option is selected.                                       |  |  |

#### 10.4.4 Configuring communication interface

The **Communication** submenu guides you systematically through all the parameters that have to be configured for selecting and setting the communication interface.

##### Navigation

"Setup" menu → Communication

▶ Communication

→ 62

##### Parameter overview with brief description


| Parameter      | Description           | User entry |
|----------------|-----------------------|------------|
| Device address | Enter device address. | 0 to 126   |

### 10.4.5 Configuration of the Analog Inputs

The **Analog inputs** submenu guides the user systematically to the individual **Analog input 1 to n** submenu. From here you get to the parameters of the individual analog input.

#### Navigation

"Setup" menu → Analog inputs



#### Parameter overview with brief description

| Parameter       | Prerequisite   | Description  | Selection / User entry  |
|-----------------|--|--|---|
| Channel         | –  | Select the process variable.   | <ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> <li>■ Density</li> <li>■ Reference density</li> <li>■ Concentration *</li> <li>■ Temperature</li> <li>■ Electronic temperature</li> <li>■ Oscillation frequency 0</li> <li>■ Oscillation amplitude 0 *</li> <li>■ Frequency fluctuation 0</li> <li>■ Oscillation damping 0</li> <li>■ Tube damping fluctuation 0</li> <li>■ Signal asymmetry</li> <li>■ Exciter current 0</li> </ul> |
| PV filter time  | –  | Specify the time to suppress signal peaks. During the specified time the Analog Input does not respond to an erratic increase in the process variable. | Positive floating-point number  |
| Fail safe type  | –  | Select the failure mode.   | <ul style="list-style-type: none"> <li>■ Fail safe value</li> <li>■ Fallback value</li> <li>■ Off</li> </ul>  |
| Fail safe value | In <b>Fail safe type</b> parameter, the <b>Fail safe value</b> option is selected. | Specify the values to be output when an error occurs.  | Signed floating-point number  |


\* Visibility depends on order options or device settings

## 10.4.6 Configuring the low flow cut off

The **Low flow cut off** submenu contains the parameters that must be set in order to configure the low flow cut off.

### Navigation

"Setup" menu → Low flow cut off



### Parameter overview with brief description

| Parameter                  | Prerequisite   | Description  | Selection / User entry   | Factory setting                         |
|----------------------------|--|--|--|---|
| Assign process variable    | –  | Select process variable for low flow cut off.                                  | <ul style="list-style-type: none"> <li>■ Off</li> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> </ul> | –                                       |
| On value low flow cutoff   | A process variable is selected in the <b>Assign process variable</b> parameter (→ 64). | Enter on value for low flow cut off.   | Positive floating-point number   | Depends on country and nominal diameter |
| Off value low flow cutoff  | A process variable is selected in the <b>Assign process variable</b> parameter (→ 64). | Enter off value for low flow cut off.  | 0 to 100.0 %   | –                                       |
| Pressure shock suppression | A process variable is selected in the <b>Assign process variable</b> parameter (→ 64). | Enter time frame for signal suppression (= active pressure shock suppression). | 0 to 100 s   | –                                       |




### 10.4.7 Configuring partially filled pipe detection

The **Partially filled pipe detection** submenu contains parameters that have to be set for configuring empty pipe detection.

#### Navigation

"Setup" menu → Partially filled pipe detection




#### Parameter overview with brief description

| Parameter                                | Prerequisite   | Description  | Selection / User entry  | Factory setting   |
|--|--|--|---|---|
| Assign process variable                  | –  | Select process variable for partially filled pipe detection.   | <ul style="list-style-type: none"> <li>■ Off</li> <li>■ Density</li> <li>■ Reference density</li> </ul> | Density   |
| Low value partial filled pipe detection  | A process variable is selected in the <b>Assign process variable</b> parameter (→ ⓘ 65). | Enter lower limit value for deactivating partially filled pipe detection.  | Signed floating-point number  | Depends on country: <ul style="list-style-type: none"> <li>■ 200 kg/m<sup>3</sup></li> <li>■ 12.5 lb/ft<sup>3</sup></li> </ul>    |
| High value partial filled pipe detection | A process variable is selected in the <b>Assign process variable</b> parameter (→ ⓘ 65). | Enter upper limit value for deactivating partially filled pipe detection.  | Signed floating-point number  | Depends on country: <ul style="list-style-type: none"> <li>■ 6 000 kg/m<sup>3</sup></li> <li>■ 374.6 lb/ft<sup>3</sup></li> </ul> |
| Response time part. filled pipe detect.  | A process variable is selected in the <b>Assign process variable</b> parameter (→ ⓘ 65). | Use this function to enter the minimum time (hold time) the signal must be present before diagnostic message S962 "Pipe only partly filled" is triggered in the event of a partially filled or empty measuring pipe. | 0 to 100 s  | –   |


## 10.5 Advanced settings

The **Advanced setup** submenu with its submenus contains parameters for specific settings.

 The number of submenus can vary depending on the device version, e.g. viscosity is available only with the Promass I.

### Navigation

"Setup" menu → Advanced setup



### 10.5.1 Using the parameter to enter the access code

#### Navigation


"Setup" menu → Advanced setup

#### Parameter overview with brief description

| Parameter         | Description  | User entry  |
|-------------------|--|---|
| Enter access code | Enter access code to disable write protection of parameters. | Max. 16-digit character string comprising numbers, letters and special characters |


### 10.5.2 Calculated process variables

The **Calculated values** submenu contains parameters for calculating the corrected volume flow.

 The **Calculated values** submenu is **not** available if one of the following options was selected in the **Petroleum mode** parameter in the "Application package", option **EJ** "Petroleum": **API referenced correction** option, **Net oil & water cut** option or **ASTM D4311** option

**Navigation**


"Setup" menu → Advanced setup → Calculated values



**"Corrected volume flow calculation" submenu**

**Navigation**

"Setup" menu → Advanced setup → Calculated values → Corrected volume flow calculation



**Parameter overview with brief description**

| Parameter                         | Prerequisite   | Description   | Selection / User interface / User entry  | Factory setting |
|-----------------------------------|--|---|--|-----------------|
| Corrected volume flow calculation | –  | Select reference density for calculating the corrected volume flow. | <ul style="list-style-type: none"> <li>■ Fixed reference density</li> <li>■ Calculated reference density</li> <li>■ Reference density by API table 53</li> <li>■ External reference density</li> </ul> | –               |
| External reference density        | In the <b>Corrected volume flow calculation</b> parameter, the <b>External reference density</b> option is selected. | Shows external reference density.                                   | Floating point number with sign  | –               |
| Fixed reference density           | The <b>Fixed reference density</b> option is selected in the <b>Corrected volume flow calculation</b> parameter.     | Enter fixed value for reference density.                            | Positive floating-point number   | –               |


| Parameter                    | Prerequisite  | Description  | Selection / User interface / User entry | Factory setting                           |
|------------------------------|---|--|---|---|
| Reference temperature        | The <b>Calculated reference density</b> option is selected in the <b>Corrected volume flow calculation</b> parameter parameter. | Enter reference temperature for calculating the reference density.   | -273.15 to 99 999 °C                    | Country-specific:<br>■ +20 °C<br>■ +68 °F |
| Linear expansion coefficient | The <b>Calculated reference density</b> option is selected in the <b>Corrected volume flow calculation</b> parameter parameter. | Enter linear, medium-specific expansion coefficient for calculating the reference density.   | Signed floating-point number            | -   |
| Square expansion coefficient | The <b>Calculated reference density</b> option is selected in the <b>Corrected volume flow calculation</b> parameter parameter. | For media with a non-linear expansion pattern: enter the quadratic, medium-specific expansion coefficient for calculating the reference density. | Signed floating-point number            | -   |

### 10.5.3 Carrying out a sensor adjustment

The **Sensor adjustment** submenu contains parameters that pertain to the functionality of the sensor.

#### Navigation


"Setup" menu → Advanced setup → Sensor adjustment



#### Parameter overview with brief description

| Parameter              | Description   | Selection   |
|------------------------|---|---|
| Installation direction | Set sign of flow direction to match the direction of the arrow on the sensor. | <ul style="list-style-type: none"> <li>■ Flow in arrow direction</li> <li>■ Flow against arrow direction</li> </ul> |

#### Density adjustment

 With density adjustment, a high level of accuracy is achieved only at the point of adjustment and at the relevant density and temperature. However, the accuracy of a density adjustment is only ever as good as the quality of the reference measuring data provided. Therefore it is not a substitute for special density calibration.

*Performing density adjustment*

Note the following before performing the adjustment:

- A density adjustment only makes sense if there is little variation in the operating conditions and the density adjustment is performed under the operating conditions.
- The density adjustment scales the internally computed density value with a user-specific slope and offset.
- A 1-point or 2-point density adjustment can be performed.
- For a 2-point density adjustment, there must be a difference of at least 0.2 kg/l between the two target density values.
- The reference media must be gas-free or pressurized so that any gas they contain is compressed.
- The reference density measurements must be performed at the same medium temperature that prevails in the process, as otherwise the density adjustment will not be accurate.
- The correction resulting from the density adjustment can be deleted with the **Restore original** option.

**"1 point adjustment" option**

1. In the **Density adjustment mode** parameter, select the **1 point adjustment** option and confirm.
2. In the **Density setpoint 1** parameter, enter the density value and confirm.
  - ↳ In the **Execute density adjustment** parameter the following options are now available:
    - Ok
    - Measure density 1 option**
    - Restore original
3. Select the **Measure density 1** option and confirm.
4. If 100% was reached in the **Progress** parameter on the display and the **Ok** option is displayed in the **Execute density adjustment** parameter, then confirm.
  - ↳ In the **Execute density adjustment** parameter the following options are now available:
    - Ok
    - Calculate
    - Cancel
5. Select the **Calculate** option and confirm.

If the adjustment was completed successfully, the **Density adjustment factor** parameter and the **Density adjustment offset** parameter and the values calculated for them are shown on the display.

**"2 point adjustment" option**

1. In the **Density adjustment mode** parameter, select the **2 point adjustment** option and confirm.
2. In the **Density setpoint 1** parameter, enter the density value and confirm.
3. In the **Density setpoint 2** parameter, enter the density value and confirm.
  - ↳ In the **Execute density adjustment** parameter the following options are now available:
    - Ok
    - Measure density 1
    - Restore original

4. Select the **Measure density 1** option and confirm.
  - ↳ In the **Execute density adjustment** parameter the following options are now available:
    - Ok
    - Measure density 2
    - Restore original
5. Select the **Measure density 2** option and confirm.
  - ↳ In the **Execute density adjustment** parameter the following options are now available:
    - Ok
    - Calculate
    - Cancel
6. Select the **Calculate** option and confirm.

If the **Density adjust failure** option is displayed in the **Execute density adjustment** parameter, call up the options and select the **Cancel** option. The density adjustment is canceled and can be repeated.

If the adjustment was completed successfully, the **Density adjustment factor** parameter and the **Density adjustment offset** parameter and the values calculated for them are shown on the display.

#### Navigation

"Expert" menu → Sensor → Sensor adjustment → Density adjustment


| ► Density adjustment       |      |
|----------------------------|------|
| Density adjustment mode    | → 70 |
| Density setpoint 1         | → 70 |
| Density setpoint 2         | → 71 |
| Execute density adjustment | → 71 |
| Progress                   | → 71 |
| Density adjustment factor  | → 71 |
| Density adjustment offset  | → 71 |

#### Parameter overview with brief description

| Parameter               | Prerequisite | Description | Selection / User entry / User interface  | Factory setting |
|-------------------------|--------------|-------------|--|-----------------|
| Density adjustment mode | -            |             | <ul style="list-style-type: none"> <li>▪ 1 point adjustment</li> <li>▪ 2 point adjustment</li> </ul> | -               |
| Density setpoint 1      | -            |             | The entry depends on the unit selected in the <b>Density unit</b> parameter (0555).                  | -               |

| Parameter                  | Prerequisite   | Description                        | Selection / User entry / User interface   | Factory setting |
|----------------------------|--|------------------------------------|---|-----------------|
| Density setpoint 2         | In the <b>Density adjustment mode</b> parameter, the <b>2 point adjustment</b> option is selected. |                                    | The entry depends on the unit selected in the <b>Density unit</b> parameter (0555).   | –               |
| Execute density adjustment | –  |                                    | <ul style="list-style-type: none"> <li>■ Cancel</li> <li>■ Busy</li> <li>■ Ok</li> <li>■ Density adjust failure</li> <li>■ Measure density 1</li> <li>■ Measure density 2</li> <li>■ Calculate</li> <li>■ Restore original</li> </ul> | –               |
| Progress                   | –  | Shows the progress of the process. | 0 to 100 %  | –               |
| Density adjustment factor  | –  |                                    | Signed floating-point number  | –               |
| Density adjustment offset  | –  |                                    | Signed floating-point number  | –               |

### Zero verification and zero adjustment

All measuring instruments are calibrated in accordance with state-of-the-art technology. Calibration takes place under reference conditions →  14.1. Therefore, a zero adjustment in the field is generally not required.

Experience shows that zero adjustment is advisable only in special cases:

- To achieve maximum measurement accuracy even with low flow rates.
- Under extreme process or operating conditions (e.g. very high process temperatures or very high-viscosity fluids).
- For gas applications with low pressure



To achieve the highest possible measurement accuracy at low flow rates, the installation must protect the sensor from mechanical stresses during operation.

To get a representative zero point, ensure that:

- any flow in the device is prevented during the adjustment
- the process conditions (e.g. pressure, temperature) are stable and representative



Zero verification and zero adjustment cannot be performed if the following process conditions are present:

- Gas pockets  
Ensure that the system has been sufficiently flushed with the medium. Repeat flushing can help to eliminate gas pockets
- Thermal circulation  
In the event of temperature differences (e.g. between the measuring tube inlet and outlet section), induced flow can occur even if the valves are closed due to thermal circulation in the device
- Leaks at the valves  
If the valves are not leak-tight, flow is not sufficiently prevented when determining the zero point

If these conditions cannot be avoided, it is advisable to keep the factory setting for the zero point.

**Navigation**

"Setup" menu → Advanced setup → Sensor adjustment → Zero point adjustment

|                                |  |
|--------------------------------|--|
| <b>► Zero point adjustment</b> |  |
| Zero point adjustment control  | →  72 |
| Progress                       | →  72 |

**Parameter overview with brief description**






| Parameter                     | Description                        | Selection / User interface   | Factory setting |
|-------------------------------|------------------------------------|--|-----------------|
| Zero point adjustment control | Start zero point adjustment.       | <ul style="list-style-type: none"> <li>■ Cancel</li> <li>■ Busy</li> <li>■ Zero point adjust failure</li> <li>■ Start</li> </ul> | –               |
| Progress                      | Shows the progress of the process. | 0 to 100 %   | –               |

**10.5.4 Configuring the totalizer**

In the "Totalizer 1 to n" submenu, you can configure the specific totalizer.

**Navigation**

"Setup" menu → Advanced setup → Totalizer 1 to n

|                           |  |
|---------------------------|--|
| <b>► Totalizer 1 to n</b> |  |
| Assign process variable   | →  73 |
| Unit totalizer            | →  73 |
| Control Totalizer 1 to n  | →  73 |
| Totalizer operation mode  | →  73 |
| Failure mode              | →  73 |



**Parameter overview with brief description**

| Parameter                | Prerequisite  | Description   | Selection  | Factory setting  |
|--------------------------|---|---|--|--|
| Assign process variable  | –   | Select process variable for totalizer.                        | <ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> | –  |
| Unit totalizer           | One of the following options is selected in the <b>Assign process variable</b> parameter: <ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul>  | Select the unit for the process variable of the totalizer.    | Unit choose list   | Country-specific: <ul style="list-style-type: none"> <li>■ kg</li> <li>■ lb</li> </ul> |
| Control Totalizer 1 to n | One of the following options is selected in the <b>Assign process variable</b> parameter: <ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul>  | Control the totalizer value.                                  | <ul style="list-style-type: none"> <li>■ Totalize</li> <li>■ Reset + hold</li> <li>■ Preset + hold</li> </ul>  | –  |
| Totalizer operation mode | In the <b>Assign process variable</b> parameter, one of the following options is selected: <ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> | Select totalizer calculation mode.                            | <ul style="list-style-type: none"> <li>■ Net flow total</li> <li>■ Forward flow total</li> <li>■ Reverse flow total</li> <li>■ Last valid value</li> </ul>                         | –  |
| Failure mode             | In the <b>Assign process variable</b> parameter, one of the following options is selected: <ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> | Define the totalizer behavior in the event of a device alarm. | <ul style="list-style-type: none"> <li>■ Stop</li> <li>■ Actual value</li> <li>■ Last valid value</li> </ul>   | –  |


\* Visibility depends on order options or device settings

**10.5.5 Using parameters for device administration**

The **Administration** submenu systematically guides the user through all the parameters that can be used for device administration purposes.

**Navigation**

"Setup" menu → Advanced setup → Administration



### Parameter overview with brief description

| Parameter          | Description   | User entry / Selection   |
|--------------------|---|--|
| Define access code | Define release code for write access to parameters.                               | 0 to 9999  |
| Device reset       | Reset the device configuration - either entirely or in part - to a defined state. | <ul style="list-style-type: none"> <li>■ Cancel</li> <li>■ To delivery settings</li> <li>■ Restart device</li> </ul> |

## 10.6 Simulation

Via the **Simulation** submenu, it is possible to simulate various process variables in the process and the device alarm mode and verify downstream signal chains (switching valves or closed-control loops). The simulation can be performed without a real measurement (no flow of medium through the device).

### Navigation

"Diagnostics" menu → Simulation

|                                    |      |
|------------------------------------|------|
| ▶ Simulation                       |      |
| Assign simulation process variable | → 74 |
| Value process variable             | → 74 |
| Simulation device alarm            | → 74 |
| Simulation diagnostic event        | → 75 |

### Parameter overview with brief description



| Parameter                          | Prerequisite  | Description   | Selection / User entry  |
|------------------------------------|---|---|---|
| Assign simulation process variable | –   | Select a process variable for the simulation process that is activated. | <ul style="list-style-type: none"> <li>■ Off</li> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Density</li> <li>■ Reference density</li> <li>■ Temperature</li> <li>■ Concentration *</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> |
| Value process variable             | A process variable is selected in the <b>Assign simulation process variable</b> parameter (→ 74). | Enter the simulation value for the selected process variable.           | Depends on the process variable selected  |
| Simulation device alarm            | –   | Switch the device alarm on and off.                                     | <ul style="list-style-type: none"> <li>■ Off</li> <li>■ On</li> </ul>   |

| Parameter                   | Prerequisite | Description   | Selection / User entry  |
|-----------------------------|--------------|---|---|
| Diagnostic event category   | –            | Select a diagnostic event category.                                     | <ul style="list-style-type: none"> <li>▪ Sensor</li> <li>▪ Electronics</li> <li>▪ Configuration</li> <li>▪ Process</li> </ul>   |
| Simulation diagnostic event | –            | Select a diagnostic event for the simulation process that is activated. | <ul style="list-style-type: none"> <li>▪ Off</li> <li>▪ Diagnostic event picklist (depends on the category selected)</li> </ul> |

\* Visibility depends on order options or device settings

## 10.7 Protecting settings from unauthorized access

The following options exist for protecting the configuration of the measuring device from unintentional modification after commissioning:


- Write protection via access code for Web browser →  75
- Write protection via write protection switch →  76

### 10.7.1 Write protection via access code



With the customer-specific access code, access to the measuring instrument via the Web browser is protected, as are the parameters for the measuring instrument configuration.

#### Navigation

"Setup" menu → Advanced setup → Administration → Define access code



#### Defining the access code via the web browser

1. Navigate to the **Define access code** parameter.
  2. Define a 16-digit (max.) numeric code as the access code.
  3. Enter the access code again in the to confirm.
    - ↳ The web browser switches to the login page.
-  **▪** Disabling parameter write protection via access code .
- If the access code is lost: Resetting the access code .
  - The **Access status tooling** parameter shows which user role the user is currently logged in with.
    - Navigation path: Operation → Access status tooling
    - User roles and their access rights →  38

If no action is performed for 10 minutes, the web browser automatically returns to the login page.


## 10.7.2 Write protection via write protection switch


The write protection switch makes it possible to block write access to the entire operating menu with the exception of the following parameters:

- External pressure
- External temperature
- Reference density
- All parameters for configuring the totalizer

The parameter values are now read only and cannot be edited any more:

- Via service interface (CDI-RJ45)
- Via PROFIBUS DP

1. Depending on the housing version, loosen the securing clamp or fixing screw of the housing cover.
2. Depending on the housing version, unscrew or open the housing cover and disconnect the local display from the main electronics module where necessary  
→  151.



Setting the write protection switch on the main electronics module to the **On** position enables hardware write protection. Setting the write protection switch on the main electronics module to the **Off** position (factory setting) disables hardware write protection.

↳ If hardware write protection is enabled: the **Locking status** parameter displays the **Hardware locked** option ; if disabled, the **Locking status** parameter does not display any option .

4. Reverse the removal procedure to reassemble the transmitter.

# 11 Operation

## 11.1 Reading the device locking status

Device active write protection: **Locking status** parameter


### Navigation



"Operation" menu → Locking status

*Function scope of "Locking status" parameter*

| Options            | Description   |
|--------------------|---|
| Hardware locked    | The write protection switch (DIP switch) for hardware locking is activated on the I/O electronic module. This prevents write access to the parameters .   |
| Temporarily locked | Write access to the parameters is temporarily locked on account of internal processes running in the device (e.g. data upload/download, reset etc.). Once the internal processing has been completed, the parameters can be changed once again. |

## 11.2 Adjusting the operating language

 Detailed information:

- To configure the operating language →  57
- For information on the operating languages supported by the measuring device →  152

## 11.3 Configuring the display

Detailed information:



On the advanced settings for the local display

## 11.4 Reading off measured values

With the **Measured values** submenu, it is possible to read all the measured values.

### Navigation

"Diagnostics" menu → Measured values

|                     |  |
|---------------------|--|
| ▶ Measured values   |  |
| ▶ Process variables | →  77 |
| ▶ Totalizer 1 to n  | →  87 |

### 11.4.1 "Measured variables" submenu

The **Process variables** submenu contains all the parameters needed to display the current measured values for each process variable.









**Navigation**

"Diagnostics" menu → Measured values → Measured variables








| ► Measured variables          |      |
|-------------------------------|------|
| Mass flow                     | → 80 |
| Volume flow                   | → 80 |
| Corrected volume flow         | → 80 |
| Density                       | → 80 |
| Reference density             | → 80 |
| Temperature                   | → 80 |
| Pressure                      | → 80 |
| Concentration                 | → 80 |
| Target mass flow              | → 81 |
| Carrier mass flow             | → 81 |
| Target corrected volume flow  | → 81 |
| Carrier corrected volume flow | → 81 |
| Target volume flow            | → 81 |
| Carrier volume flow           | → 81 |
| CTL                           | → 81 |
| CPL                           | → 81 |
| CTPL                          | → 81 |
| S&W volume flow               | → 82 |
| S&W correction value          | → 82 |
| Reference density alternative | → 82 |
| GSV flow                      | → 82 |
| GSV flow alternative          | → 82 |




|                              |      |
|------------------------------|------|
| NSV flow                     | → 83 |
| NSV flow alternative         | → 83 |
| Oil CTL                      | → 83 |
| Oil CPL                      | → 83 |
| Oil CTPL                     | → 83 |
| Water CTL                    | → 84 |
| CTL alternative              | → 84 |
| CPL alternative              | → 84 |
| CTPL alternative             | → 84 |
| Oil reference density        | → 84 |
| Water reference density      | → 85 |
| Oil density                  | → 85 |
| Water density                | → 85 |
| Water cut                    | → 85 |
| Oil volume flow              | → 85 |
| Oil corrected volume flow    | → 86 |
| Oil mass flow                | → 86 |
| Water volume flow            | → 86 |
| Water corrected volume flow  | → 86 |
| Water mass flow              | → 86 |
| Weighted density average     | → 87 |
| Weighted temperature average | → 87 |






## Parameter overview with brief description






| Parameter             | Prerequisite   | Description   | User interface               | Factory setting |
|-----------------------|--|---|------------------------------|-----------------|
| Mass flow             | –  | Displays the mass flow that is currently measured.<br><i>Dependency</i><br>The unit is taken from: <b>Mass flow unit</b> parameter (→  59)                           | Signed floating-point number | –               |
| Volume flow           | –  | Displays the volume flow that is currently calculated.<br><i>Dependency</i><br>The unit is taken from the <b>Volume flow unit</b> parameter (→  59).                 | Signed floating-point number | –               |
| Corrected volume flow | –  | Displays the corrected volume flow that is currently calculated.<br><i>Dependency</i><br>The unit is taken from: <b>Corrected volume flow unit</b> parameter (→  59) | Signed floating-point number | –               |
| Density               | –  | Shows the density currently measured.<br><i>Dependency</i><br>The unit is taken from the <b>Density unit</b> parameter (→  59).                                    | Signed floating-point number | –               |
| Reference density     | –  | Displays the reference density that is currently calculated.<br><i>Dependency</i><br>The unit is taken from: <b>Reference density unit</b> parameter (→  59)       | Signed floating-point number | –               |
| Temperature           | –  | Shows the medium temperature currently measured.<br><i>Dependency</i><br>The unit is taken from: <b>Temperature unit</b> parameter (→  60)                         | Signed floating-point number | –               |
| Pressure value        | –  | Displays either a fixed or external pressure value.<br><i>Dependency</i><br>The unit is taken from the <b>Pressure unit</b> parameter (→  60).                     | Signed floating-point number | –               |
| Concentration         | For the following order code: Order code for "Application package", option <b>ED</b> "Concentration"<br> The software options currently enabled are displayed in the <b>Software option overview</b> parameter. | Displays the concentration that is currently calculated.<br><i>Dependency</i><br>The unit is taken from the <b>Concentration unit</b> parameter.  | Signed floating-point number | –               |













| Parameter                     | Prerequisite   | Description   | User interface                 | Factory setting |
|-------------------------------|--|---|--------------------------------|-----------------|
| Target mass flow              | <p>With the following conditions:<br/>Order code for "Application package", option <b>ED</b> "Concentration"</p> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | <p>Displays the mass flow that is currently measured for the target medium.</p> <p><i>Dependency</i><br/>The unit is taken from: <b>Mass flow unit</b> parameter<br/>(→  59)</p> | Signed floating-point number   | –               |
| Carrier mass flow             | <p>With the following conditions:<br/>Order code for "Application package", option <b>ED</b> "Concentration"</p> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | <p>Displays the mass flow of the carrier medium that is currently measured.</p> <p><i>Dependency</i><br/>The unit is taken from: <b>Mass flow unit</b> parameter<br/>(→  59)</p> | Signed floating-point number   | –               |
| Target corrected volume flow  | –  |   | Signed floating-point number   | –               |
| Carrier corrected volume flow | –  |   | Signed floating-point number   | –               |
| Target volume flow            | –  |   | Signed floating-point number   | –               |
| Carrier volume flow           | –  |   | Signed floating-point number   | –               |
| CTL                           | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>API referenced correction</b> option is selected in <b>Petroleum mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the calibration factor which represents the effect of temperature on the fluid. This is used to convert the measured volume flow and the measured density to values at reference temperature.</p>   | Positive floating-point number | –               |
| CPL                           | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>API referenced correction</b> option is selected in <b>Petroleum mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the calibration factor which represents the effect of pressure on the fluid. This is used to convert the measured volume flow and the measured density to values at reference pressure.</p>   | Positive floating-point number | –               |
| CTPL                          | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>API referenced correction</b> option is selected in <b>Petroleum mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the combined calibration factor which represents the effect of temperature and pressure on the fluid This is used to convert the measured volume flow and the measured density to values at reference temperature and reference pressure.</p>         | Positive floating-point number | –               |



| Parameter                     | Prerequisite   | Description   | User interface                 | Factory setting |
|-------------------------------|--|---|--------------------------------|-----------------|
| S&W volume flow               | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>API referenced correction</b> option is selected in <b>Petroleum mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>                                   | <p>Displays the S&amp;W volume flow which is calculated from the measured total volume flow minus the net volume flow.</p> <p><i>Dependency</i><br/>The unit is taken from:<br/><b>Volume flow unit</b> parameter</p>                           | Signed floating-point number   | -               |
| S&W correction value          | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>External value</b> option or <b>Current input 1...n</b> option is selected in the <b>S&amp;W input mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Shows the correction value for sediment and water.</p>   | Positive floating-point number | -               |
| Reference density alternative | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>                            | <p>Displays the fluid density at the alternative reference temperature.</p> <p><i>Dependency</i><br/>The unit is taken from:<br/><b>Reference density unit</b> parameter</p>  | Signed floating-point number   | -               |
| GSV flow                      | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>API referenced correction</b> option is selected in <b>Petroleum mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>                                 | <p>Displays the measured total volume flow, corrected to the reference temperature and the reference pressure.</p> <p><i>Dependency</i><br/>The unit is taken from:<br/><b>Corrected volume flow unit</b> parameter</p>                         | Signed floating-point number   | -               |
| GSV flow alternative          | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>                            | <p>Displays the measured total volume flow, corrected to the alternative reference temperature and the alternative reference pressure.</p> <p><i>Dependency</i><br/>The unit is taken from:<br/><b>Corrected volume flow unit</b> parameter</p> | Signed floating-point number   | -               |

| Parameter            | Prerequisite  | Description   | User interface                 | Factory setting |
|----------------------|---|---|--------------------------------|-----------------|
| NSV flow             | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ The <b>API referenced correction</b> option is selected in <b>Petroleum mode</b> parameter.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>      | <p>Displays the net volume flow which is calculated from the measured total volume flow minus the value for sediment &amp; water and minus the shrinkage.</p> <p><i>Dependency</i><br/>The unit is taken from: <b>Corrected volume flow unit</b> parameter</p>        | Signed floating-point number   | -               |
| NSV flow alternative | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the net volume flow which is calculated from the measured alternative total volume minus the value for sediment &amp; water and minus the shrinkage.</p> <p><i>Dependency</i><br/>The unit is taken from: <b>Corrected volume flow unit</b> parameter</p> | Signed floating-point number   | -               |
| Oil CTL              | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the correction factor which represents the effect of temperature on the oil. This is used to convert the measured oil volume flow and the measured oil density to values at reference temperature.</p>  | Positive floating-point number | -               |
| Oil CPL              | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the correction factor which represents the effect of pressure on the oil. This is used to convert the measured oil volume flow and the measured oil density to values at reference pressure.</p>  | Positive floating-point number | -               |
| Oil CTPL             | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the combined correction factor which represents the effect of temperature and pressure on the oil. This is used to convert the measured oil volume flow and the measured oil density to values at reference temperature and reference pressure.</p>       | Positive floating-point number | -               |

| Parameter             | Prerequisite   | Description   | User interface                 | Factory setting |
|-----------------------|--|---|--------------------------------|-----------------|
| Water CTL             | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>     | <p>Displays the correction factor which represents the effect of temperature on the water. This is used to convert the measured water volume flow and the measured water density to values at reference temperature.</p>  | Positive floating-point number | -               |
| CTL alternative       | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | <p>Displays the correction factor which represents the effect of temperature on the fluid. This is used to convert the measured volume flow and the measured density to values at the alternative reference temperature.</p>  | Positive floating-point number | -               |
| CPL alternative       | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the correction factor which represents the effect of pressure on the fluid. This is used to convert the measured volume flow and the measured density to values at the alternative reference pressure.</p>  | Positive floating-point number | -               |
| CTPL alternative      | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the combined correction factor which represents the effect of temperature and pressure on the fluid. This is used to convert the measured volume flow and the measured density to values at the alternative reference temperature and the alternative reference pressure.</p> | Positive floating-point number | -               |
| Oil reference density | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   |   | Signed floating-point number   | -               |

| Parameter               | Prerequisite   | Description   | User interface               | Factory setting |
|-------------------------|--|---|------------------------------|-----------------|
| Water reference density | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>     |   | Signed floating-point number | –               |
| Oil density             | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>     | Displays the density of the oil currently measured.   | Signed floating-point number | –               |
| Water density           | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | Displays the density of the water currently measured.   | Signed floating-point number | –               |
| Water cut               | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>API referenced correction</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | Displays the percentage water volume flow in relation to the total volume flow of the fluid.  | 0 to 100 %                   | –               |
| Oil volume flow         | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | <p>Displays the currently calculated volume flow of the oil.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ Based on the value displayed in the <b>Water cut</b> parameter</li> <li>▪ The unit is taken from: <b>Volume flow unit</b> parameter</li> </ul> | Signed floating-point number | –               |

| Parameter                   | Prerequisite  | Description   | User interface               | Factory setting |
|-----------------------------|---|---|------------------------------|-----------------|
| Oil corrected volume flow   | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | <p>Displays the currently calculated volume flow of the oil, calculated to values at reference temperature and reference pressure.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ Based on the value displayed in the <b>Water cut</b> parameter</li> <li>▪ The unit is taken from: <b>Corrected volume flow unit</b> parameter</li> </ul>   | Signed floating-point number | -               |
| Oil mass flow               | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p>   | <p>Displays the currently calculated mass flow of the oil.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ Based on the value displayed in the <b>Water cut</b> parameter</li> <li>▪ The unit is taken from: <b>Mass flow unit</b> parameter</li> </ul>   | Signed floating-point number | -               |
| Water volume flow           | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the currently calculated volume flow of the water.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ Based on the value displayed in the <b>Water cut</b> parameter</li> <li>▪ The unit is taken from: <b>Volume flow unit</b> parameter</li> </ul>   | Signed floating-point number | -               |
| Water corrected volume flow | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the currently calculated volume flow of the water, calculated to values at reference temperature and reference pressure.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ Based on the value displayed in the <b>Water cut</b> parameter</li> <li>▪ The unit is taken from: <b>Corrected volume flow unit</b> parameter</li> </ul> | Signed floating-point number | -               |
| Water mass flow             | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option EJ "Petroleum"</li> <li>▪ In the <b>Petroleum mode</b> parameter, the <b>Net oil &amp; water cut</b> option is selected.</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the currently calculated mass flow of the water.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ Based on the value displayed in the <b>Water cut</b> parameter</li> <li>▪ The unit is taken from: <b>Mass flow unit</b> parameter</li> </ul>   | Signed floating-point number | -               |


| Parameter                    | Prerequisite   | Description   | User interface               | Factory setting |
|------------------------------|--|---|------------------------------|-----------------|
| Weighted density average     | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ "Application package", option <b>EM</b> "Petroleum + Locking function"</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the weighted average for the density since the last time the density averages were reset.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ The unit is taken from: <b>Density unit</b> parameter</li> <li>▪ The value is reset to NaN (Not a Number) via the <b>Reset weighted averages</b> parameter</li> </ul>             | Signed floating-point number | -               |
| Weighted temperature average | <p>For the following order code:</p> <ul style="list-style-type: none"> <li>▪ "Application package", option <b>EJ</b> "Petroleum"</li> <li>▪ "Application package", option <b>EM</b> "Petroleum + Locking function"</li> </ul> <p> The software options currently enabled are displayed in the <b>Software option overview</b> parameter.</p> | <p>Displays the weighted average for the temperature since the last time the temperature averages were reset.</p> <p>Dependency:</p> <ul style="list-style-type: none"> <li>▪ The unit is taken from: <b>Temperature unit</b> parameter</li> <li>▪ The value is reset to NaN (Not a Number) via the <b>Reset weighted averages</b> parameter</li> </ul> | Signed floating-point number | -               |

### 11.4.2 "Totalizer" submenu

The **Totalizer** submenu contains all the parameters needed to display the current measured values for every totalizer.

#### Navigation

"Diagnostics" menu → Measured values → Totalizer





**Parameter overview with brief description**

| Parameter                 | Prerequisite   | Description                                   | User interface               |
|---------------------------|--|---|------------------------------|
| Totalizer value 1 to n    | One of the following options is selected in the <b>Assign process variable</b> parameter of the <b>Totalizer 1 to n</b> submenu:<br><ul style="list-style-type: none"> <li>■ Volume flow</li> <li>■ Mass flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> | Displays the current totalizer counter value. | Signed floating-point number |
| Totalizer overflow 1 to n | One of the following options is selected in the <b>Assign process variable</b> parameter of the <b>Totalizer 1 to n</b> submenu:<br><ul style="list-style-type: none"> <li>■ Volume flow</li> <li>■ Mass flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> | Displays the current totalizer overflow.      | Integer with sign            |

\* Visibility depends on order options or device settings

## 11.5 Adapting the measuring device to the process conditions

The following are available for this purpose:

- Basic settings using the **Setup** menu (→  57)
- Advanced settings using the **Advanced setup** submenu (→  66)

## 11.6 Performing a totalizer reset

The totalizers are reset in the **Operation** submenu:

Control Totalizer 1 to n

*Function range of "Control Totalizer" parameter*


| Options                | Description  |
|------------------------|--|
| Totalize               | The totalizer is started.  |
| Reset + hold           | The totaling process is stopped and the totalizer is reset to 0.   |
| Preset + hold          | The totaling process is stopped and the totalizer is set to its defined start value from the <b>Preset value 1 to n</b> parameter. |
| Stop totalizing option | Totalizing is stopped.   |

### Navigation

"Operation" menu → Totalizer handling

▶ Totalizer handling

Control Totalizer 1 to n

→  89



|                      |      |
|----------------------|------|
| Preset value 1 to n  | → 89 |
| Reset all totalizers | → 89 |

### Parameter overview with brief description

| Parameter                | Prerequisite  | Description                          | Selection / User entry  |
|--------------------------|---|--------------------------------------|---|
| Control Totalizer 1 to n | One of the following options is selected in the <b>Assign process variable</b> parameter:<br><ul style="list-style-type: none"> <li>■ Mass flow</li> <li>■ Volume flow</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow *</li> <li>■ Carrier mass flow *</li> </ul> | Control the totalizer value.         | <ul style="list-style-type: none"> <li>■ Totalize</li> <li>■ Reset + hold</li> <li>■ Preset + hold</li> </ul> |
| Preset value 1 to n      | –   | Specify start value for totalizer.   | Signed floating-point number  |
| Reset all totalizers     | –   | Reset all totalizers to 0 and start. | <ul style="list-style-type: none"> <li>■ Cancel</li> <li>■ Reset + totalize</li> </ul>                        |

\* Visibility depends on order options or device settings

## 12 Diagnostics and troubleshooting

### 12.1 General troubleshooting

#### For local display

| Error   | Possible causes   | Remedial action  |
|---|---|--|
| Local display is dark, but signal output is within the valid range        | The cable of the display module is not plugged in correctly.  | Insert the plug correctly into the main electronics module and display module.   |
| Local display dark and no output signals                                  | Supply voltage does not match the voltage specified on the nameplate.   | Apply the correct supply voltage → 28.   |
| Local display dark and no output signals                                  | Supply voltage has incorrect polarity.  | Reverse polarity of supply voltage.  |
| Local display dark and no output signals                                  | No contact between connecting cables and terminals.   | Ensure electrical contact between the cable and the terminal.  |
| Local display dark and no output signals                                  | <ul style="list-style-type: none"> <li>▪ Terminals are not plugged into the I/O electronics module correctly.</li> <li>▪</li> </ul> | Check terminals.   |
| Local display dark and no output signals                                  | <ul style="list-style-type: none"> <li>▪ I/O electronics module is defective.</li> <li>▪</li> </ul>                                 | Order spare part → 131.  |
| Local display cannot be read, but signal output is within the valid range | Display is set too bright or too dark.  | <ul style="list-style-type: none"> <li>▪ Set the display brighter by simultaneously pressing <math>\boxplus</math> + <math>\boxminus</math>.</li> <li>▪ Set the display darker by simultaneously pressing <math>\boxminus</math> + <math>\boxplus</math>.</li> </ul> |
| Local display is dark, but signal output is within the valid range        | Display module is defective.  | Order spare part → 131.  |
| Backlighting of local display is red                                      | Diagnostic event with "Alarm" diagnostic behavior has occurred.   | Take remedial measures → 98  |
| Message on local display:<br>"Communication Error"<br>"Check Electronics" | Communication between the display module and the electronics is interrupted.  | <ul style="list-style-type: none"> <li>▪ Check the cable and the connector between the main electronics module and display module.</li> <li>▪ Order spare part → 131.</li> </ul>   |

#### For output signals

| Error   | Possible causes   | Remedial action   |
|---|---|---|
| Green power LED on the main electronics module of the transmitter is dark | Supply voltage does not match the voltage specified on the nameplate. | Apply the correct supply voltage → 28.  |
| Device measures incorrectly.  | Configuration error or device is operated outside the application.    | <ol style="list-style-type: none"> <li>1. Check and correct parameter configuration.</li> <li>2. Observe limit values specified in the "Technical Data".</li> </ol> |

#### For access


| Fault                                       | Possible causes                                 | Remedial action   |
|---|---|---|
| Write access to parameters is not possible. | Hardware write protection is enabled.           | Set the write protection switch on the main electronics module to the <b>OFF</b> position → 76.   |
| Connection via PROFIBUS DP is not possible. | PROFIBUS DP bus cable is incorrectly connected. | Check the terminal assignment → 26.   |
| Connection via PROFIBUS DP is not possible. | Device plug is incorrectly connected.           | Check the pin assignment of the device plugs .  |
| Connection via PROFIBUS DP is not possible. | PROFIBUS DP cable is incorrectly terminated.    | Check the terminating resistor → 31.  |
| Unable to connect to the web server.        | Web server is disabled.                         | Using the "FieldCare" or "DeviceCare" operating tool, check whether the web server of the device is enabled, and enable it if necessary → 43. |

| Fault  | Possible causes   | Remedial action   |
|--|---|---|
|  | The Ethernet interface on the PC is incorrectly configured.   | <ul style="list-style-type: none"> <li>▶ Check the properties of the Internet protocol (TCP/IP).</li> <li>▶ Check the network settings with the IT manager.</li> </ul>  |
| Unable to connect to the web server.   | The IP address on the PC is incorrectly configured.   | Check the IP address: 192.168.1.212 → 📄 40  |
| Web browser frozen and operation no longer possible  | Data transfer is active.  | Wait until data transfer or current action is finished.   |
|  | Connection lost   | <ul style="list-style-type: none"> <li>▶ Check cable connection and power supply.</li> <li>▶ Refresh the web browser and restart if necessary.</li> </ul>               |
| Display of web browser content is difficult to read or incomplete.   | Web browser version used is not optimal.  | <ul style="list-style-type: none"> <li>▶ Use correct web browser version → 📄 39.</li> <li>▶ Empty the web browser cache.</li> <li>▶ Restart the web browser.</li> </ul> |
|  | Unsuitable view settings.   | Change the font size/display ratio of the Web browser.  |
| Incomplete or no display of content in the web browser   | <ul style="list-style-type: none"> <li>▪ JavaScript is not enabled.</li> <li>▪ JavaScript cannot be enabled.</li> </ul> | <ul style="list-style-type: none"> <li>▶ Enable JavaScript.</li> <li>▶ Enter http://XXX.XXX.X.XX/servlet/basic.html as the IP address.</li> </ul>                       |
| Operation with FieldCare or DeviceCare via service interface CDI-RJ45 (port 8000) is not possible.                           | Firewall of the PC or network is blocking communication.  | Depending on the settings of the firewall used on the PC or in the network, the firewall must be adapted or disabled to allow FieldCare/ DeviceCare access.             |
| Flashing the firmware with FieldCare or DeviceCare via service interface CDI-RJ45 (port 8000 or TFTP ports) is not possible. | Firewall of the PC or network is blocking communication.  | Depending on the settings of the firewall used on the PC or in the network, the firewall must be adapted or disabled to allow FieldCare/ DeviceCare access.             |

## 12.2 Diagnostic information via LEDs

### 12.2.1 Transmitter

Different LEDs in the transmitter provide information on the device status.



A0029689

- 1 Supply voltage  
 2 Device status  
 3 Not used  
 4 Communication  
 5 Service interface (CDI) active, Ethernet Link/Activity


1. Open the housing cover.
2. Remove the display module.
3. Fold open the terminal cover.

| LED            | Color          | Meaning   |
|----------------|----------------|---|
| Supply voltage | Off            | Supply voltage is off or too low  |
|                | Green          | Supply voltage is ok  |
| Alarm          | Off            | Device status is ok   |
|                | Flashing red   | A device error of diagnostic behavior "Warning" has occurred  |
|                | Red            | <ul style="list-style-type: none"> <li>▪ A device error of diagnostic behavior "Alarm" has occurred</li> <li>▪ Boot loader is active</li> </ul> |
| Communication  | Flashing white | PROFIBUS DP communication is active   |

## 12.3 Diagnostic information in the web browser

### 12.3.1 Diagnostic options

Any faults detected by the measuring device are displayed in the Web browser on the home page once the user has logged on.



- 1 Status area with status signal
- 2 Diagnostics information → 93 and remedial measures with service ID

**i** In addition, diagnostic events which have occurred can be shown in the **Diagnostics** menu:

- Via parameter → 123
- Via submenu → 124

### Status signals


The status signals provide information on the state and reliability of the device by categorizing the cause of the diagnostic information (diagnostic event).

| Symbol | Meaning   |
|--------|---|
|        | <b>Failure</b><br>A device error has occurred. The measured value is no longer valid.   |
|        | <b>Function check</b><br>The device is in service mode (e.g. during a simulation).  |
|        | <b>Out of specification</b><br>The device is being operated:<br>Outside its technical specification limits (e.g. outside the process temperature range) |
|        | <b>Maintenance required</b><br>Maintenance is required. The measured value remains valid.   |

**i** The status signals are categorized in accordance with VDI/VDE 2650 and NAMUR Recommendation NE 107.

### Diagnostic information

The fault can be identified using the diagnostic information. The short text helps you by providing information about the fault.




### 12.3.2 Calling up remedy information

Remedy information is provided for every diagnostic event to ensure that problems can be rectified quickly. These measures are displayed in red along with the diagnostic event and the related diagnostic information.

## 12.4 Diagnostic information in FieldCare or DeviceCare

### 12.4.1 Diagnostic options

Any faults detected by the measuring device are displayed on the home page of the operating tool once the connection has been established.



A0021799-EN


- 1 Status area with status signal
- 2 Diagnostic information → 93
- 3 Remedial measures with service ID

**i** In addition, diagnostic events which have occurred can be shown in the **Diagnostics** menu:

- Via parameter → 123
- Via submenu → 124

### Diagnostic information

The fault can be identified using the diagnostic information. The short text helps you by providing information about the fault.



### 12.4.2 Calling up remedy information

Remedy information is provided for every diagnostic event to ensure that problems can be rectified quickly:

- On the home page  
Remedy information is displayed in a separate field below the diagnostics information.
- In the **Diagnostics** menu  
Remedy information can be called up in the working area of the user interface.

The user is in the **Diagnostics** menu.


1. Call up the desired parameter.
2. On the right in the working area, mouse over the parameter.  
↳ A tool tip with remedy information for the diagnostic event appears.

## 12.5 Adapting the diagnostic information

### 12.5.1 Adapting the diagnostic behavior

Each item of diagnostic information is assigned a specific diagnostic behavior at the factory. The user can change this assignment for specific diagnostic information in the **Diagnostic behavior** submenu.

Expert → System → Diagnostic handling → Diagnostic behavior



#### Available diagnostic behaviors


The following diagnostic behaviors can be assigned:

| Diagnostic behavior | Description   |
|---------------------|---|
| Alarm               | The device stops measurement. The totalizers assume the defined alarm condition. A diagnostic message is generated.                     |
| Warning             | The device continues to measure. Measured value output via PROFIBUS and totalizers are not affected. A diagnostic message is generated. |

| Diagnostic behavior | Description   |
|---------------------|---|
| Logbook entry only  | The device continues to measure. The diagnostic message is only displayed in the <b>Event logbook</b> submenu ( <b>Event list</b> submenu) and is not displayed in alternating sequence with the operational display. |
| Off                 | The diagnostic event is ignored, and no diagnostic message is generated or entered.   |

### Displaying the measured value status

If the Analog Input, Digital Input and Totalizer function blocks are configured for cyclic data transmission, the device status is coded as per PROFIBUS PA Profile 3.02 Specification and transmitted along with the measured value to the PROFIBUS Master (Class 1) via the coding byte (byte 5). The coding byte is split into three segments: Quality, Quality Substatus and Limits.



A0032228-EN

17 Structure of the coding byte

The content of the coding byte depends on the configured failure mode in the individual function block. Depending on which failure mode has been configured, status information in accordance with PROFINET PA Profile Specification 4 is transmitted to the PROFIBUS master (Class 1) via the coding byte status information.

### Determining the measured value status and device status via the diagnostic behavior

When the diagnostic behavior is assigned, this also changes the measured value status and device status for the diagnostic information. The measured value status and device status depend on the choice of diagnostic behavior and on the group in which the diagnostic information is located.

The diagnostic information is grouped as follows:

- Diagnostic information pertaining to the sensor: diagnostic number 000 to 199  
→ 97
- Diagnostic information pertaining to the electronics: diagnostic number 200 to 399  
→ 97
- Diagnostic information pertaining to the configuration: diagnostic number 400 to 599  
→ 97
- Diagnostic information pertaining to the process: diagnostic number 800 to 999  
→ 98

Depending on the group in which the diagnostic information is located, the following measured value status and device status are firmly assigned to the particular diagnostic behavior:



*Diagnostic information pertaining to the sensor: diagnostic number 000 to 199*

| Diagnostic behavior (configurable) | Measured value status (fixed assignment) |                      |              |                  | Device diagnosis (fixed assignment) |
|------------------------------------|--|----------------------|--------------|------------------|-------------------------------------|
|                                    | Quality                                  | Quality Substatus    | Coding (hex) | Category (NE107) |                                     |
| Alarm                              | BAD                                      | Maintenance alarm    | 0x24 to 0x27 | F (Failure)      | Maintenance alarm                   |
| Warning                            | GOOD                                     | Maintenance demanded | 0xA8 to 0xAB | M (Maintenance)  | Maintenance demanded                |
| Logbook entry only                 | GOOD                                     | ok                   | 0x80 to 0x8E | -                | -                                   |
| Off                                |  |                      |              |                  |                                     |

*Diagnostic information pertaining to the electronics: diagnostic number 200 to 399*

*Diagnostic number 200 to 301, 303 to 399*

| Diagnostic behavior (configurable) | Measured value status (fixed assignment) |                   |              |                  | Device diagnostics (fixed assignment) |
|------------------------------------|--|-------------------|--------------|------------------|---------------------------------------|
|                                    | Quality                                  | Quality Substatus | Coding (hex) | Category (NE107) |                                       |
| Alarm                              | BAD                                      | Maintenance alarm | 0x24 to 0x27 | F (Failure)      | Maintenance alarm                     |
| Warning                            |  |                   |              |                  |                                       |
| Logbook entry only                 | GOOD                                     | ok                | 0x80 to 0x8E | -                | -                                     |
| Off                                |  |                   |              |                  |                                       |

*Diagnostic information 302*

| Diagnostic behavior (configurable) | Measured value status (fixed assignment) |                                |              |                  | Device diagnostics (fixed assignment) |
|------------------------------------|--|--------------------------------|--------------|------------------|---------------------------------------|
|                                    | Quality                                  | Quality Substatus              | Coding (hex) | Category (NE107) |                                       |
| Alarm                              | BAD                                      | Function check, local override | 0x3C to 0x3F | C                | Function check                        |
| Warning                            | GOOD                                     | Function check                 | 0xBC to 0xBF | -                | -                                     |

Data logging continues when Heartbeat Verification is started. The signal outputs and totalizers are not affected.

- Signal status: Function check
- Choice of diagnostic behavior: alarm or warning (factory setting)

When the Heartbeat Verification is started, data logging is interrupted, the last valid measured value is output and the totalizer counter is stopped.




*Diagnostic information pertaining to the configuration: diagnostic number 400 to 599*

| Diagnostic behavior (configurable) | Measured value status (fixed assignment) |                   |              |                  | Device diagnosis (fixed assignment) |
|------------------------------------|--|-------------------|--------------|------------------|-------------------------------------|
|                                    | Quality                                  | Quality Substatus | Coding (hex) | Category (NE107) |                                     |
| Alarm                              | BAD                                      | Function check    | 0x3C to 0x3F | C (Check)        | Function check                      |
| Logbook entry only                 | GOOD                                     | Function check    | 0xBC to 0xBF | -                | Function check                      |
| Off                                |  |                   |              |                  |                                     |
| Logbook entry only                 | GOOD                                     | ok                | 0x80 to 0x8E | -                | -                                   |
| Off                                |  |                   |              |                  |                                     |

Diagnostic information pertaining to the process: diagnostic number 800 to 999

| Diagnostic behavior (configurable) | Measured value status (fixed assignment) |                   |              |                          | Device diagnosis (fixed assignment) |
|------------------------------------|--|-------------------|--------------|--------------------------|-------------------------------------|
|                                    | Quality                                  | Quality Substatus | Coding (hex) | Category (NE107)         |                                     |
| Alarm                              | BAD                                      | Process related   | 0x28 to 0x2B | F (Failure)              | Invalid process condition           |
| Warning                            | UNCERTAIN                                | Process related   | 0x78 to 0x7B | S (Out of specification) | Invalid process condition           |
| Logbook entry only                 | GOOD                                     | ok                | 0x80 to 0x8E | -                        | -                                   |
| Off                                |  |                   |              |                          |                                     |

## 12.6 Overview of diagnostic information

-  The amount of diagnostic information and the number of measured variables affected increase if the measuring device has one or more application packages.
- All of the measured variables affected in the entire Promass instrument family are always listed under "Measured variables affected". The measured variables available for the device in question depend on the device version. When assigning the measured variables to the device functions, for example to the individual outputs, all of the measured variables available for the device version in question are available for selection.
-  In the case of some items of diagnostic information, the diagnostic behavior can be changed. Adapting the diagnostic information →  95

### 12.6.1 Diagnostic of sensor

| No. | Diagnostic information |       | Remedy instructions                                  | Influenced measured variables  |
|-----|------------------------|-------|--|--|
|     | Short text             |       |  |  |
| 022 | Sensor temperature     |       | 1. Change main electronic module<br>2. Change sensor | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |
|     | Status signal          | F     |  |  |
|     | Diagnostic behavior    | Alarm |  |  |

| Diagnostic information |                       | Remedy instructions | Influenced measured variables   |
|------------------------|-----------------------|---------------------|---|
| No.                    | Short text            |                     |   |
| 046                    | Sensor limit exceeded |                     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ Kinematic viscosity</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Volume flow</li> </ul> |
|                        | Status signal         | S                   |   |
|                        | Diagnostic behavior   | Warning             |   |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |
|------------------------|---------------------|---------------------|--|
| No.                    | Short text          |                     |  |
| 062                    | Sensor connection   |                     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |
|                        | Status signal       | F                   |  |
|                        | Diagnostic behavior | Alarm               |  |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |
|------------------------|---------------------|---------------------|--|
| No.                    | Short text          |                     |  |
| 082                    | Data storage        |                     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Volume flow</li> </ul> |
|                        | Status signal       | F                   |  |
|                        | Diagnostic behavior | Alarm               |  |

| Diagnostic information |                     | Remedy instructions                     | Influenced measured variables  |       |
|------------------------|---------------------|---|--|-------|
| No.                    | Short text          |   |  |       |
| 083                    | Memory content      | 1. Restart device<br>2. Contact service | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |   |  | F     |
|                        | Diagnostic behavior |   |  | Alarm |

| Diagnostic information |                     | Remedy instructions                                     | Influenced measured variables   |       |
|------------------------|---------------------|---|---|-------|
| No.                    | Short text          |   |   |       |
| 140                    | Sensor signal       | 1. Check or change main electronics<br>2. Change sensor | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> </ul> |       |
|                        | Status signal       |   |   | S     |
|                        | Diagnostic behavior |   |   | Alarm |

| Diagnostic information |                          | Remedy instructions                                      | Influenced measured variables   |       |
|------------------------|--------------------------|--|---|-------|
| No.                    | Short text               |  |   |       |
| 144                    | Measuring error too high | 1. Check or change sensor<br>2. Check process conditions | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> </ul> |       |
|                        | Status signal            |  |   | F     |
|                        | Diagnostic behavior      |  |   | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 190                    | Special event 1     | Contact service     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 191                    | Special event 5     | Contact service     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| No. | Diagnostic information |       | Remedy instructions | Influenced measured variables  |
|-----|------------------------|-------|---------------------|--|
|     | Short text             |       |                     |  |
| 192 | Special event 9        |       | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |
|     | Status signal          | F     |                     |  |
|     | Diagnostic behavior    | Alarm |                     |  |

### 12.6.2 Diagnostic of electronic

| No. | Diagnostic information |       | Remedy instructions                     | Influenced measured variables  |
|-----|------------------------|-------|---|--|
|     | Short text             |       |   |  |
| 201 | Device failure         |       | 1. Restart device<br>2. Contact service | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |
|     | Status signal          | F     |   |  |
|     | Diagnostic behavior    | Alarm |   |  |

| Diagnostic information |                       | Remedy instructions   | Influenced measured variables  |       |
|------------------------|-----------------------|---|--|-------|
| No.                    | Short text            |   |  |       |
| 242                    | Software incompatible | 1. Check software<br>2. Flash or change main electronics module | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal         |   |  | F     |
|                        | Diagnostic behavior   |   |  | Alarm |

| Diagnostic information |                      | Remedy instructions   | Influenced measured variables  |       |
|------------------------|----------------------|---|--|-------|
| No.                    | Short text           |   |  |       |
| 252                    | Modules incompatible | 1. Check electronic modules<br>2. Change electronic modules | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal        |   |  | F     |
|                        | Diagnostic behavior  |   |  | Alarm |

| Diagnostic information |                     | Remedy instructions                                       | Influenced measured variables  |       |
|------------------------|---------------------|---|--|-------|
| No.                    | Short text          |   |  |       |
| 262                    | Module connection   | 1. Check module connections<br>2. Change main electronics | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |   |  | F     |
|                        | Diagnostic behavior |   |  | Alarm |

| Diagnostic information |                         | Remedy instructions           | Influenced measured variables  |       |
|------------------------|-------------------------|-------------------------------|--|-------|
| No.                    | Short text              |                               |  |       |
| 270                    | Main electronic failure | Change main electronic module | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal           |                               |  | F     |
|                        | Diagnostic behavior     |                               |  | Alarm |



| Diagnostic information |                         | Remedy instructions                                   | Influenced measured variables  |       |
|------------------------|-------------------------|---|--|-------|
| No.                    | Short text              |   |  |       |
| 271                    | Main electronic failure | 1. Restart device<br>2. Change main electronic module | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal           |   |  | F     |
|                        | Diagnostic behavior     |   |  | Alarm |

| Diagnostic information |                         | Remedy instructions                     | Influenced measured variables  |       |
|------------------------|-------------------------|---|--|-------|
| No.                    | Short text              |   |  |       |
| 272                    | Main electronic failure | 1. Restart device<br>2. Contact service | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal           |   |  | F     |
|                        | Diagnostic behavior     |   |  | Alarm |

| Diagnostic information |                         | Remedy instructions | Influenced measured variables  |       |
|------------------------|-------------------------|---------------------|--|-------|
| No.                    | Short text              |                     |  |       |
| 273                    | Main electronic failure | Change electronic   | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal           |                     |  | F     |
|                        | Diagnostic behavior     |                     |  | Alarm |

| Diagnostic information |                         | Remedy instructions | Influenced measured variables   |         |
|------------------------|-------------------------|---------------------|---|---------|
| No.                    | Short text              |                     |   |         |
| 274                    | Main electronic failure | Change electronic   | <ul style="list-style-type: none"> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Corrected volume flow</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal           |                     |   | S       |
|                        | Diagnostic behavior     |                     |   | Warning |

| Diagnostic information |                     | Remedy instructions   | Influenced measured variables  |       |
|------------------------|---------------------|---|--|-------|
| No.                    | Short text          |   |  |       |
| 283                    | Memory content      | <ol style="list-style-type: none"> <li>1. Reset device</li> <li>2. Contact service</li> </ol> | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |   |  | F     |
|                        | Diagnostic behavior |   |  | Alarm |

| Diagnostic information |                     | Remedy instructions                   | Influenced measured variables  |       |
|------------------------|---------------------|---------------------------------------|--|-------|
| No.                    | Short text          |                                       |  |       |
| 311                    | Electronic failure  | 1. Reset device<br>2. Contact service | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal       |                                       |  | F     |
|                        | Diagnostic behavior |                                       |  | Alarm |

| Diagnostic information |                     | Remedy instructions                          | Influenced measured variables  |         |
|------------------------|---------------------|--|--|---------|
| No.                    | Short text          |  |  |         |
| 311                    | Electronic failure  | 1. Do not reset device<br>2. Contact service | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Volume flow</li> </ul> |         |
|                        | Status signal       |  |  | M       |
|                        | Diagnostic behavior |  |  | Warning |

| Diagnostic information |                     | Remedy instructions                          | Influenced measured variables  |       |
|------------------------|---------------------|--|--|-------|
| No.                    | Short text          |  |  |       |
| 382                    | Data storage        | 1. Insert DAT module<br>2. Change DAT module | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |  |  | F     |
|                        | Diagnostic behavior |  |  | Alarm |

| Diagnostic information |                     | Remedy instructions   | Influenced measured variables  |       |
|------------------------|---------------------|---|--|-------|
| No.                    | Short text          |   |  |       |
| 383                    | Memory content      | 1. Restart device<br>2. Check or change DAT module 3. Contact service | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |   |  | F     |
|                        | Diagnostic behavior |   |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 390                    | Special event 2     | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 391                    | Special event 6     | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| No. | Diagnostic information |       | Remedy instructions | Influenced measured variables  |
|-----|------------------------|-------|---------------------|--|
|     | Short text             |       |                     |  |
| 392 | Special event 10       |       | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |
|     | Status signal          | F     |                     |  |
|     | Diagnostic behavior    | Alarm |                     |  |

### 12.6.3 Diagnostic of configuration

| No. | Diagnostic information |       | Remedy instructions   | Influenced measured variables  |
|-----|------------------------|-------|---|--|
|     | Short text             |       |   |  |
| 410 | Data transfer          |       | <ol style="list-style-type: none"> <li>1. Check connection</li> <li>2. Retry data transfer</li> </ol> | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |
|     | Status signal          | F     |   |  |
|     | Diagnostic behavior    | Alarm |   |  |

| Diagnostic information |                     | Remedy instructions              | Influenced measured variables  |         |
|------------------------|---------------------|----------------------------------|--|---------|
| No.                    | Short text          |                                  |  |         |
| 411                    | Up-/download active | Up-/download active, please wait | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |                                  |  | C       |
|                        | Diagnostic behavior |                                  |  | Warning |

| Diagnostic information |                     | Remedy instructions              | Influenced measured variables  |         |
|------------------------|---------------------|----------------------------------|--|---------|
| No.                    | Short text          |                                  |  |         |
| 411                    | Up-/download active | Up-/download active, please wait | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |                                  |  | C       |
|                        | Diagnostic behavior |                                  |  | Warning |

| Diagnostic information |                            | Remedy instructions                     | Influenced measured variables  |       |
|------------------------|----------------------------|---|--|-------|
| No.                    | Short text                 |   |  |       |
| 437                    | Configuration incompatible | 1. Restart device<br>2. Contact service | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal              |   |  | F     |
|                        | Diagnostic behavior        |   |  | Alarm |

| Diagnostic information |                     | Remedy instructions  | Influenced measured variables  |         |
|------------------------|---------------------|--|--|---------|
| No.                    | Short text          |  |  |         |
| 438                    | Dataset             | 1. Check data set file<br>2. Check device configuration<br>3. Up- and download new configuration | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |  |  | M       |
|                        | Diagnostic behavior |  |  | Warning |



| Diagnostic information |                     | Remedy instructions      | Influenced measured variables  |         |
|------------------------|---------------------|--------------------------|--|---------|
| No.                    | Short text          |                          |  |         |
| 453                    | Flow override       | Deactivate flow override | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |                          |  | C       |
|                        | Diagnostic behavior |                          |  | Warning |

| Diagnostic information |                     | Remedy instructions    | Influenced measured variables |       |
|------------------------|---------------------|------------------------|-------------------------------|-------|
| No.                    | Short text          |                        |                               |       |
| 482                    | FB not Auto/Cas     | Set Block in AUTO mode | -                             |       |
|                        | Status signal       |                        |                               | F     |
|                        | Diagnostic behavior |                        |                               | Alarm |

| Diagnostic information |                         | Remedy instructions   | Influenced measured variables  |       |
|------------------------|-------------------------|-----------------------|--|-------|
| No.                    | Short text              |                       |  |       |
| 484                    | Simulation failure mode | Deactivate simulation | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal           |                       |  | C     |
|                        | Diagnostic behavior     |                       |  | Alarm |

| Diagnostic information |                              | Remedy instructions   | Influenced measured variables  |         |
|------------------------|------------------------------|-----------------------|--|---------|
| No.                    | Short text                   |                       |  |         |
| 485                    | Simulation measured variable | Deactivate simulation | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal                |                       |  | C       |
|                        | Diagnostic behavior          |                       |  | Warning |

| Diagnostic information |                             | Remedy instructions   | Influenced measured variables |         |
|------------------------|-----------------------------|-----------------------|-------------------------------|---------|
| No.                    | Short text                  |                       |                               |         |
| 495                    | Simulation diagnostic event | Deactivate simulation | -                             |         |
|                        | Status signal               |                       |                               | C       |
|                        | Diagnostic behavior         |                       |                               | Warning |

| Diagnostic information |                         | Remedy instructions   | Influenced measured variables |         |
|------------------------|-------------------------|-----------------------|-------------------------------|---------|
| No.                    | Short text              |                       |                               |         |
| 497                    | Simulation block output | Deactivate simulation | -                             |         |
|                        | Status signal           |                       |                               | C       |
|                        | Diagnostic behavior     |                       |                               | Warning |

| Diagnostic information |                     | Remedy instructions                                      | Influenced measured variables |         |
|------------------------|---------------------|--|-------------------------------|---------|
| No.                    | Short text          |  |                               |         |
| 537                    | Configuration       | 1. Check IP addresses in network<br>2. Change IP address | -                             |         |
|                        | Status signal       |  |                               | F       |
|                        | Diagnostic behavior |  |                               | Warning |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 590                    | Special event 3     | Contact service     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 591                    | Special event 7     | Contact service     | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Status</li> <li>■ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 592                    | Special event 11    | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

### 12.6.4 Diagnostic of process

| Diagnostic information |                       | Remedy instructions  | Influenced measured variables |         |
|------------------------|-----------------------|--|-------------------------------|---------|
| No.                    | Short text            |  |                               |         |
| 825                    | Operating temperature | 1. Check ambient temperature<br>2. Check process temperature | Volume flow                   |         |
|                        | Status signal         |  |                               | S       |
|                        | Diagnostic behavior   |  |                               | Warning |

| Diagnostic information |                       | Remedy instructions  | Influenced measured variables  |         |
|------------------------|-----------------------|--|--|---------|
| No.                    | Short text            |  |  |         |
| 825                    | Operating temperature | 1. Check ambient temperature<br>2. Check process temperature | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal         |  |  | S       |
|                        | Diagnostic behavior   |  |  | Warning |

| Diagnostic information |                       | Remedy instructions  | Influenced measured variables  |       |
|------------------------|-----------------------|--|--|-------|
| No.                    | Short text            |  |  |       |
| 825                    | Operating temperature | 1. Check ambient temperature<br>2. Check process temperature | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal         |  |  | F     |
|                        | Diagnostic behavior   |  |  | Alarm |

| Diagnostic information |                             | Remedy instructions                            | Influenced measured variables  |         |
|------------------------|-----------------------------|--|--|---------|
| No.                    | Short text                  |  |  |         |
| 830                    | Sensor temperature too high | Reduce ambient temp. around the sensor housing | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal               |  |  | S       |
|                        | Diagnostic behavior         |  |  | Warning |

| Diagnostic information |                            | Remedy instructions                              | Influenced measured variables  |         |
|------------------------|----------------------------|--|--|---------|
| No.                    | Short text                 |  |  |         |
| 831                    | Sensor temperature too low | Increase ambient temp. around the sensor housing | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal              |  |  | S       |
|                        | Diagnostic behavior        |  |  | Warning |

| Diagnostic information |                                 | Remedy instructions        | Influenced measured variables  |         |
|------------------------|---------------------------------|----------------------------|--|---------|
| No.                    | Short text                      |                            |  |         |
| 832                    | Electronic temperature too high | Reduce ambient temperature | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal                   |                            |  | S       |
|                        | Diagnostic behavior             |                            |  | Warning |

| Diagnostic information |                                | Remedy instructions          | Influenced measured variables   |         |
|------------------------|--------------------------------|------------------------------|---|---------|
| No.                    | Short text                     |                              |   |         |
| 833                    | Electronic temperature too low | Increase ambient temperature | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal                  |                              |   | S       |
|                        | Diagnostic behavior            |                              |   | Warning |

| Diagnostic information |                              | Remedy instructions        | Influenced measured variables  |         |
|------------------------|------------------------------|----------------------------|--|---------|
| No.                    | Short text                   |                            |  |         |
| 834                    | Process temperature too high | Reduce process temperature | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal                |                            |  | S       |
|                        | Diagnostic behavior          |                            |  | Warning |

| Diagnostic information |                             | Remedy instructions          | Influenced measured variables  |         |
|------------------------|-----------------------------|------------------------------|--|---------|
| No.                    | Short text                  |                              |  |         |
| 835                    | Process temperature too low | Increase process temperature | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal               |                              |  | S       |
|                        | Diagnostic behavior         |                              |  | Warning |

| Diagnostic information |                     | Remedy instructions   | Influenced measured variables  |         |
|------------------------|---------------------|---|--|---------|
| No.                    | Short text          |   |  |         |
| 842                    | Process limit       | Low flow cut off active!<br>1. Check low flow cut off configuration | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |   |  | S       |
|                        | Diagnostic behavior |   |  | Warning |

| Diagnostic information |                     | Remedy instructions      | Influenced measured variables  |         |
|------------------------|---------------------|--------------------------|--|---------|
| No.                    | Short text          |                          |  |         |
| 843                    | Process limit       | Check process conditions | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |                          |  | S       |
|                        | Diagnostic behavior |                          |  | Warning |

| Diagnostic information |                     | Remedy instructions   | Influenced measured variables  |         |
|------------------------|---------------------|---|--|---------|
| No.                    | Short text          |   |  |         |
| 862                    | Partly filled pipe  | <ol style="list-style-type: none"> <li>1. Check for gas in process</li> <li>2. Adjust detection limits</li> </ol> | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |         |
|                        | Status signal       |   |  | S       |
|                        | Diagnostic behavior |   |  | Warning |

| Diagnostic information |                     | Remedy instructions  | Influenced measured variables   |       |
|------------------------|---------------------|--|---|-------|
| No.                    | Short text          |  |   |       |
| 882                    | Input signal        | <ol style="list-style-type: none"> <li>1. Check input configuration</li> <li>2. Check external device or process conditions</li> </ol> | <ul style="list-style-type: none"> <li>▪ Density</li> <li>▪ Mass flow</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |  |   | F     |
|                        | Diagnostic behavior |  |   | Alarm |

| Diagnostic information |                       | Remedy instructions  | Influenced measured variables  |       |
|------------------------|-----------------------|--|--|-------|
| No.                    | Short text            |  |  |       |
| 910                    | Tubes not oscillating | <ol style="list-style-type: none"> <li>1. Check electronic</li> <li>2. Inspect sensor</li> </ol> | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal         |  |  | F     |
|                        | Diagnostic behavior   |  |  | Alarm |



| Diagnostic information |                      | Remedy instructions                                   | Influenced measured variables  |         |
|------------------------|----------------------|---|--|---------|
| No.                    | Short text           |   |  |         |
| 912                    | Medium inhomogeneous | 1. Check process cond.<br>2. Increase system pressure | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Volume flow</li> </ul> |         |
|                        | Status signal        |   |  | S       |
|                        | Diagnostic behavior  |   |  | Warning |

| Diagnostic information |                     | Remedy instructions                                   | Influenced measured variables  |         |
|------------------------|---------------------|---|--|---------|
| No.                    | Short text          |   |  |         |
| 912                    | Inhomogeneous       | 1. Check process cond.<br>2. Increase system pressure | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ <b>Empty pipe detection</b> option</li> <li>■ Kinematic viscosity</li> <li>■ <b>Low flow cut off</b> option</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Volume flow</li> </ul> |         |
|                        | Status signal       |   |  | S       |
|                        | Diagnostic behavior |   |  | Warning |

| Diagnostic information |                     | Remedy instructions  | Influenced measured variables  |         |
|------------------------|---------------------|--|--|---------|
| No.                    | Short text          |  |  |         |
| 913                    | Medium unsuitable   | 1. Check process conditions<br>2. Check electronic modules or sensor | <ul style="list-style-type: none"> <li>■ Carrier mass flow</li> <li>■ Concentration</li> <li>■ Density</li> <li>■ Dynamic viscosity</li> <li>■ Kinematic viscosity</li> <li>■ Mass flow</li> <li>■ Sensor integrity</li> <li>■ Reference density</li> <li>■ Corrected volume flow</li> <li>■ Target mass flow</li> <li>■ Temp. compensated dynamic viscosity</li> <li>■ Temp. compensated kinematic viscosity</li> <li>■ Temperature</li> <li>■ Volume flow</li> </ul> |         |
|                        | Status signal       |  |  | S       |
|                        | Diagnostic behavior |  |  | Warning |

| Diagnostic information |                     | Remedy instructions                               | Influenced measured variables   |         |
|------------------------|---------------------|---|---|---------|
| No.                    | Short text          |   |   |         |
| 944                    | Monitoring failed   | Check process conditions for Heartbeat Monitoring | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temperature</li> </ul> |         |
|                        | Status signal       |   |   | S       |
|                        | Diagnostic behavior |   |   | Warning |

| Diagnostic information |                       | Remedy instructions      | Influenced measured variables |         |
|------------------------|-----------------------|--------------------------|-------------------------------|---------|
| No.                    | Short text            |                          |                               |         |
| 948                    | Tube damping too high | Check process conditions | -                             |         |
|                        | Status signal         |                          |                               | S       |
|                        | Diagnostic behavior   |                          |                               | Warning |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 990                    | Special event 4     | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 991                    | Special event 8     | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ <b>Empty pipe detection</b> option</li> <li>▪ Kinematic viscosity</li> <li>▪ <b>Low flow cut off</b> option</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Status</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

| Diagnostic information |                     | Remedy instructions | Influenced measured variables  |       |
|------------------------|---------------------|---------------------|--|-------|
| No.                    | Short text          |                     |  |       |
| 992                    | Special event 12    | Contact service     | <ul style="list-style-type: none"> <li>▪ Carrier mass flow</li> <li>▪ Concentration</li> <li>▪ Density</li> <li>▪ Dynamic viscosity</li> <li>▪ Kinematic viscosity</li> <li>▪ Mass flow</li> <li>▪ Sensor integrity</li> <li>▪ Reference density</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Temp. compensated dynamic viscosity</li> <li>▪ Temp. compensated kinematic viscosity</li> <li>▪ Temperature</li> <li>▪ Volume flow</li> </ul> |       |
|                        | Status signal       |                     |  | F     |
|                        | Diagnostic behavior |                     |  | Alarm |

## 12.7 Pending diagnostic events

The **Diagnostics** menu allows the user to view the current diagnostic event and the previous diagnostic event separately.



To call up the measures to rectify a diagnostic event:


- Via web browser → 94
- Via "FieldCare" operating tool → 95
- Via "DeviceCare" operating tool → 95




Other pending diagnostic events can be displayed in the **Diagnostic list** submenu → 124.

**Navigation**

"Diagnostics" menu

**Parameter overview with brief description**


| Parameter                   | Prerequisite                                 | Description  | User interface   |
|-----------------------------|--|--|--|
| Actual diagnostics          | A diagnostic event has occurred.             | Shows the current occurred diagnostic event along with its diagnostic information.<br> If two or more messages occur simultaneously, the message with the highest priority is shown on the display. | Symbol for diagnostic behavior, diagnostic code and short message. |
| Previous diagnostics        | Two diagnostic events have already occurred. | Shows the diagnostic event that occurred prior to the current diagnostic event along with its diagnostic information.  | Symbol for diagnostic behavior, diagnostic code and short message. |
| Operating time from restart | –  | Shows the time the device has been in operation since the last device restart.   | Days (d), hours (h), minutes (m) and seconds (s)                   |
| Operating time              | –  | Indicates how long the device has been in operation.   | Days (d), hours (h), minutes (m) and seconds (s)                   |

## 12.8 Diagnostics list

Up to 5 currently pending diagnostic events can be displayed in the **Diagnostic list** submenu along with the associated diagnostic information. If more than 5 diagnostic events are pending, the events with the highest priority are shown on the display.

**Navigation path**

Diagnostics → Diagnostic list

 To call up the measures to rectify a diagnostic event:

- Via web browser → 📄 94
- Via "FieldCare" operating tool → 📄 95
- Via "DeviceCare" operating tool → 📄 95

## 12.9 Event logbook



### 12.9.1 Reading out the event logbook

A chronological overview of the event messages that have occurred is provided in the **Events list** submenu.




**Navigation path**


**Diagnostics** menu → **Event logbook** submenu → Events list




The event history includes entries for:


- Diagnostic events →  98
- Information events →  125

In addition to the operating time when the event occurred, each event is also assigned a symbol that indicates whether the event has occurred or is finished:

- Diagnostics event
  - : Occurrence of the event
  - : End of the event
- Information event
  - : Occurrence of the event

 To call up the measures to rectify a diagnostic event:

- Via web browser →  94
- Via "FieldCare" operating tool →  95
- Via "DeviceCare" operating tool →  95

 For filtering the displayed event messages →  125

**12.9.2 Filtering the event logbook**

Using the **Filter options** parameter you can define which category of event message is displayed in the **Events list** submenu.

**Navigation path**

Diagnostics → Event logbook → Filter options

**Filter categories**

- All
- Failure (F)
- Function check (C)
- Out of specification (S)
- Maintenance required (M)
- Information (I)


**12.9.3 Overview of information events**

Unlike a diagnostic event, an information event is displayed in the event logbook only and not in the diagnostic list.


| Info number | Info name                       |
|-------------|---------------------------------|
| I1000       | ------(Device ok)               |
| I1089       | Power on                        |
| I1090       | Configuration reset             |
| I1091       | Configuration changed           |
| I1110       | Write protection switch changed |
| I1111       | Density adjust failure          |
| I1137       | Electronic changed              |
| I1151       | History reset                   |
| I1155       | Reset electronic temperature    |
| I1157       | Memory error event list         |
| I1185       | Display backup done             |
| I1186       | Restore via display done        |

| Info number | Info name                                 |
|-------------|---|
| I1187       | Settings downloaded with display          |
| I1188       | Display data cleared                      |
| I1189       | Backup compared                           |
| I1209       | Density adjustment ok                     |
| I1221       | Zero point adjust failure                 |
| I1222       | Zero point adjustment ok                  |
| I1256       | Display: access status changed            |
| I1264       | Safety sequence aborted                   |
| I1335       | Firmware changed                          |
| I1361       | Wrong web server login                    |
| I1397       | Fieldbus: access status changed           |
| I1398       | CDI: access status changed                |
| I1444       | Device verification passed                |
| I1445       | Device verification failed                |
| I1446       | Device verification active                |
| I1447       | Record application reference data         |
| I1448       | Application reference data recorded       |
| I1449       | Recording application ref. data failed    |
| I1450       | Monitoring off                            |
| I1451       | Monitoring on                             |
| I1457       | Failed: Measured error verification       |
| I1459       | Failed: I/O module verification           |
| I1460       | Failed: Sensor integrity verification     |
| I1461       | Failed: Sensor verification               |
| I1462       | Failed: Sensor electronic module verific. |

## 12.10 Resetting the measuring device

The entire device configuration or some of the configuration can be reset to a defined state with the **Device reset** parameter (→  74).

### 12.10.1 Function range of "Device reset" parameter

| Options              | Description   |
|----------------------|---|
| Cancel               | No action is executed and the user exits the parameter.   |
| To delivery settings | Every parameter for which a customer-specific default setting was ordered is reset to the customer-specific value. All other parameters are reset to the factory setting.<br> This option is not visible if no customer-specific settings have been ordered. |
| Restart device       | The restart resets every parameter with data stored in volatile memory (RAM) to the factory setting (e.g. measured value data). The device configuration remains unchanged.   |

## 12.11 Device information

The **Device information** submenu contains all parameters that display different information for device identification.

### Navigation






"Diagnostics" menu → Device information

▶ **Device information**

|                               |         |
|-------------------------------|---------|
| Device tag                    | → ⓘ 127 |
| Serial number                 | → ⓘ 127 |
| Firmware version              | → ⓘ 127 |
| Device name                   | → ⓘ 128 |
| Order code                    | → ⓘ 128 |
| Extended order code 1         | → ⓘ 128 |
| Extended order code 2         | → ⓘ 128 |
| Extended order code 3         | → ⓘ 128 |
| ENP version                   | → ⓘ 128 |
| PROFIBUS ident number         | → ⓘ 128 |
| Status PROFIBUS Master Config | → ⓘ 128 |
| IP address                    |         |
| Subnet mask                   |         |
| Default gateway               |         |

### Parameter overview with brief description




| Parameter        | Description                                      | User interface   | Factory setting |
|------------------|--|--|-----------------|
| Device tag       | Shows name of measuring point.                   | Max. 32 characters, such as letters, numbers or special characters (e.g. @, %, /). | Promass 100 DP  |
| Serial number    | Shows the serial number of the measuring device. | Max. 11-digit character string comprising letters and numbers.                     | –               |
| Firmware version | Shows the device firmware version installed.     | Character string in the format xx.yy.zz  | –               |

| Parameter                     | Description  | User interface  | Factory setting |
|-------------------------------|--|---|-----------------|
| Order code                    | Shows the device order code.<br> The order code can be found on the nameplate of the sensor and transmitter in the "Order code" field.                                    | Character string composed of letters, numbers and certain punctuation marks (e.g. /). | –               |
| Device name                   | Shows the name of the transmitter.<br> The name can be found on the nameplate of the transmitter.   | Max. 32 characters such as letters or numbers.  | –               |
| Extended order code 1         | Shows the 1st part of the extended order code.<br> The extended order code can also be found on the nameplate of the sensor and transmitter in the "Ext. ord. cd." field. | Character string  | –               |
| Extended order code 2         | Shows the 2nd part of the extended order code.<br> The extended order code can also be found on the nameplate of the sensor and transmitter in the "Ext. ord. cd." field. | Character string  | –               |
| Extended order code 3         | Shows the 3rd part of the extended order code.<br> The extended order code can also be found on the nameplate of the sensor and transmitter in the "Ext. ord. cd." field. | Character string  | –               |
| ENP version                   | Shows the version of the electronic nameplate (ENP).   | Character string  | –               |
| PROFIBUS ident number         | Displays the PROFIBUS identification number.   | 0 to FFFF   | 0x1561          |
| Status PROFIBUS Master Config | Displays the status of the PROFIBUS Master configuration.  | <ul style="list-style-type: none"> <li>■ Active</li> <li>■ Not active</li> </ul>      | –               |



## 12.12 Firmware history

| Release date | Firmware version | Order code for "Firmware version" | Firmware Changes   | Documentation type     | Documentation |
|--------------|------------------|-----------------------------------|--|------------------------|---------------|
| 09.2013      | 01.00.00         | Option 78                         | Original firmware  | Operating Instructions |               |
| 10.2014      | 01.01.zz         | Option 69                         | <ul style="list-style-type: none"> <li>▪ Integration of optional local display</li> <li>▪ New unit "Beer Barrel (BBL)"</li> <li>▪ Simulation of diagnostic events</li> </ul> | Operating Instructions |               |

-  It is possible to flash the firmware to the current version or the previous version using the service interface.
-  For the compatibility of the firmware version with the previous version, the installed device description files and operating tools, observe the information about the device in the "Manufacturer's information" document.
-  The manufacturer's information is available:
  - In the Download Area of the Endress+Hauser web site: [www.endress.com](http://www.endress.com) → Downloads
  - Specify the following details:
    - Product root, e.g. 8E1B  
The product root is the first part of the order code: see the nameplate on the device.
    - Text search: Manufacturer's information
    - Media type: Documentation – Technical Documentation

## 13 Maintenance

### 13.1 Maintenance work

No special maintenance work is required.

#### 13.1.1 Exterior cleaning

When cleaning the exterior of measuring devices, always use cleaning agents that do not attack the surface of the housing or the seals.


#### 13.1.2 Internal cleaning


Observe the following points for CIP and SIP cleaning:

- Use only cleaning agents to which the process-wetted materials are adequately resistant.
- Observe the maximum permitted medium temperature for the measuring device .

### 13.2 Measuring and test equipment


Endress+Hauser offers a variety of measuring and testing equipment, such as Netilion or device tests.

 Your Endress+Hauser Sales Center can provide detailed information on the services.

List of some of the measuring and testing equipment: →  134

### 13.3 Endress+Hauser services

Endress+Hauser offers a wide variety of services for maintenance such as recalibration, maintenance service or device tests.

 Your Endress+Hauser Sales Center can provide detailed information on the services.

## 14 Repair

### 14.1 General notes

#### 14.1.1 Repair and conversion concept

The Endress+Hauser repair and conversion concept provides for the following:

- The measuring devices have a modular design.
- Spare parts are grouped into logical kits with the associated Installation Instructions.
- Repairs are carried out by Endress+Hauser Service or by appropriately trained customers.
- Certified devices can only be converted to other certified devices by Endress+Hauser Service or at the factory.

#### 14.1.2 Notes for repair and conversion



For repair and conversion of a measuring device, observe the following notes:

- ▶ Use only original Endress+Hauser spare parts.
- ▶ Carry out the repair according to the Installation Instructions.
- ▶ Observe the applicable standards, federal/national regulations, Ex documentation (XA) and certificates.
- ▶ Document all repairs and conversions and enter the details in Netilion Analytics.

### 14.2 Spare parts

*Device Viewer* ([www.endress.com/deviceviewer](http://www.endress.com/deviceviewer)):

All the spare parts for the measuring device, along with the order code, are listed here and can be ordered. If available, users can also download the associated Installation Instructions.

-  Measuring device serial number:
  - Is located on the nameplate of the device.
  - Can be read out via the **Serial number** parameter (→  127) in the **Device information** submenu.

### 14.3 Endress+Hauser services

Endress+Hauser offers a wide range of services.

-  Your Endress+Hauser Sales Center can provide detailed information on the services.

### 14.4 Return

The requirements for safe device return can vary depending on the device type and national legislation.

1. Refer to the web page for information:  
<https://www.endress.com/support/return-material>  
↳ Select the region.
2. If returning the device, pack the device in such a way that it is reliably protected against impact and external influences. The original packaging offers the best protection.

## 14.5 Disposal



If required by the Directive 2012/19/EU on waste electrical and electronic equipment (WEEE), the product is marked with the depicted symbol in order to minimize the disposal of WEEE as unsorted municipal waste. Do not dispose of products bearing this marking as unsorted municipal waste. Instead, return them to the manufacturer for disposal under the applicable conditions.

### 14.5.1 Removing the measuring device

1. Switch off the device.

#### WARNING

##### **Danger to persons from process conditions!**

- ▶ Beware of hazardous process conditions such as pressure in the measuring device, high temperatures or aggressive media.

2. Carry out the mounting and connection steps from the "Mounting the measuring device" and "Connecting the measuring device" sections in reverse order. Observe the safety instructions.

### 14.5.2 Disposing of the measuring device

#### WARNING

##### **Danger to personnel and environment from fluids that are hazardous to health.**

- ▶ Ensure that the measuring device and all cavities are free of fluid residues that are hazardous to health or the environment, e.g. substances that have permeated into crevices or diffused through plastic.

Observe the following notes during disposal:



- ▶ Observe valid federal/national regulations.
- ▶ Ensure proper separation and reuse of the device components.

## 15 Accessories




Various accessories, which can be ordered with the device or subsequently from Endress+Hauser, are available for the device. Detailed information on the order code in question is available from your local Endress+Hauser sales center or on the product page of the Endress+Hauser website: [www.endress.com](http://www.endress.com).



### 15.1 Device-specific accessories

#### 15.1.1 For the sensor



| Accessories    | Description  |
|----------------|--|
| Heating jacket | <p>Is used to stabilize the temperature of the fluids in the sensor. Water, water vapor and other non-corrosive liquids are permitted for use as fluids.</p> <p> If using oil as a heating medium, please consult with Endress+Hauser.</p> <p>Heating jackets cannot be used with sensors fitted with a rupture disk.</p> <ul style="list-style-type: none"> <li>▪ If ordered together with the measuring device:           <ul style="list-style-type: none"> <li>Order code for "Accessory enclosed"</li> <li>▪ Option RB "Heating jacket, G 1/2" female thread"</li> <li>▪ Option RC "Heating jacket, G 3/4" female thread"</li> <li>▪ Option RD "Heating jacket, NPT 1/2" female thread"</li> <li>▪ Option RE "Heating jacket, NPT 3/4" female thread"</li> </ul> </li> <li>▪ If ordered subsequently:           <ul style="list-style-type: none"> <li>Use the order code with the product root DK8003.</li> </ul> </li> </ul> <p> Special Documentation SD02151D</p> |

### 15.2 Communication-specific accessories




| Accessories       | Description  |
|-------------------|--|
| Commubox FXA291   | <p>Connects Endress+Hauser field devices with a CDI interface (= Endress+Hauser Common Data Interface) and the USB port of a computer or laptop.</p> <p> Technical Information TI00405C</p>   |
| Fieldgate FXA42   | <p>Transmission of the measured values of connected 4 to 20 mA analog measuring instruments, as well as digital measuring instruments</p> <p> <ul style="list-style-type: none"> <li>▪ Technical Information TI01297S</li> <li>▪ Operating Instructions BA01778S</li> <li>▪ Product page: <a href="http://www.endress.com/fxa42">www.endress.com/fxa42</a></li> </ul> </p>  |
| Field Xpert SMT50 | <p>The Field Xpert SMT50 tablet PC for device configuration enables mobile plant asset management in the non-hazardous areas. It is suitable for commissioning and maintenance staff to manage field instruments with a digital communication interface and to record progress.</p> <p>This tablet PC is designed as an all-in-one solution with a preinstalled driver library and is an easy-to-use, touch-sensitive tool which can be used to manage the field instruments throughout their entire life cycle.</p> <p> <ul style="list-style-type: none"> <li>▪ Technical Information TI01555S</li> <li>▪ Operating Instructions BA02053S</li> <li>▪ Product page: <a href="http://www.endress.com/smt50">www.endress.com/smt50</a></li> </ul> </p> |

|                   |  |
|-------------------|--|
| Field Xpert SMT70 | <p>The Field Xpert SMT70 tablet PC for device configuration enables mobile plant asset management in hazardous and non-hazardous areas. It is suitable for commissioning and maintenance staff to manage field instruments with a digital communication interface and to record progress.</p> <p>This tablet PC is designed as an all-in-one solution with a preinstalled driver library and is an easy-to-use, touch-sensitive tool which can be used to manage the field instruments throughout their entire life cycle.</p> <ul style="list-style-type: none"> <li> ■ Technical Information TI01342S</li> <li>■ Operating Instructions BA01709S</li> <li>■ Product page: <a href="http://www.endress.com/smt70">www.endress.com/smt70</a></li> </ul> |
| Field Xpert SMT77 | <p>The Field Xpert SMT77 tablet PC for device configuration enables mobile plant asset management in areas categorized as Ex Zone 1.</p> <ul style="list-style-type: none"> <li> ■ Technical Information TI01418S</li> <li>■ Operating Instructions BA01923S</li> <li>■ Product page: <a href="http://www.endress.com/smt77">www.endress.com/smt77</a></li> </ul>   |

### 15.3 Service-specific accessories

| Accessories | Description   |
|-------------|---|
| Applicator  | <p>Software for selecting and sizing Endress+Hauser measuring instruments:</p> <ul style="list-style-type: none"> <li>■ Choice of measuring instruments for industrial requirements</li> <li>■ Calculation of all the necessary data for identifying the optimum flowmeter: e.g. nominal diameter, pressure loss, flow velocity and measurement accuracy.</li> <li>■ Graphic display of the calculation results</li> <li>■ Determination of the partial order code, administration, documentation and access to all project-related data and parameters over the entire life cycle of a project.</li> </ul> <p>Applicator is available:<br/>Via the Internet: <a href="https://portal.endress.com/webapp/applicator">https://portal.endress.com/webapp/applicator</a></p> |
| Netilion    | <p>IloT ecosystem: Unlock knowledge</p> <p>With the Netilion IloT ecosystem, Endress+Hauser allows you to optimize your plant performance, digitize workflows, share knowledge, and enhance collaboration.</p> <p>Drawing upon decades of experience in process automation, Endress+Hauser offers the process industry an IloT ecosystem designed to effortlessly extract insights from data. These insights allow process optimization, leading to increased plant availability, efficiency, and reliability - ultimately resulting in a more profitable plant.</p> <p><a href="http://www.netilion.endress.com">www.netilion.endress.com</a></p>  |
| FieldCare   | <p>FDT-based plant asset management tool from Endress+Hauser.</p> <p>It can configure all intelligent field units in your system and helps you manage them. By using the status information, it is also a simple but effective way of checking their status and condition.</p> <ul style="list-style-type: none"> <li> Operating Instructions BA00027S and BA00059S</li> </ul>   |
| DeviceCare  | <p>Tool to connect and configure Endress+Hauser field devices.</p> <ul style="list-style-type: none"> <li> Innovation brochure IN01047S</li> </ul>   |

## 15.4 System components

| Accessories                      | Description  |
|----------------------------------|--|
| Memograph M graphic data manager | <p>The Memograph M graphic data manager provides information on all the relevant measured variables. Measured values are recorded correctly, limit values are monitored and measuring points analyzed. The data are stored in the 256 MB internal memory and also on a SD card or USB stick.</p> <ul style="list-style-type: none"> <li> ■ Technical Information TI00133R</li> <li> ■ Operating Instructions BA00247R</li> </ul> |
| iTEMP                            | <p>The temperature transmitters can be used in all applications and are suitable for the measurement of gases, steam and liquids. They can be used to read in the medium temperature.</p> <ul style="list-style-type: none"> <li> "Fields of Activity" document FA00006T</li> </ul>   |

## 16 Technical data

### 16.1 Application


The measuring device is intended only for the flow measurement of liquids and gases.

Depending on the version ordered, the measuring device can also measure potentially explosive, flammable, poisonous and oxidizing media.

To ensure that the device remains in proper operating condition for its service life, use the measuring device only for media against which the process-wetted materials are sufficiently resistant.

### 16.2 Function and system design

---

|                     |  |
|---------------------|--|
| Measuring principle | Mass flow measurement based on the Coriolis measuring principle  |
| Measuring system    | <p>The device consists of a transmitter and a sensor.</p> <p>The device is available as a compact version:<br/>The transmitter and sensor form a mechanical unit.</p> <p>For information on the structure of the measuring instrument →  12</p> |

---



## 16.3 Input

Measured variable

### Direct measured variables

- Mass flow
- Density
- Temperature

### Calculated measured variables

- Volume flow
- Corrected volume flow
- Reference density

Measuring range

### Measuring range for liquids

| DN   |                | Measuring range full scale values $\dot{m}_{\min(F)}$ to $\dot{m}_{\max(F)}$ |            |
|------|----------------|--|------------|
| [mm] | [in]           | [kg/h]   | [lb/min]   |
| 8    | $\frac{3}{8}$  | 0 to 2 000   | 0 to 73.50 |
| 15   | $\frac{1}{2}$  | 0 to 6 500   | 0 to 238.9 |
| 25   | 1              | 0 to 18 000  | 0 to 661.5 |
| 40   | $1\frac{1}{2}$ | 0 to 45 000  | 0 to 1 654 |
| 50   | 2              | 0 to 70 000  | 0 to 2 573 |
| 80   | 3              | 0 to 180 000   | 0 to 6 615 |

### Measuring range for gases

The full scale value depends on the density and the sound velocity of the gas used. The full scale value can be calculated with the following formulas:

$$\dot{m}_{\max(G)} = \text{Minimum of } (\dot{m}_{\max(F)} \cdot \rho_G : x) \text{ and } (\rho_G \cdot (c_G/2) \cdot d_i^2 \cdot (\pi/4) \cdot 3600 \cdot n)$$

|   |   |
|---|---|
| $\dot{m}_{\max(G)}$                     | Maximum full scale value for gas [kg/h]                           |
| $\dot{m}_{\max(F)}$                     | Maximum full scale value for liquid [kg/h]                        |
| $\dot{m}_{\max(G)} < \dot{m}_{\max(F)}$ | $\dot{m}_{\max(G)}$ can never be greater than $\dot{m}_{\max(F)}$ |
| $\rho_G$                                | Gas density in [kg/m <sup>3</sup> ] at operating conditions       |
| x                                       | Limitation constant for max. gas flow [kg/m <sup>3</sup> ]        |
| $c_G$                                   | Sound velocity (gas) [m/s]  |
| $d_i$                                   | Measuring tube internal diameter [m]                              |
| $\pi$                                   | Pi  |
| n = 2                                   | Number of measuring tubes   |



| DN   |               | x                    |
|------|---------------|----------------------|
| [mm] | [in]          | [kg/m <sup>3</sup> ] |
| 8    | $\frac{3}{8}$ | 85                   |
| 15   | $\frac{1}{2}$ | 110                  |
| 25   | 1             | 125                  |

| DN   |      | x                    |
|------|------|----------------------|
| [mm] | [in] | [kg/m <sup>3</sup> ] |
| 40   | 1½   | 125                  |
| 50   | 2    | 125                  |
| 80   | 3    | 155                  |

If calculating the full scale value using the two formulas:

1. Calculate the full scale value with both formulas.
2. The smaller value is the value that must be used.

**Recommended measuring range**

 Flow limit →  147

Operable flow range

Over 1000 : 1.

Flow rates above the preset full scale value do not override the electronics unit, with the result that the totalizer values are registered correctly.

Input signal

**External measured values**

To increase the measurement accuracy of certain measured variables or to calculate the corrected volume flow for gases, the automation system can continuously write different measured values to the measuring instrument:

- Operating pressure to increase measurement accuracy (Endress+Hauser recommends the use of a pressure measuring instrument for absolute pressure, e.g. Cerabar M or Cerabar S)
- Medium temperature to increase measurement accuracy (e.g. iTEMP)
- Reference density for calculating the corrected volume flow for gases

 Various pressure transmitters and temperature measuring instruments can be ordered from Endress+Hauser: see "Accessories" section →  135

It is recommended to read in external measured values to calculate the following measured variables:

- Mass flow
- Corrected volume flow

*Digital communication*

The measured values are written by the automation system via PROFIBUS DP.

## 16.4 Output

Output signal

**PROFIBUS DP**

|                 |                      |
|-----------------|----------------------|
| Signal encoding | NRZ code             |
| Data transfer   | 9.6 kBaud...12 MBaud |

Signal on alarm

Depending on the interface, failure information is displayed as follows.

**PROFIBUS DP**

|                                  |   |
|----------------------------------|---|
| <b>Status and alarm messages</b> | Diagnostics in accordance with PROFIBUS PA Profile 3.02 |
|----------------------------------|---|

**Local display**

|                           |   |
|---------------------------|---|
| <b>Plain text display</b> | With information on cause and remedial measures |
| <b>Backlight</b>          | Red backlighting indicates a device error.      |

 Status signal as per NAMUR recommendation NE 107

**Interface/protocol**


- Via digital communication:  
PROFIBUS DP
- Via service interface  
CDI-RJ45 service interface

|                           |   |
|---------------------------|---|
| <b>Plain text display</b> | With information on cause and remedial measures |
|---------------------------|---|

**Web browser**

|                           |   |
|---------------------------|---|
| <b>Plain text display</b> | With information on cause and remedial measures |
|---------------------------|---|

**Light emitting diodes (LED)**

|                           |  |
|---------------------------|--|
| <b>Status information</b> | <p>Status indicated by various light emitting diodes</p> <p>The following information is displayed depending on the device version:</p> <ul style="list-style-type: none"> <li>▪ Supply voltage active</li> <li>▪ Data transmission active</li> <li>▪ Device alarm/error has occurred</li> </ul> <p> Diagnostic information via light emitting diodes</p> |
|---------------------------|--|

Low flow cut off                      The switch points for low flow cut off are user-selectable.

Galvanic isolation                      The following connections are galvanically isolated from each other:

- Outputs
- Power supply

Protocol-specific data                      **protocol-specific data**

|  |   |
|--|---|
| <b>Manufacturer ID</b>                         | 0x11  |
| <b>Ident number</b>                            | 0x1561  |
| <b>Profile version</b>                         | 3.02  |
| <b>Device description files (GSD, DTM, DD)</b> | <p>Information and files available at:</p> <ul style="list-style-type: none"> <li>▪ <a href="https://www.endress.com/download">https://www.endress.com/download</a><br/>On the device product page: PRODUCTS → Product Finder → Links</li> <li>▪ <a href="https://www.profibus.com">https://www.profibus.com</a></li> </ul> |

|  |  |
|--|--|
| <p><b>Output values</b><br/>(from measuring instrument to automation system)</p> | <p><b>Analog input 1 to 8</b></p> <ul style="list-style-type: none"> <li>▪ Mass flow</li> <li>▪ Volume flow</li> <li>▪ Corrected volume flow</li> <li>▪ Target mass flow</li> <li>▪ Carrier mass flow</li> <li>▪ Density</li> <li>▪ Reference density</li> <li>▪ Concentration</li> <li>▪ Temperature</li> <li>▪ Carrier pipe temperature</li> <li>▪ Electronics temperature</li> <li>▪ Oscillation frequency</li> <li>▪ Oscillation amplitude</li> <li>▪ Frequency fluctuation</li> <li>▪ Oscillation damping</li> <li>▪ Tube damping fluctuation</li> <li>▪ Signal asymmetry</li> <li>▪ Exciter current</li> </ul> <p><b>Digital input 1 to 2</b></p> <ul style="list-style-type: none"> <li>▪ Partially filled pipe detection</li> <li>▪ Low flow cut off</li> </ul> <p><b>Totalizer 1 to 3</b></p> <ul style="list-style-type: none"> <li>▪ Mass flow</li> <li>▪ Volume flow</li> <li>▪ Corrected volume flow</li> </ul> |
| <p><b>Input values</b><br/>(from automation system to measuring instrument)</p>  | <p><b>Analog output 1 to 3 (fixed assignment)</b></p> <ul style="list-style-type: none"> <li>▪ Pressure</li> <li>▪ Temperature</li> <li>▪ Reference density</li> </ul> <p><b>Digital output 1 to 3 (fixed assignment)</b></p> <ul style="list-style-type: none"> <li>▪ Digital output 1: switch positive zero return on/off</li> <li>▪ Digital output 2: perform zero adjustment</li> <li>▪ Digital output 3: switch switch output on/off</li> </ul> <p><b>Totalizer 1 to 3</b></p> <ul style="list-style-type: none"> <li>▪ Totalize</li> <li>▪ Reset and hold</li> <li>▪ Preset and hold</li> <li>▪ Stop</li> <li>▪ Operating mode configuration:             <ul style="list-style-type: none"> <li>▪ Net flow total</li> <li>▪ Forward flow total</li> <li>▪ Reverse flow total</li> </ul> </li> </ul>   |
| <p><b>Supported functions</b></p>  | <ul style="list-style-type: none"> <li>▪ Identification &amp; maintenance<br/>Straightforward device identification on the part of the control system and nameplate</li> <li>▪ PROFIBUS upload/download<br/>Reading and writing parameters is up to ten times faster with PROFIBUS upload/download.</li> <li>▪ Condensed status<br/>Straightforward and self-explanatory diagnostic information by categorizing diagnostic messages that occur</li> </ul>  |
| <p><b>Configuration of the device address</b></p>                                | <ul style="list-style-type: none"> <li>▪ DIP switches on the I/O electronics module</li> <li>▪ Via operating tools (e.g. FieldCare)</li> </ul>   |

## 16.5 Power supply

Terminal assignment

- → 26
- 

Supply voltage

The power unit must be tested to ensure it meets safety requirements (e.g. PELV, SELV).

**Transmitter**

DC 20 to 30 V

Power consumption

**Transmitter**

| Order code for "Output" | Maximum Power consumption |
|-------------------------|---------------------------|
| Option L: PROFIBUS DP   | 3.5 W                     |

Current consumption

**Transmitter**

| Order code for "Output" | Maximum Current consumption | Maximum switch-on current |
|-------------------------|-----------------------------|---------------------------|
| Option L: PROFIBUS DP   | 145 mA                      | 18 A (< 0.125 ms)         |

Device fuse

Fine-wire fuse (slow-blow) T2A

Power supply failure

- Totalizers stop at the last value measured.
- Depending on the device version, the configuration is retained in the device memory or in the pluggable data memory (HistoROM DAT).
- Error messages (incl. total operated hours) are stored.

Electrical connection

→  27

Potential equalization

→  29

Terminals

**Transmitter**Spring terminals for wire cross-sections 0.5 to 2.5 mm<sup>2</sup> (20 to 14 AWG)

Cable entries

- Cable gland: M20 × 1.5 with cable Ø 6 to 12 mm (0.24 to 0.47 in)
- Thread for cable entry:
  - M20
  - G ½"
  - NPT ½"


Cable specification

→  25

## 16.6 Performance characteristics

Reference operating conditions

- Error limits based on ISO 11631
- Water
  - +15 to +45 °C (+59 to +113 °F)
  - 2 to 6 bar (29 to 87 psi)
- Data as indicated in the calibration protocol
- Accuracy based on accredited calibration rigs according to ISO 17025

To obtain measured errors, use the *Applicator* sizing tool →  134

Maximum measurement error

o.r. = of reading; 1 g/cm<sup>3</sup> = 1 kg/l; T = medium temperature

**Base accuracy**

 Design fundamentals →  144

*Mass flow and volume flow (liquids)*

- ±0.15 % o.r.
- ±0.10 % o.r. (order code for "Calibration flow", option A, B, C, for mass flow)
- ±0.25 % o.r.

*Mass flow (gases)*

±0.50 % o.r.

*Density (liquids)*

| Under reference conditions<br>[g/cm <sup>3</sup> ] | Standard density calibration<br>[g/cm <sup>3</sup> ] |
|--|--|
| ±0.0005  | ±0.002   |

*Temperature*

±0.5 °C ± 0.005 · T °C (±0.9 °F ± 0.003 · (T - 32) °F)

**Zero point stability**

| DN   |       | Zero point stability |          |
|------|-------|----------------------|----------|
| [mm] | [in]  | [kg/h]               | [lb/min] |
| 8    | 3/8   | 0.20                 | 0.007    |
| 15   | 1/2   | 0.65                 | 0.024    |
| 25   | 1     | 1.80                 | 0.066    |
| 40   | 1 1/2 | 4.50                 | 0.165    |
| 50   | 2     | 7.0                  | 0.257    |
| 80   | 3     | 18.0                 | 0.6615   |

**Flow values**

Flow values as turndown parameters depending on nominal diameter.


*SI units*

| DN<br>[mm] | 1:1     | 1:10   | 1:20   | 1:50   | 1:100  | 1:500  |
|------------|---------|--------|--------|--------|--------|--------|
|            | [kg/h]  | [kg/h] | [kg/h] | [kg/h] | [kg/h] | [kg/h] |
| 8          | 2 000   | 200    | 100    | 40     | 20     | 4      |
| 15         | 6 500   | 650    | 325    | 130    | 65     | 13     |
| 25         | 18 000  | 1 800  | 900    | 360    | 180    | 36     |
| 40         | 45 000  | 4 500  | 2 250  | 900    | 450    | 90     |
| 50         | 70 000  | 7 000  | 3 500  | 1 400  | 700    | 140    |
| 80         | 180 000 | 18 000 | 9 000  | 3 600  | 1 800  | 360    |

*US units*

| DN            | 1:1      | 1:10     | 1:20     | 1:50     | 1:100    | 1:500    |
|---------------|----------|----------|----------|----------|----------|----------|
| [inch]        | [lb/min] | [lb/min] | [lb/min] | [lb/min] | [lb/min] | [lb/min] |
| $\frac{3}{8}$ | 73.50    | 7.350    | 3.675    | 1.470    | 0.735    | 0.147    |
| $\frac{1}{2}$ | 238.9    | 23.89    | 11.95    | 4.778    | 2.389    | 0.478    |
| 1             | 661.5    | 66.15    | 33.08    | 13.23    | 6.615    | 1.323    |
| 1½            | 1654     | 165.4    | 82.70    | 33.08    | 16.54    | 3.308    |
| 2             | 2573     | 257.3    | 128.7    | 51.46    | 25.73    | 5.146    |
| 3             | 6615     | 661.5    | 330.8    | 132.3    | 66.15    | 13.23    |

**Accuracy of outputs**

 The output accuracy must be factored into the measurement error if analog outputs are used; but can be ignored for fieldbus outputs (e.g. Modbus RS485, EtherNet/IP).

The outputs have the following base accuracy specifications.

---

Repeatability o.r. = of reading;  $1 \text{ g/cm}^3 = 1 \text{ kg/l}$ ; T = medium temperature

**Base repeatability**

 Design fundamentals →  144

*Mass flow and volume flow (liquids)*

$\pm 0.075 \%$  o.r.

$\pm 0.05 \%$  o.r. (calibration option, for mass flow)

*Mass flow (gases)*

$\pm 0.25 \%$  o.r. (up to a Mach number of 0.2)

*Density (liquids)*

$\pm 0.00025 \text{ g/cm}^3$

*Temperature*

$\pm 0.25 \text{ }^\circ\text{C} \pm 0.0025 \cdot T \text{ }^\circ\text{C}$  ( $\pm 0.45 \text{ }^\circ\text{F} \pm 0.0015 \cdot (T-32) \text{ }^\circ\text{F}$ )

---

Response time The response time depends on the configuration (damping).

---

Influence of medium temperature

**Mass flow**


o.f.s. = of full scale value

If there is a difference between the temperature during zero adjustment and the process temperature, the additional measurement error of the sensors is typically  $\pm 0.0002 \%$  o.f.s./ $^\circ\text{C}$  ( $\pm 0.0001 \%$  o. f.s./ $^\circ\text{F}$ ).

The influence is reduced when the zero adjustment is performed at process temperature.

**Density**

If there is a difference between the density calibration temperature and the process temperature, the measurement error of the sensors is typically  $\pm 0.0001 \text{ g/cm}^3/^\circ\text{C}$  ( $\pm 0.00005 \text{ g/cm}^3/^\circ\text{F}$ ). Field density adjustment is possible.



18 Field density adjustment, for example at +20 °C (+68 °F)

**Temperature**

$$\pm 0.005 \cdot T \text{ } ^\circ\text{C} (\pm 0.005 \cdot (T - 32) \text{ } ^\circ\text{F})$$

**Influence of medium pressure**

The following shows how the process pressure (gauge pressure) affects the accuracy of the mass flow.

o.r. = of reading



It is possible to compensate for the effect by:

- Reading in the current pressure measured value via the current input or a digital input.
- Specifying a fixed value for the pressure in the device parameters.



Operating Instructions .

| DN   |       | [% o.r./bar] | [% o.r./psi] |
|------|-------|--------------|--------------|
| [mm] | [in]  |              |              |
| 8    | 3/8   | no influence |              |
| 15   | 1/2   | no influence |              |
| 25   | 1     | no influence |              |
| 40   | 1 1/2 | no influence |              |
| 50   | 2     | -0.009       | -0.0006      |
| 80   | 3     | -0.020       | -0.0014      |

**Design fundamentals**

o.r. = of reading, o.f.s. = of full scale value

BaseAccu = base accuracy in % o.r., BaseRepeat = base repeatability in % o.r.

MeasValue = measured value; ZeroPoint = zero point stability

Calculation of the maximum measured error as a function of the flow rate


| Flow rate  | Maximum measured error in % o.r.   |
|--|--|
| $\geq \frac{\text{ZeroPoint}}{\text{BaseAccu}} \cdot 100$<br><small>A0021332</small> | $\pm \text{BaseAccu}$<br><small>A0021339</small>                                     |
| $< \frac{\text{ZeroPoint}}{\text{BaseAccu}} \cdot 100$<br><small>A0021333</small>    | $\pm \frac{\text{ZeroPoint}}{\text{MeasValue}} \cdot 100$<br><small>A0021334</small> |



Calculation of the maximum repeatability as a function of the flow rate

| Flow rate  | Maximum repeatability in % o.r.  |
|--|--|
| $\geq \frac{1/2 \cdot \text{ZeroPoint}}{\text{BaseRepeat}} \cdot 100$<br><small>A0021335</small> | $\pm \text{BaseRepeat}$<br><small>A0021340</small>   |
| $< \frac{1/2 \cdot \text{ZeroPoint}}{\text{BaseRepeat}} \cdot 100$<br><small>A0021336</small>    | $\pm 1/2 \cdot \frac{\text{ZeroPoint}}{\text{MeasValue}} \cdot 100$<br><small>A0021337</small> |

**Example of maximum measurement error**



E Maximum measurement error in % o.r. (example)  
 Q Flow rate in % of maximum full scale value



## 16.7 Mounting

Mounting requirements → 18

## 16.8 Environment

Ambient temperature range → 20 → 20

**Temperature tables**




-  Observe the interdependencies between the permitted ambient and fluid temperatures when operating the device in hazardous areas.
-  For detailed information on the temperature tables, see the separate document entitled "Safety Instructions" (XA) for the device.

Storage temperature -40 to +80 °C (-40 to +176 °F), preferably at +20 °C (+68 °F)



Climate class DIN EN 60068-2-38 (test Z/AD)

Degree of protection **Transmitter and sensor**

- Standard: IP66/67, Type 4X enclosure, suitable for pollution degree 4
- With the order code for "Sensor options", option CM: IP69 can also be ordered
- When the housing is open: IP20, Type 1 enclosure, suitable for pollution degree 2
- Display module: IP20, Type 1 enclosure, suitable for pollution degree 2

|                                     |  |
|-------------------------------------|--|
| Shock and vibration resistance      | <p><b>Vibration sinusoidal, in accordance with IEC 60068-2-6</b></p> <ul style="list-style-type: none"> <li>■ 2 to 8.4 Hz, 3.5 mm peak</li> <li>■ 8.4 to 2 000 Hz, 1 g peak</li> </ul> <p><b>Vibration broad-band random, according to IEC 60068-2-64</b></p> <ul style="list-style-type: none"> <li>■ 10 to 200 Hz, 0.003 g<sup>2</sup>/Hz</li> <li>■ 200 to 2 000 Hz, 0.001 g<sup>2</sup>/Hz</li> <li>■ Total: 1.54 g rms</li> </ul> <p><b>Shock half-sine, according to IEC 60068-2-27</b></p> <p>6 ms 30 g</p> <p><b>Rough handling shocks according to IEC 60068-2-31</b></p>   |
| Internal cleaning                   | <ul style="list-style-type: none"> <li>■ CIP cleaning</li> <li>■ SIP cleaning</li> </ul> <p><b>Options</b></p> <p>Oil- and grease-free version for wetted parts, without declaration<br/>Order code for "Service", option HA <sup>3)</sup></p>   |
| Electromagnetic compatibility (EMC) | <ul style="list-style-type: none"> <li>■ As per IEC/EN 61326 and NAMUR Recommendation 21 (NE 21)</li> <li>■ As per IEC/EN 61000-6-2 and IEC/EN 61000-6-4</li> <li>■ Complies with emission limits for industry as per EN 55011 (Class A)</li> <li>■ Device version with PROFIBUS DP: Complies with emission limits for industry as per EN 50170 Volume 2, IEC 61784</li> </ul> <p> The following applies for PROFIBUS DP: If baud rates &gt; 1.5 Mbaud, an EMC cable entry must be used and the cable shield must continue as far as the terminal wherever possible.</p> <p> Details are provided in the Declaration of Conformity.</p> <p> This unit is not intended for use in residential environments and cannot guarantee adequate protection of the radio reception in such environments.</p> |

## 16.9 Process

|                              |  |
|------------------------------|--|
| Medium temperature range     | -40 to +150 °C (-40 to +302 °F)  |
| Pressure-temperature ratings |  For an overview of the pressure-temperature ratings for the process connections, see the Technical Information   |
| Sensor housing               | <p>The sensor housing is filled with dry nitrogen gas and protects the electronics and mechanics inside.</p> <p> If a measuring tube fails (e.g. due to process characteristics like corrosive or abrasive fluids), the fluid will initially be contained by the sensor housing.</p> <p>In the event of a tube failure, the pressure level inside the sensor housing will rise according to the operating process pressure. If the user judges that the sensor housing burst pressure does not provide an adequate safety margin, the device can be fitted with a</p> |

3) The cleaning refers to the measuring instrument only. Any accessories supplied are not cleaned.

rupture disk. This prevents excessively high pressure from forming inside the sensor housing. Therefore, the use of a rupture disk is strongly recommended in applications involving high gas pressures, and particularly in applications in which the process pressure is greater than 2/3 of the sensor housing burst pressure.

### Burst pressure of the sensor housing

If the device is fitted with a rupture disk (order code for "Sensor option", option CA "Rupture disk"), the rupture disk trigger pressure is decisive.

The sensor housing burst pressure refers to a typical internal pressure which is reached prior to mechanical failure of the sensor housing and which was determined during type testing. The corresponding type test declaration can be ordered with the device (order code for "Additional approval", option LN "Sensor housing burst pressure, type test").

| DN   |                | Sensor housing burst pressure |       |
|------|----------------|-------------------------------|-------|
| [mm] | [in]           | [bar]                         | [psi] |
| 8    | $\frac{3}{8}$  | 250                           | 3 620 |
| 15   | $\frac{1}{2}$  | 250                           | 3 620 |
| 25   | 1              | 250                           | 3 620 |
| 40   | $1\frac{1}{2}$ | 200                           | 2 900 |
| 50   | 2              | 180                           | 2 610 |
| 80   | 3              | 120                           | 1 740 |



For information on the dimensions: see the "Mechanical construction" section of the "Technical Information" document

### Rupture disk

To increase the level of safety, a device version with a rupture disk with a trigger pressure of 10 to 15 bar (145 to 217.5 psi) can be used (order code for "Sensor option", option CA "rupture disk").

The use of rupture disks cannot be combined with the separately available heating jacket.

### Flow limit

Select the nominal diameter by optimizing between the required flow range and permissible pressure loss.



For an overview of the full scale values for the measuring range, see the "Measuring range" section → 137

- The minimum recommended full scale value is approx. 1/20 of the maximum full scale value
- In most applications, 20 to 50 % of the maximum full scale value can be considered ideal
- A low full scale value must be selected for abrasive media (such as liquids with entrained solids): flow velocity < 1 m/s (< 3 ft/s).
- For gas measurement the following rules apply:
  - The flow velocity in the measuring tubes should not exceed half the sound velocity (0.5 Mach).
  - The maximum mass flow depends on the density of the gas: formula



To calculate the flow limit, use the *Applicator* sizing tool → 134

### Pressure loss



To calculate the pressure loss, use the *Applicator* sizing tool → 134

### System pressure

→ 20

## 16.10 Mechanical construction

### Design, dimensions



For the dimensions and installation lengths of the device, see the "Technical Information" document, "Mechanical construction" section

### Weight

All values (weight exclusive of packaging material) refer to devices with EN/DIN PN 40 flanges. Weight specifications including transmitter: order code for "Housing", option A "Compact, aluminum coated".

#### Weight in SI units

| DN [mm] | Weight [kg] |
|---------|-------------|
| 8       | 4.5         |
| 15      | 4.8         |
| 25      | 6.4         |
| 40      | 10.4        |
| 50      | 15.5        |
| 80      | 29          |

#### Weight in US units


| DN [in] | Weight [lbs] |
|---------|--------------|
| 3/8     | 10           |
| 1/2     | 11           |
| 1       | 14           |
| 1 1/2   | 23           |
| 2       | 34           |
| 3       | 64           |

### Materials

#### Transmitter housing

- Order code for "Housing", option **A** "Compact, aluminum coated":  
Aluminum, AlSi10Mg, coated
- Order code for "Housing", option **B** "Compact, hygienic, stainless":  
Hygienic version, stainless steel 1.4301 (304)
- Order code for "Housing", option **C** "Ultra-compact, hygienic, stainless":  
Hygienic version, stainless steel 1.4301 (304)
- Window material for optional local display (→ 151):
  - For order code for "Housing", option **A**: glass
  - For order code for "Housing", option **B** and **C**: plastic

**Cable entries/cable glands**



19 Possible cable entries/cable glands

- 1 Female thread M20 × 1.5
- 2 Cable gland M20 × 1.5
- 3 Adapter for cable entry with female thread G ½" or NPT ½"

Order code for "Housing", option A "Compact, aluminum, coated"

The various cable entries are suitable for hazardous and non-hazardous areas.

| Cable entry/cable gland                             | Material            |
|---|---------------------|
| Cable gland M20 × 1.5                               | Nickel-plated brass |
| Adapter for cable entry with internal thread G ½"   |                     |
| Adapter for cable entry with internal thread NPT ½" |                     |

Order code for "Housing", option B "Compact, hygienic, stainless"

The various cable entries are suitable for hazardous and non-hazardous areas.

| Cable entry/cable gland                             | Material                       |
|---|--------------------------------|
| Cable gland M20 × 1.5                               | Stainless steel, 1.4404 (316L) |
| Adapter for cable entry with internal thread G ½"   |                                |
| Adapter for cable entry with internal thread NPT ½" |                                |

**Device plug**

| Electrical connection | Material  |
|-----------------------|---|
| Plug M12x1            | <ul style="list-style-type: none"> <li>▪ Socket: Stainless steel, 1.4404 (316L)</li> <li>▪ Contact housing: Polyamide</li> <li>▪ Contacts: Gold-plated brass</li> </ul> |

**Sensor housing**



- Acid and alkali-resistant outer surface
- Stainless steel 1.4301 (304)

**Measuring tubes**

Stainless steel, 1.4539 (904L); manifold: stainless steel, 1.4404 (316L)

**Process connections**

- Flanges according to EN 1092-1 (DIN2501) / according to ASME B 16.5 / as per JIS B2220:  
Stainless steel, 1.4404 (F316/F316L)
- All other process connections:  
Stainless steel, 1.4404 (316/316L)

 Available process connections →  150

**Seals**

Welded process connections without internal seals

**Accessories**

*Protective cover*

Stainless steel, 1.4404 (316L)

*Safety Barrier Promass 100*

Housing: Polyamide

Process connections

- Fixed flange connections:
  - EN 1092-1 (DIN 2501) flange
  - EN 1092-1 (DIN 2512N) flange
  - NAMUR lengths in accordance with NE 132
  - ASME B16.5 flange
  - JIS B2220 flange
  - DIN 11864-2 Form A flange, DIN 11866 series A, flange with notch
- Clamp connections:  
Tri-Clamp (OD tubes), DIN 11866 series C
- Thread:
  - DIN 11851 thread, DIN 11866 series A
  - SMS 1145 thread
  - ISO 2853 thread, ISO 2037
  - DIN 11864-1 Form A thread, DIN 11866 series A
- VCO connections:
  - 8-VCO-4
  - 12-VCO-4

 Process connection materials →  148

Surface roughness

All data refer to parts in contact with the medium.

*The following surface roughness categories can be ordered:*

| Category                              | Method   | Option(s) order code<br>"Measuring tube mat., wetted surface" |
|---------------------------------------|--|---|
| Not polished                          | -  | SA  |
| $Ra \leq 0.76 \mu m (30 \mu in)^{1)}$ | Mechanically polished <sup>2)</sup>                                | SB  |
| $Ra \leq 0.76 \mu m (30 \mu in)^{1)}$ | Mechanically polished <sup>2)</sup> , welds in as-welded condition | SJ  |

| Category                            | Method   | Option(s) order code<br>"Measuring tube mat., wetted surface" |
|-------------------------------------|--|---|
| Ra ≤ 0.38 μm (15 μin) <sup>1)</sup> | Mechanically polished <sup>2)</sup>                                | SC  |
| Ra ≤ 0.38 μm (15 μin) <sup>1)</sup> | Mechanically polished <sup>2)</sup> , welds in as-welded condition | SK  |

1) Ra according to ISO 21920

2) Except for inaccessible welds between pipe and manifold

## 16.11 Operability


### Local display

The local display is only available with the following device order code:  
Order code for "Display; operation", option **B**: 4-line; illuminated, via communication

#### Display element

- 4-line liquid crystal display with 16 characters per line.
- White background lighting; switches to red in event of device errors.
- Format for displaying measured variables and status variables can be individually configured.
- Permitted ambient temperature for the display: -20 to +60 °C (-4 to +140 °F). The readability of the display may be impaired at temperatures outside the temperature range.

#### Disconnecting the local display from the main electronics module

 In the case of the "Compact, aluminum coated" housing version, the local display must only be disconnected manually from the main electronics module. In the case of the "Compact, hygienic, stainless" and "Ultra-compact, hygienic, stainless" housing versions, the local display is integrated in the housing cover and is disconnected from the main electronics module when the housing cover is opened.

#### *"Compact, aluminum coated" housing version*

The local display is plugged onto the main electronics module. The electronic connection between the local display and main electronics module is established via a connecting cable.

For some work performed on the measuring device (e.g. electrical connection), it is advisable to disconnect the local display from the main electronics module:


1. Press in the side latches of the local display.
2. Remove the local display from the main electronics module. Pay attention to the length of the connecting cable when doing so.

Once the work is completed, plug the local display back on.

### Remote operation

#### Via PROFIBUS DP network

This communication interface is available in device versions with PROFIBUS DP.



A0020905


20 Options for remote operation via PROFIBUS DP network

- 1 Automation system
- 2 Computer with PROFIBUS network card
- 3 PROFIBUS DP network
- 4 Measuring device

Service interface

Via service interface (CDI-RJ45)

PROFIBUS DP



A0021270

21 Connection for order code for "Output", option L: PROFIBUS DP

- 1 Service interface (CDI-RJ45) of the measuring device with access to the integrated web server
- 2 Computer with web browser (e.g. Internet Explorer) for accessing the integrated web server or with "FieldCare" operating tool with COM DTM "CDI Communication TCP/IP"
- 3 Standard Ethernet connecting cable with RJ45 plug

Languages

Can be operated in the following languages:


- Via "FieldCare" operating tool: English, German, French, Spanish, Italian, Chinese, Japanese
- Via Web browser: English, German, French, Spanish, Italian, Dutch, Portuguese, Polish, Russian, Turkish, Chinese, Japanese, Bahasa (Indonesian), Vietnamese, Czech, Swedish, Korean



## 16.12 Certificates and approvals

Current certificates and approvals for the product are available at [www.endress.com](http://www.endress.com) on the relevant product page:

1. Select the product using the filters and search field.
2. Open the product page.
3. Select **Downloads**.

|                        |  |
|------------------------|--|
| CE mark                | <p>The device meets the legal requirements of the applicable EU Directives. These are listed in the corresponding EU Declaration of Conformity along with the standards applied.</p> <p>Endress+Hauser confirms successful testing of the device by affixing to it the CE mark.</p>  |
| UKCA marking           | <p>The device meets the legal requirements of the applicable UK regulations (Statutory Instruments). These are listed in the UKCA Declaration of Conformity along with the designated standards. By selecting the order option for UKCA marking, Endress+Hauser confirms a successful evaluation and testing of the device by affixing the UKCA mark.</p> <p>Contact address Endress+Hauser UK:<br/>         Endress+Hauser Ltd.<br/>         Floats Road<br/>         Manchester M23 9NF<br/>         United Kingdom<br/> <a href="http://www.uk.endress.com">www.uk.endress.com</a></p>  |
| RCM marking            | <p>The measuring system meets the EMC requirements of the "Australian Communications and Media Authority (ACMA)".</p>  |
| Ex-approval            | <p>The devices are certified for use in hazardous areas and the relevant safety instructions are provided in the separate "Safety Instructions" (XA) document. Reference is made to this document on the nameplate.</p>  |
| Hygienic compatibility | <ul style="list-style-type: none"> <li>■ 3-A approval             <ul style="list-style-type: none"> <li>■ Only measuring instruments with the order code for "Additional approval", option LP "3A" have 3-A approval.</li> <li>■ The 3-A approval refers to the measuring instrument.</li> <li>■ When installing the measuring instrument, ensure that no liquid can accumulate on the outside of the measuring instrument.<br/>                 A remote display module must be installed in accordance with the 3-A Standard.</li> <li>■ Accessories (e.g. heating jacket, weather protection cover, wall holder unit) must be installed in accordance with the 3-A Standard.<br/>                 Each accessory can be cleaned. Disassembly may be necessary under certain circumstances.</li> </ul> </li> <li>■ EHEDG-tested<br/>                 Only devices with the order code for "Additional approval", option LT "EHEDG" have been tested and meet the requirements of the EHEDG.<br/>                 To meet the requirements for EHEDG certification, the device must be used with process connections in accordance with the EHEDG position paper entitled "Easy cleanable Pipe couplings and Process connections" (<a href="http://www.ehedg.org">www.ehedg.org</a>).<br/>                 To meet the requirements for EHEDG certification, the device must be installed in a position that ensures drainability.</li> </ul> <p> Observe the special installation instructions</p> |

Pharmaceutical  
compatibility

- FDA 21 CFR 177
- USP <87>
- USP <88> Class VI 121 °C
- TSE/BSE Certificate of Suitability

## Certification PROFIBUS

**PROFIBUS interface**

The measuring device is certified and registered by the PNO (PROFIBUS Nutzerorganisation e.V./PROFIBUS User Organization). The measuring system meets all the requirements of the following specifications:

- Certified according to PA Profile 3.02
- The device can also be operated with certified devices of other manufacturers (interoperability)

Pressure Equipment  
Directive

- With the marking
  - a) PED/G1/x (x = category) or
  - b) PESR/G1/x (x = category)
 on the sensor nameplate, Endress+Hauser confirms compliance with the "Essential Safety Requirements"
  - a) specified in Annex I of the Pressure Equipment Directive 2014/68/EU or
  - b) Schedule 2 of Statutory Instruments 2016 No. 1105.
- Devices not bearing this marking (without PED or PESR) are designed and manufactured according to sound engineering practice. They meet the requirements of
  - a) Art. 4 Para. 3 of the Pressure Equipment Directive 2014/68/EU or
  - b) Part 1, Para. 8 of Statutory Instruments 2016 No. 1105.
 The scope of application is indicated
  - a) in diagrams 6 to 9 in Annex II of the Pressure Equipment Directive 2014/68/EU or
  - b) Schedule 3, Para. 2 of Statutory Instruments 2016 No. 1105.

External standards and  
guidelines



- EN 60529  
Degrees of protection provided by enclosures (IP code)
- IEC/EN 60068-2-6  
Environmental influences: Test procedure - Test Fc: vibrate (sinusoidal).
- IEC/EN 60068-2-31  
Environmental influences: Test procedure - Test Ec: shocks due to rough handling, primarily for devices.
- EN 61010-1  
Safety requirements for electrical equipment for measurement, control and laboratory use - general requirements
- EN 61326-1/-2-3  
EMC requirements for electrical equipment for measurement, control and laboratory use
- NAMUR NE 21  
Electromagnetic compatibility (EMC) of industrial process and laboratory control equipment
- NAMUR NE 32  
Data retention in the event of a power failure in field and control instruments with microprocessors
- NAMUR NE 43  
Standardization of the signal level for the breakdown information of digital transmitters with analog output signal.
- NAMUR NE 53  
Software of field devices and signal-processing devices with digital electronics
- NAMUR NE 80  
The application of the pressure equipment directive to process control devices
- NAMUR NE 105  
Specifications for integrating fieldbus devices in engineering tools for field devices

- NAMUR NE 107  
Self-monitoring and diagnosis of field devices
- NAMUR NE 131  
Requirements for field devices for standard applications
- NAMUR NE 132  
Coriolis mass meter
- ETSI EN 300 328  
Guidelines for 2.4 GHz radio components.
- EN 301489  
Electromagnetic compatibility and radio spectrum matters (ERM).

## 16.13 Application packages

Many different application packages are available to enhance the functionality of the device. Such packages might be needed to address safety aspects or specific application requirements.

The application packages can be ordered with the device or subsequently from Endress+Hauser. Detailed information on the order code in question is available from your local Endress+Hauser sales center or on the product page of the Endress+Hauser website: [www.endress.com](http://www.endress.com).

 Detailed information on the application packages:  
Special Documentation →  157

---

### Heartbeat Technology

Order code for "Application package", option EB "Heartbeat Verification + Monitoring"

#### Heartbeat Verification

Meets the requirement for traceable verification to DIN ISO 9001:2008 Chapter 7.6 a) "Control of monitoring and measuring equipment".

- Functional testing in the installed state without interrupting the process.
- Traceable verification results on request, including a report.
- Simple testing process via local operation or other operating interfaces.
- Clear measuring point assessment (pass/fail) with high test coverage within the framework of manufacturer specifications.
- Extension of calibration intervals according to operator's risk assessment.

#### Heartbeat Monitoring

Continuously supplies data, which are characteristic of the measuring principle, to an external condition monitoring system for the purpose of preventive maintenance or process analysis. These data enable the operator to:

- Draw conclusions - using these data and other information - about the impact process influences (e.g. corrosion, abrasion, buildup etc.) have on the measuring performance over time.
- Schedule servicing in time.
- Monitor the process or product quality, e.g. gas pockets .

 For detailed information, see the Special Documentation for the device.

---

### Concentration measurement

Order code for "Application package", option ED "Concentration"

Calculation and outputting of fluid concentrations.

The measured density is converted to the concentration of a substance of a binary mixture using the "Concentration" application package:

- Choice of predefined fluids (e.g. various sugar solutions, acids, alkalis, salts, ethanol etc.).
- Common or user-defined units (°Brix, °Plato, % mass, % volume, mol/l etc.) for standard applications.
- Concentration calculation from user-defined tables.

The measured values are output via the digital and analog outputs of the device.



For detailed information, see the Special Documentation for the device.

Petroleum & locking function

Order code for "Application package", option EM "Petroleum & locking function"

The most important parameters for the Oil & Gas Industry can be calculated and displayed with this application package. It is also possible to lock the settings.

- Corrected volume flow and calculated reference density in accordance with the "API Manual of Petroleum Measurement Standards, Chapter 11.1"
- Water content, based on density measurement
- Weighted mean of the density and temperature



For detailed information, see the Special Documentation for the device.

## 16.14 Accessories



Overview of accessories available to order →  133

## 16.15 Supplementary documentation



For an overview of the scope of the associated Technical Documentation, refer to the following:

- *Device Viewer* ([www.endress.com/deviceviewer](http://www.endress.com/deviceviewer)): Enter the serial number from the nameplate
- *Endress+Hauser Operations app*: Enter serial number from nameplate or scan matrix code on nameplate.

Standard documentation

### Brief Operating instructions

*Brief Operating Instructions for the sensor*

| Measuring instrument | Documentation code |
|----------------------|--------------------|
| Proline Promass E    | KA01260D           |

*Transmitter Brief Operating Instructions*

| Measuring device    | Documentation code |
|---------------------|--------------------|
| Proline Promass 100 | KA01333D           |

### Technical Information

| Measuring device      | Documentation code |
|-----------------------|--------------------|
| Proline Promass E 100 | TI01351D           |

### Description of Device Parameters

| Measuring device    | Documentation code |
|---------------------|--------------------|
| Proline Promass 100 | GP01034D           |

Supplementary device-  
dependent documentation



### Safety Instructions

| Content          | Documentation code |
|------------------|--------------------|
| ATEX/IECEX Ex i  | XA00159D           |
| ATEX/IECEX Ex nA | XA01029D           |
| cCSAus IS        | XA00160D           |
| INMETRO Ex i     | XA01219D           |
| INMETRO Ex nA    | XA01220D           |

### Special Documentation

| Content   | Documentation code |
|---|--------------------|
| Information on the Pressure Equipment Directive | SD00142D           |
| Concentration measurement                       | SD01152D           |
| Heartbeat Technology                            | SD01153D           |
| Web server                                      | SD01821D           |

### Installation instructions

| Contents  | Note  |
|---|---|
| Installation instructions for spare part sets and accessories | <ul style="list-style-type: none"> <li>▪ Access the overview of all the available spare part sets via <i>Device Viewer</i> →  131</li> <li>▪ Accessories available for order with Installation Instructions →  133</li> </ul> |

# Index

- 0 ... 9**  
 3-A approval . . . . . 153
- A**  
 Access authorization to parameters  
   Read access . . . . . 38  
   Write access . . . . . 38  
 Access code . . . . . 38  
   Incorrect input . . . . . 38  
 Adapting the diagnostic behavior . . . . . 95  
 Ambient conditions  
   Shock and vibration resistance . . . . . 146  
   Storage temperature . . . . . 145  
 Analog Input module . . . . . 52  
 Analog Output module . . . . . 54  
 Application . . . . . 136  
 Application packages . . . . . 155  
 Applicator . . . . . 137  
 Approvals . . . . . 153
- C**  
 Cable entries  
   Technical data . . . . . 141  
 Cable entry  
   Degree of protection . . . . . 32  
 CE mark . . . . . 10, 153  
 Certificates . . . . . 153  
 Certification PROFIBUS . . . . . 154  
 cGMP . . . . . 154  
 Checklist  
   Post-connection check . . . . . 32  
   Post-installation check . . . . . 24  
 CIP cleaning . . . . . 146  
 Cleaning  
   CIP cleaning . . . . . 130  
   Exterior cleaning . . . . . 130  
   Internal cleaning . . . . . 130  
   SIP cleaning . . . . . 130  
 Climate class . . . . . 145  
 Commissioning . . . . . 57  
   Advanced settings . . . . . 66  
   Configuring the measuring instrument . . . . . 57  
 Compatibility with previous model . . . . . 47  
 Connecting cable . . . . . 25  
 Connecting the measuring instrument . . . . . 27  
 Connection  
   see Electrical connection  
 Connection preparations . . . . . 27  
 Connection tools . . . . . 25  
 Current consumption . . . . . 141  
 Cyclic data transmission . . . . . 51
- D**  
 Date of manufacture . . . . . 14  
 Declaration of Conformity . . . . . 10  
 Defining the access code . . . . . 75  
 Degree of protection . . . . . 32, 145  
 Density adjustment . . . . . 68  
 Design  
   Measuring device . . . . . 12  
   Operating menu . . . . . 35  
 Design fundamentals  
   Measurement error . . . . . 144  
   Repeatability . . . . . 144  
 Device components . . . . . 12  
 Device description files . . . . . 47  
 Device fuse . . . . . 141  
 Device locking, status . . . . . 77  
 Device master file  
   GSD . . . . . 47  
 Device name  
   Sensor . . . . . 14  
   Transmitter . . . . . 14  
 Device repair . . . . . 131  
 Device revision . . . . . 47  
 Device type ID . . . . . 47  
 Device Viewer . . . . . 131  
 DeviceCare . . . . . 46  
   Device description file . . . . . 47  
 Diagnostic information  
   Design, description . . . . . 93, 94  
   DeviceCare . . . . . 94  
   FieldCare . . . . . 94  
   LEDs . . . . . 91  
   Overview . . . . . 98  
   Remedial measures . . . . . 98  
   Web browser . . . . . 92  
 Diagnostics list . . . . . 124  
 DIP switch  
   see Write protection switch  
 Disabling write protection . . . . . 75  
 Discrete Input module . . . . . 55  
 Discrete Output module . . . . . 56  
 Display area  
   For operational display . . . . . 37  
 Display values  
   For locking status . . . . . 77  
 Disposal . . . . . 132  
 Document  
   Function . . . . . 6  
   Symbols . . . . . 6  
 Document function . . . . . 6  
 Down pipe . . . . . 18
- E**  
 EHEDG-tested . . . . . 153  
 Electrical connection  
   Degree of protection . . . . . 32  
   Measuring instrument . . . . . 25  
   Operating tools  
     Via PROFIBUS DP network . . . . . 44, 151  
     Via service interface (CDI-RJ45) . . . . . 44, 152

- Web server . . . . . 44, 152
- Electromagnetic compatibility . . . . . 146
- EMPTY\_MODULE module . . . . . 56
- Enabling write protection . . . . . 75
- Endress+Hauser services
  - Maintenance . . . . . 130
  - Repair . . . . . 131
- Error messages
  - see Diagnostic messages
- Event logbook . . . . . 124
- Events list . . . . . 124
- Ex-approval . . . . . 153
- Extended order code
  - Sensor . . . . . 14
  - Transmitter . . . . . 14
- Exterior cleaning . . . . . 130
- F**
- FDA . . . . . 153, 154
- Field of application
  - Residual risks . . . . . 10
- FieldCare . . . . . 45
  - Device description file . . . . . 47
  - Establishing a connection . . . . . 45
  - Function . . . . . 45
  - User interface . . . . . 46
- Filtering the event logbook . . . . . 125
- Firmware
  - Release date . . . . . 47
  - Version . . . . . 47
- Firmware history . . . . . 129
- Flow direction . . . . . 19, 23
- Flow limit . . . . . 147
- Food Contact Materials Regulation . . . . . 153
- FOUNDATION Fieldbus block structure . . . . . 49
- Functions
  - see Parameters
- G**
- Galvanic isolation . . . . . 139
- H**
- Hardware write protection . . . . . 76
- Hygienic compatibility . . . . . 153
- I**
- I/O electronics module . . . . . 12, 28
- Identifying the measuring instrument . . . . . 13
- Incoming acceptance . . . . . 13
- Indication
  - Current diagnostic event . . . . . 123
  - Previous diagnostic event . . . . . 123
- Influence
  - Medium pressure . . . . . 144
  - Medium temperature . . . . . 143
- Information about this document . . . . . 6
- Inlet runs . . . . . 20
- Input variables . . . . . 137
- Inspection
  - Connection . . . . . 32
- Installation . . . . . 24
  - Received goods . . . . . 13
- Installation . . . . . 18
- Installation dimensions . . . . . 20
- Installation point . . . . . 18
- Intended use . . . . . 9
- Internal cleaning . . . . . 130, 146
- L**
- Languages, operation options . . . . . 152
- Local display
  - see Operational display
- Low flow cut off . . . . . 139
- M**
- Main electronics module . . . . . 12
- Maintenance work . . . . . 130
- Manufacturer ID . . . . . 47
- Materials . . . . . 148
- Maximum measurement error . . . . . 142
- Measured variables
  - see Process variables
- Measurement accuracy . . . . . 141
- Measuring and test equipment . . . . . 130
- Measuring device
  - Conversion . . . . . 131
  - Design . . . . . 12
  - Disposal . . . . . 132
  - Mounting the sensor . . . . . 23
  - Preparing for electrical connection . . . . . 27
  - Removing . . . . . 132
  - Repairs . . . . . 131
- Measuring instrument
  - Configuring . . . . . 57
  - Preparing for mounting . . . . . 23
- Measuring principle . . . . . 136
- Measuring range
  - For gases . . . . . 137
  - For liquids . . . . . 137
- Measuring range, recommended . . . . . 147
- Measuring system . . . . . 136
- Medium pressure
  - Influence . . . . . 144
- Medium temperature
  - Influence . . . . . 143
- Menu
  - Diagnostics . . . . . 123
  - Operation . . . . . 77
  - Setup . . . . . 58
- Menus
  - For measuring instrument configuration . . . . . 57
  - For specific settings . . . . . 66
- Module
  - Analog Input . . . . . 52
  - Analog output . . . . . 54
  - Discrete Input . . . . . 55
  - Discrete Output . . . . . 56
  - EMPTY\_MODULE . . . . . 56

|   |     |  |  |
|---|-----|--|--|
| Totalizer                                   |     |  |  |
| SETTOT_MODETOT_TOTAL                        | 54  |  |  |
| SETTOT_TOTAL                                | 53  |  |  |
| TOTAL                                       | 53  |  |  |
| Mounting dimensions                         |     |  |  |
| see Installation dimensions                 |     |  |  |
| Mounting preparations                       | 23  |  |  |
| Mounting requirements                       |     |  |  |
| Down pipe                                   | 18  |  |  |
| Inlet and outlet runs                       | 20  |  |  |
| Installation dimensions                     | 20  |  |  |
| Installation point                          | 18  |  |  |
| Orientation                                 | 19  |  |  |
| Rupture disk                                | 22  |  |  |
| Sensor heating                              | 21  |  |  |
| Static pressure                             | 20  |  |  |
| Thermal insulation                          | 20  |  |  |
| Vibrations                                  | 21  |  |  |
| Mounting tools                              | 23  |  |  |
| <b>N</b>                                    |     |  |  |
| Nameplate                                   |     |  |  |
| Sensor                                      | 14  |  |  |
| Transmitter                                 | 14  |  |  |
| Netilion                                    | 130 |  |  |
| <b>O</b>                                    |     |  |  |
| Operable flow range                         | 138 |  |  |
| Operating menu                              |     |  |  |
| Design                                      | 35  |  |  |
| Menus, submenus                             | 35  |  |  |
| Submenus and user roles                     | 36  |  |  |
| Operating philosophy                        | 36  |  |  |
| Operation                                   | 77  |  |  |
| Operation options                           | 34  |  |  |
| Operational display                         | 37  |  |  |
| Operational safety                          | 10  |  |  |
| Order code                                  | 14  |  |  |
| Orientation (vertical, horizontal)          | 19  |  |  |
| Outlet runs                                 | 20  |  |  |
| Output signal                               | 138 |  |  |
| Output variables                            | 138 |  |  |
| <b>P</b>                                    |     |  |  |
| Packaging disposal                          | 17  |  |  |
| Parameter settings                          |     |  |  |
| Administration (Submenu)                    | 73  |  |  |
| Advanced setup (Submenu)                    | 66  |  |  |
| Analog inputs (Submenu)                     | 63  |  |  |
| Communication (Submenu)                     | 62  |  |  |
| Corrected volume flow calculation (Submenu) | 67  |  |  |
| Density adjustment (Wizard)                 | 69  |  |  |
| Device information (Submenu)                | 127 |  |  |
| Diagnostics (Menu)                          | 123 |  |  |
| Low flow cut off (Wizard)                   | 64  |  |  |
| Measured variables (Submenu)                | 77  |  |  |
| Medium selection (Submenu)                  | 61  |  |  |
| Partially filled pipe detection (Wizard)    | 65  |  |  |
| Sensor adjustment (Submenu)                 | 68  |  |  |
| Setup (Menu)                                | 58  |  |  |
| Simulation (Submenu)                        | 74  |  |  |
| System units (Submenu)                      | 58  |  |  |
| Totalizer (Submenu)                         | 87  |  |  |
| Totalizer 1 to n (Submenu)                  | 72  |  |  |
| Totalizer handling (Submenu)                | 88  |  |  |
| Web server (Submenu)                        | 43  |  |  |
| Zero point adjustment (Submenu)             | 71  |  |  |
| Performance characteristics                 | 141 |  |  |
| Performing density adjustment               | 69  |  |  |
| Pharmaceutical compatibility                | 154 |  |  |
| Post-connection check                       | 57  |  |  |
| Post-connection check (checklist)           | 32  |  |  |
| Post-installation check                     | 57  |  |  |
| Post-installation check (checklist)         | 24  |  |  |
| Potential equalization                      | 29  |  |  |
| Power consumption                           | 141 |  |  |
| Power supply failure                        | 141 |  |  |
| Pressure Equipment Directive                | 154 |  |  |
| Pressure loss                               | 147 |  |  |
| Pressure-temperature ratings                | 146 |  |  |
| Process connections                         | 150 |  |  |
| Process variables                           |     |  |  |
| Calculated                                  | 137 |  |  |
| Measured                                    | 137 |  |  |
| Product safety                              | 10  |  |  |
| Protecting parameter settings               | 75  |  |  |
| <b>R</b>                                    |     |  |  |
| RCM marking                                 | 153 |  |  |
| Read access                                 | 38  |  |  |
| Reading off measured values                 | 77  |  |  |
| Recalibration                               | 130 |  |  |
| Reference operating conditions              | 141 |  |  |
| Registered trademarks                       | 8   |  |  |
| Remote operation                            | 151 |  |  |
| Repair                                      | 131 |  |  |
| Notes                                       | 131 |  |  |
| Repair of a device                          | 131 |  |  |
| Repeatability                               | 143 |  |  |
| Replacement                                 |     |  |  |
| Device components                           | 131 |  |  |
| Requirements for personnel                  | 9   |  |  |
| Response time                               | 143 |  |  |
| Return                                      | 131 |  |  |
| Rupture disk                                |     |  |  |
| Safety instructions                         | 22  |  |  |
| Triggering pressure                         | 147 |  |  |
| <b>S</b>                                    |     |  |  |
| Safety                                      | 9   |  |  |
| Sensor                                      |     |  |  |
| Installing                                  | 23  |  |  |
| Sensor heating                              | 21  |  |  |
| Sensor housing                              | 146 |  |  |
| Serial number                               | 14  |  |  |
| Setting the operating language              | 57  |  |  |



- Settings
  - Adapting the measuring device to the process conditions . . . . . 88
  - Administration . . . . . 73
  - Analog Input . . . . . 63
  - Communication interface . . . . . 62
  - Low flow cut off . . . . . 64
  - Medium . . . . . 61
  - Operating language . . . . . 57
  - Partially filled pipe detection . . . . . 65
  - Resetting the device . . . . . 126
  - Resetting the totalizer . . . . . 88
  - Sensor adjustment . . . . . 68
  - Simulation . . . . . 74
  - System units . . . . . 58
  - Tag name . . . . . 58
  - Totalizer . . . . . 72
  - Totalizer reset . . . . . 88
- SETTOT\_MODETOT\_TOTAL module . . . . . 54
- SETTOT\_TOTAL module . . . . . 53
- Shock and vibration resistance . . . . . 146
- Signal on alarm . . . . . 138
- SIP cleaning . . . . . 146
- Software release . . . . . 47
- Spare part . . . . . 131
- Spare parts . . . . . 131
- Special connection instructions . . . . . 30
- Special mounting instructions
  - Hygienic compatibility . . . . . 22
- Standards and guidelines . . . . . 154
- Static pressure . . . . . 20
- Status area
  - For operational display . . . . . 37
- Status signals . . . . . 93
- Storage conditions . . . . . 16
- Storage temperature . . . . . 16
- Storage temperature range . . . . . 145
- Submenu
  - Administration . . . . . 73
  - Advanced setup . . . . . 66
  - Analog inputs . . . . . 63
  - Calculated values . . . . . 66
  - Communication . . . . . 62
  - Corrected volume flow calculation . . . . . 67
  - Device information . . . . . 127
  - Events list . . . . . 124
  - Measured values . . . . . 77
  - Measured variables . . . . . 77
  - Medium selection . . . . . 61
  - Overview . . . . . 36
  - Process variables . . . . . 66
  - Sensor adjustment . . . . . 68
  - Simulation . . . . . 74
  - System units . . . . . 58
  - Totalizer . . . . . 87
  - Totalizer 1 to n . . . . . 72
  - Totalizer handling . . . . . 88
  - Web server . . . . . 43
  - Zero point adjustment . . . . . 71
- Supply voltage . . . . . 140
- Surface roughness . . . . . 150
- Symbols
  - For communication . . . . . 37
  - For diagnostic behavior . . . . . 37
  - For locking . . . . . 37
  - For measured variable . . . . . 37
  - For measurement channel number . . . . . 37
  - For status signal . . . . . 37
  - In the status area of the local display . . . . . 37
- System design
  - Measuring system . . . . . 136
  - see Measuring device design
- System integration . . . . . 47
- T**
  - Technical data, overview . . . . . 136
  - Temperature range
    - Medium temperature . . . . . 146
    - Storage temperature . . . . . 16
  - Terminal assignment . . . . . 26, 28
  - Terminals . . . . . 141
  - Thermal insulation . . . . . 20
  - Tool
    - Transport . . . . . 16
  - Tools
    - Electrical connection . . . . . 25
    - For mounting . . . . . 23
  - TOTAL module . . . . . 53
  - Totalizer
    - Configuring . . . . . 72
    - Operating . . . . . 88
    - Reset . . . . . 88
  - Transmitter
    - Connecting the signal cables . . . . . 28
  - Transporting the measuring device . . . . . 16
  - Troubleshooting
    - General . . . . . 90
  - TSE/BSE Certificate of Suitability . . . . . 154
- U**
  - UKCA marking . . . . . 153
  - Use of measuring device
    - Borderline cases . . . . . 9
    - Incorrect use . . . . . 9
  - Use of measuring instrument
    - see Intended use
  - User roles . . . . . 36
  - USP Class VI . . . . . 154
- V**
  - Version data for the device . . . . . 47
  - Vibrations . . . . . 21
- W**
  - W@M Device Viewer . . . . . 13
  - Weight
    - SI units . . . . . 148
    - Transport (notes) . . . . . 16
    - US units . . . . . 148

---

|   |    |
|---|----|
| Wizard                                    |    |
| Define access code . . . . .              | 75 |
| Density adjustment . . . . .              | 69 |
| Low flow cut off . . . . .                | 64 |
| Partially filled pipe detection . . . . . | 65 |
| Workplace safety . . . . .                | 10 |
| Write access . . . . .                    | 38 |
| Write protection                          |    |
| Via access code . . . . .                 | 75 |
| Via write protection switch . . . . .     | 76 |
| Write protection switch . . . . .         | 76 |





71675062

[www.addresses.endress.com](http://www.addresses.endress.com)

---