

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx TUR 11.0007X	issue No.:0	Certificate history:
Status:	Current		
Date of Issue:	2011-06-30	Page 1 of 3	
Applicant:	Endress + Hauser Con Co. KG Dieselstraße 24 70826 Gerlingen Germany	ducta Gesellschaft für Mess	s- und Regeltechnik GmbH &
Electrical Apparatus: Optional accessory:	Liquiline M CM42l		
Type of Protection:	Intrinsic Safety - Ex i		
Marking:	Ex ib [ia Ga] IIC T6 Gb for -20 °C <= ta <= 50 °C and Ex ib [ia Ga] IIC T4 Gb for -20 °C <= ta <= 55 °C		
Approved for issue on b Certification Body:	ehalf of the IECEx	DiplIng. Heinz Farke	
Position:		Deputy Head of ExCB	
Signature: (for printed version)		SESE	
Date:		2011-06-3	0
2. This certificate is not	chedule may only be reproduc transferable and remains the enticity of this certificate may t	ced in full. property of the issuing body. be verified by visiting the Official	IECEx Website.
Certificate issued by:			_

**TUV Rheinland Industrie Service GmbH Am Grauen Stein** 51105 Cologne

Germany





Certificate No.:

**IECEx TUR 11.0007X** 

Date of Issue:

2011-06-30

Issue No.: 0

Page 2 of 3

Manufacturer:

Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik

GmbH & Co. KG Dieselstraße 24 70826 Gerlingen Germany

### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### **STANDARDS:**

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2007-10

Explosive atmospheres - Part 0:Equipment - General requirements

Edition: 5

IEC 60079-11: 2006

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 5

IEC 60079-26: 2006

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/TUR/ExTR11.0007/00

**Quality Assessment Report:** 

DE/BVS/QAR06.0005/03



	icate	

**IECEx TUR 11.0007X** 

Date of Issue:

2011-06-30

Issue No.: 0

Page 3 of 3

#### Schedule

### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

For further decription and parameter see the annexed file.

The Liquiline M CM42-.I...... is a measuring system for conductivity and/or pH-Value/Redox potential and dissolved Oxygen.

Ambient temperature:

-20 °C <= ta <= +50 °C for T6 and

-20 °C <= ta <= +55 °C for T4

### CONDITIONS OF CERTIFICATION: YES as shown below:

Metal enclosures must be connected to the local equipotential bonding system at the point of installation.

Only sensors, intended to be used according to the user instruction, must be connected. The rated values of input and output circuits has to be followed.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification Scheme for Explosive Atmospheres**

for rules and details of the IECEx Scheme visit www.iecex.com

00	<b>-4</b> ;€i	cate	Ma	
L.e	ITITI	Care	NΩ	

**IECEx TUR 11.0007X** 

issue No.:1

Certificate history:

Status:

Current

Issue No. 1 (2014-2-6) Issue No. 0 (2011-6-30)

Date of Issue:

2014-02-06

Page 1 of 4

Applicant:

Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik GmbH &

Co. KG

Dieselstraße 24 70839 Gerlingen Germany

Electrical Apparatus: Optional accessory:

Transmitter Liquiline M type CM42 - \*|\* \*\* \* \*\*\*\*\*

Type of Protection:

Intrinsic Safety - Ex i

Marking:

Ex ib [ia Ga] IIC T6 Gb for -20 °C <= ta <= 50 °C

and

Ex ib [ia Ga] IIC T4 Gb for -20 °C <= ta <= 55 °C

Approved for issue on behalf of the IECEX

Certification Body:

Dipl.-Ing. Klauspeter Graffi

Position:

Head of Certification Body

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

This certificate is not transferable and remains the property of the issuing body.
 The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TUV Rheinland Industrie Service GmbH** Am Grauen Stein 51105 Cologne Germany





Certificate No.: IECEx TUR 11.0007X

Date of Issue: 2014-02-06 Issue No.: 1

Page 2 of 4

Manufacturer: Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik

GmbH & Co. KG Dieselstraße 24 70839 Gerlingen Germany

Additional Manufacturing location

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-11 : 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 6.0

IEC 60079-26 : 2006 Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/TUR/ExTR11.0007/00

Quality Assessment Report:

DE/BVS/QAR06.0005/03 DE/BVS/QAR06.0005/04 DE/BVS/QAR06.0005/05



Ce	,		+~	NIA	
ce	пп	ıca	te.	INΩ	٠.

IECEx TUR 11.0007X

Date of Issue:

2014-02-06

Issue No.: 1

Page 3 of 4

### Schedule

#### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

Object of this supplement is the introduction of the new type CM42-LI\* \*\* \* \*\*\*\*\*\*, the cancellation of the old type CM42-RI\* \*\* \* \*\*\*\*\*\*, increasing of the maximum input power P<sub>i</sub> of the module FBIH1, as well as miscellaneous minor changes in the mechanical construction and the electronic design.

Moreover the compliance assessments to the standards IEC 60079-0:2011 and IEC 60079-11:2011 is part of this supplement.

For further decription and parameter see the annexed file.

## CONDITIONS OF CERTIFICATION: YES as shown below:

Metal enclosures must be connected to the local equipotential bonding system at the point of installation.

Only sensors, intended to be used according to the user instruction, must be connected. The rated values of input and output circuits has to be followed.



Certificate No.:

**IECEx TUR 11.0007X** 

Date of Issue:

2014-02-06

Issue No.: 1

Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Object of this supplement is the introduction of the new type CM42-LI\* \*\* \* \*\*\*\*\*\*, the cancellation of the old type CM42-RI\* \*\* \* \*\*\*\*\*\*, increasing of the maximum input power P<sub>i</sub> of the module FBIH1, as well as miscellaneous minor changes in the mechanical construction and the electronic design.

Moreover the compliance assessments to the standards IEC 60079-0:2011 and IEC 60079-11:2011 is part of this supplement.



## Attachment to Certificate IECEx TUR 11.0007/01 X Revison 01

### Attachment to to Certificate IECEx TUR 11.0007/01 X

Device: Transmitter Liquiline M Typ CM42 - \*I\* \*\* \* \*\*\*\*\*\*

Manufacturer: Endress + Hauser Conducta Gesellschaft


für Mess- und Regeltechnik mbH + Co.KG

Address: Dieselstraße 24, 70839 Gerlingen

Germany

### **General product information:**

Transmitter





## Attachment to Certificate IECEx TUR 11.0007/01 X Revison 01

The transmitter Liquiline M type CM42-\*I\* \*\* \*\*\*\*\*\* is used to acquire different parameters in analytical measuring technology, such as for example pH value, electrolytical conductivity or dissolved oxygen. It consists either of a metallic enclosure (type CM42-\*I\* \*1 \* \*\*\*\*\*) or a plastic enclosure (type CM42-\*G\* \*0 \* \*\*\*\*\*\*), a display with operating elements, and terminals for external connection of the intrinsically safe circuits. For connection of the different intrinsically safe circuits several modules has to be used:

- For communication circuits the assemblies FBIH1 and FBPA1
- for the sensor circuits the modules FSPH1, FSLI1, FSLC1, and FSDG1.
- 1. Technical data
- 1.1 Electrical ratings
- 1.1.1 Communication circuits
- 1.1.1.1 Assembly FBIH1: 2 Current outputs with HART communication via output 1

Current output 1 in type of protection Ex ib IIC

Terminals: 133-134

Maximum input voltageUi30 VMaximum input currentIi100 mAMaximum input powerPi800 mWEffective internal capacitanceCi1.2 nFEffective internal inductanceLi29 μH

Current output 2 in type of protection Ex ib IIC

Terminals: 233-234

Maximum input voltage Ui 30 V
Maximum input current Ii 100 mA
Maximum input power Pi 800 mW
Effective internal capacitance Ci 0.2 nF
Effective internal inductance Li 24 µH

1.1.1.2 Assembly FBPA1: Current output for connection to a field bus communication system according to the FISCO concept

Current output in type of protection Ex ib IIC

Terminals: 997-998

Maximum input voltage Ui 17.5 V Maximum input current Ii 380 mA Maximum input power Pi 5.32 W Effective internal capacitance Ci < 5 nF Effective internal inductance Li  $< 10 \text{ }\mu\text{H}$ 

- 1.1.2 Sensor circuits
- 1.1.2.1 Sensor modules FSPH1: Sensor input pH/ Redox and temperature pH/ Redox sensor input and temperature in type of protection Ex ia IIC

Terminals: 317-320; 111-113

Maximum output voltage Uo 10.08 V Maximum output current 4.1 mA lo Maximum output power 10.2 mW Po Effective internal capacitance 28.9 nF Ci Effective internal inductance Li 305 uH Effective external capacitance Co 250 nF Effective external inductance 1 mH



## Attachment to Certificate IECEx TUR 11.0007/01 X Revison 01

Terminals: 315-320; 111-113

Maximum output voltage Uo 10.08 V Maximum output current 50.7 mA lo Maximum output power Ро 128 mW Effective internal capacitance Ci 28.9 nF Effective internal inductance Li 305 µH Effective external capacitance Co 250 nF Effective external inductance 1 mH Lo

1.1.2.2 Sensor modules FSLI1: Sensor input for Inductive conductivity probe type CLS50 or type CLS54

Sensor input in type of protection Ex ia IIC

Terminals: 111-113, 215-218

Maximum output voltage Uo 10.08 V
Maximum output current Io 64 mA
Maximum output power Po 128 mW

Effective internal capacitance Ci 62 nF (only internally, not effective) Effective internal inductance Li 305 µH (only internally, not effective)

Effective external capacitance Co 1.8 µF
Effective external inductance Lo 0.1 mH

1.1.2.3 Sensor modules FSLC1: Sensor input for certified inductive conductivity probe type CLS\*\*Sensor input in type of protection Ex ia IIC

Terminals: 111-113, 219-222

Maximum output voltage Uo 10.08 V Maximum output current lo 23 mA Maximum output power Po 57 mW Effective internal capacitance 21 nF Ci Effective internal inductance Li 305 µH Effective external capacitance Co 50 nF Effective external inductance 300 µH I٥

1.1.2.4 Sensor modules FSDG1: Sensor input for suitable and intrinsically safe certified MEMOSENS devices according to IECEx BVS 11.0052X (Memosens sensors), IECEx BVS 14.0004X (CLS50D sensor), IECEx BVS 12.0007 (Memocheck Sim)

Sensor input in type of protection Ex ia IIC

Terminals: 187-188, 197-198

Maximum output voltage Uo 5.04 V
Maximum output current Io 80 mA
Maximum output power Po 112 mW

 $\begin{array}{lll} \hbox{Effective internal capacitance} & \hbox{Ci} & 12.4 \ \mu F & (only internally, not effective) \\ \hbox{Effective internal inductance} & \hbox{Li} & 160.4 \ \mu H & (only internally, not effective) \\ \end{array}$ 

1.2 Thermal ratings

Ambient temperature range

For temperature class T6  $-20 \,^{\circ}\text{C} \le \text{Ta} \le +50 \,^{\circ}\text{C}$ For temperature class T4  $-20 \,^{\circ}\text{C} \le \text{Ta} \le +55 \,^{\circ}\text{C}$ 



# INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

( 'Artiticato	N	~	
Certificate	1 1	v.	٠.

IECEx TUR 11.0007X

issue No.:2

Certificate history:

Status:

Current

Issue No. 2 (2014-10-2) Issue No. 1 (2014-2-6) Issue No. 0 (2011-6-30)

Date of Issue:

2014-10-02

Page 1 of 4

Applicant:

Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik GmbH &

Co. KG

Dieselstraße 24 70839 Gerlingen **Germany** 

Electrical Apparatus:

Optional accessory:

Transmitter Liquiline M type CM42 - \*I\* \*\* \* \*\*\*\*\*

Type of Protection:

Intrinsic Safety - Ex i

Marking:

Ex ib [ia Ga] IIC T6/T4 Gb

Approved for issue on behalf of the IECEx

Certification Body:

Dipl.-Ing. Klauspeter Graffi

Position:

Head of Certification Body

Signature:

(for printed version)

Date:

This certificate and schedule may only be reproduced in full.
 This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TUV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Cologne Germany





Certificate No.:

IECEx TUR 11.0007X

Date of Issue:

2014-10-02

Issue No.: 2

Page 2 of 4

Manufacturer:

Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik

GmbH & Co. KG Dieselstraße 24 70839 Gerlingen Germany

Additional Manufacturing location

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Edition: 6.0

Explosive atmospheres - Part 0: General requirements

IEC 60079-11: 2011

Edition: 6.0

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

IEC 60079-26: 2006

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/TUR/ExTR11.0007/00

DE/TUR/ExTR11.0007/01

DE/TUR/ExTR11.0007/02

Quality Assessment Report:

DE/BVS/QAR06.0005/03 DE/BVS/QAR06.0005/06 DE/BVS/QAR06.0005/04

DE/BVS/QAR06.0005/05



Cei	4:5:		10	N I	-	
Cel	шш	$C_{i}$	œ	IV	()	983

IECEx TUR 11.0007X

Date of Issue:

2014-10-02

Issue No.: 2

Page 3 of 4

#### Schedule

### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The assembly FBPA3 is a new part of the equipment as well, with the same function and external electrical parameters like assembly FBPA1. Minor changes to assembly type FBIH1 and type FSPH1. Beside this the ex-marking has been consolidated to one line.
For further decription and parameter see the annexed file.

CONDITIONS OF CERTIFICATION: YES as shown below:

Unchanged, see DE/TUR/ExTR11.0007/01



Certificate No.:

IECEx TUR 11.0007X

Date of Issue:

2014-10-02

Issue No.: 2

Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

The assembly FBPA3 is a new part of the equipment as well, with the same function and external electrical parameters
like assembly FBPA1.Minor changes to assembly type FBIH1 and type FSPH1.Beside this the ex-marking has been
consolidated to one line.



# INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx TUR 11.0007X Issue No. 3 Certificate history:

Status: Current Page 1 of 4

4 15506

Date of Issue: 2015-10-09

Issue No. 2 (2014-10-02) Issue No. 1 (2014-02-06) Issue No. 0 (2011-06-30)

Issue No. 3 (2015-10-09)

Applicant: Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik

GmbH & Co. KG Dieselstraße 24 70839 Gerlingen

Germany

Electrical Apparatus: Transmitter Liquiline M type CM42 - \*I\* \*\* \* \*\*\*\*\*\*

Optional accessory:

Type of Protection: Intrinsic Safety - Ex i

Marking: Ex ib [ia Ga] IIC T6/T4 Gb

Approved for issue on behalf of the IECEx

Certification Body:

Position: Head of Certification Body

Signature:

(for printed version)

Date:

2015-10-09

Dipl.-Ing. Klauspeter Graffi

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TUV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Cologne Germany





Certificate No: IECEx TUR 11.0007X Issue No: 3

Date of Issue: 2015-10-09 Page 2 of 4

Manufacturer: Endress + Hauser Conducta Gesellschaft für Mess- und Regeltechnik GmbH & Co. KG

Dieselstraße 24 70839 Gerlingen **Germany** 

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-11: 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

## **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/TUR/ExTR11.0007/00 DE/TUR/ExTR11.0007/01 DE/TUR/ExTR11.0007/02

DE/TUR/ExTR11.0007/03

Quality Assessment Report:

DE/BVS/QAR06.0005/03 DE/BVS/QAR06.0005/04 DE/BVS/QAR06.0005/05

DE/BVS/QAR06.0005/06



Certificate No:	IECEx TUR 11.0007X	Issue No: 3
Certificate No:	IECEX TUR 11.0007X	issue ino:

Date of Issue: 2015-10-09 Page 3 of 4

Schedule

**EQUIPMENT:** 

Equipment and systems covered by this certificate are as follows:

Transmitter Liquiline M, Type: CM42-\*I\* \*\* \* \*\*\*\*\*

CONDITIONS OF CERTIFICATION: YES as shown below:

Unchanged



Certificate No: IECEx TUR 11.0007X Issue No: 3

Date of Issue: 2015-10-09 Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Subject of this supplement issue the certificate without an annex to IEC 60079-26 Ed.3.0, because the transmitter is an equipment with a single standardized Types of Protection (here Ex "ia") and these equipment are not in scope of IEC 60079-26 Ed.3.0 anymore. Beside this, minor hardware changes which do not effect the type of protection have been done to the construction of the transmitter as well as editorial changes because of a new document structure.

### Annex:

DE-IECEx\_TUR\_11.0007X\_03\_Attachment\_2015-10-09.pdf



## Attachment to Certificate IECEx TUR 11.0007/03 X Revison 03

#### Attachment to to Certificate IECEx TUR 11.0007/03 X

Device: Transmitter Liquiline M Typ CM42 - \*I\* \*\* \* \*\*\*\*\*\*

Manufacturer: Endress + Hauser Conducta Gesellschaft

für Mess- und Regeltechnik mbH + Co.KG

Address: Dieselstraße 24, 70839 Gerlingen

Germany

### **General product information:**

1. Transmitter Liquiline M type CM42-\*I\* \*\* \* \*\*\*\*\*

Product Type Code: Liquiline M CM42 -

Administrative Data (letters A to Z) Administrative Data (Numbers 0, 1 or 2) Housing / Enclosure Material 0 = Plastic Material (PC) 1 = Stainless Steel 1.4301 Power/Communications Circuit 0 = 4...20 mA, HART-Communication 1 = 2x4...20 mA, 1x HART- Communication 2 = Profibus PA (FBPA1) 3 = Foundation Fieldbus (FBPA1) 4 = 2x4...20 mA, SIL5 = Profibus PA (FBPA3) 6 = Foundation Fieldbus (FBPA3) Administrative Data (letters A to Z) G = ATEX(1)2GE = ATEX(1)2GI = IECEx (Ga)Gb Connecting Sensor Types: A = No Module

C = Conductivity, conductive measurement (FSLC1 module)

I = Conductivity, inductive measurement (FSLI1 module)

P = pH / mV + Temperature (FSPH1 module)

L = Digital Sensor Inductive Conductivity, MEMOSENS (FSDG1 module)

M = Digital Sensor, MEMOSENS (FSDG1 module)

N = Digital Sensor ISFET, MEMOSENS (FSDG1 module)

O = Digital Sensor Dissolved Oxygen, MEMOSENS (FSDG1 module)

K = Digital Sensor Conductive Conductivity, MEMOSENS (FSDG1) TÜV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Köln

Tel. +49 (0) 221 806-0 Fax. + 49 (0) 221 806 114



## Attachment to Certificate IECEx TUR 11.0007/03 X Revison 03

### **Technical data**

### 2. Description of change

Subject of this supplement issue the certificate without an annex to IEC 60079-26 Ed.3.0, because the transmitter is an equipment with a single standardized Types of Protection (here Ex "ia") and these equipment are not in scope of IEC 60079-26 Ed.3.0 anymore.

Beside this, minor hardware changes which do not effect the type of protection have been done to the construction of the transmitter as well as editorial changes because of a new document structure.

### 3. Ratings

## 3.1 Electrical ratings

Unchanged

### 3.2 Thermal ratings

Unchanged



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEX TUR 11.0007X

Issue No: 4

Certificate history:

Status:

Current

Page 1 of 4

Issue No. 4 (2016-12-14) Issue No. 3 (2015-10-09)

Date of Issue: 2016-12-14

Issue No. 2 (2014-10-02) Issue No. 1 (2014-02-06) Issue No. 0 (2011-06-30)

Applicant:

Endress+Hauser Conducta GmbH+Co. KG

Dieselstraße 24 70839 Gerlingen

Germany

Equipment:

Transmitter Liquiline M type CM42-\*!\* \*\* \* \*\*\*\*\*\* or type OCM42-\*!\* \*\* \* \*\*\*\*\*\*

Optional accessory:

Type of Protection:

Intrinsic Safety - Ex I

Marking:

Ex ib [ia Ga] IIC T6/T4 Gb

Approved for issue on behalf of the IECEx

Certification Body:

Dipl.-Ing. Andreas Maschke

Position:

Deputy Head of Certification Body

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TUV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Cologne Germany





Certificate No:

IECEx TUR 11.0007X

Issue No: 4

Date of Issue:

2016-12-14

Page 2 of 4

Manufacturer:

Endress+Hauser Conducta GmbH+Co. KG

Dieselstraße 24 70839 Gerlingen **Germany** 

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-11: 2011

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

### Test Report:

DE/TUR/ExTR11.0007/04

Quality Assessment Report:

DE/BVS/QAR06.0005/07



Certificate No:

IECEx TUR 11.0007X

Issue No: 4

Date of Issue:

2016-12-14

Page 3 of 4

Schedule

**EQUIPMENT:** 

Equipment and systems covered by this certificate are as follows:

Subject and type

Transmitter Liquiline M, Type: CM42-\*|\* \*\* \* \*\*\*\*\*\* or OCM42-\*|\* \*\* \* \*\*\*\*\*\*

(For detailed type designation see attachment)

Technical data

Unchanged

CONDITIONS OF CERTIFICATION: YES as shown below:

Unchanged



Certificate No:

**IECEx TUR 11.0007X** 

Issue No: 4

Date of Issue:

2016-12-14

Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

1. The Power/ Communications Circuit designator will be extended by the options 7 and 8. The hardware is identical to the Power/ Communication options 0 and 1, however HART-Communication is disabled by firmware settings.

The options use the same communication assembly FBIH1:

0 = 4...20mA, HART-Communication

7 = 4...20mA

1 = 2x4...20mA, HART-Communication

8 = 2x4...20mA

- 2. The alternative product designation root OCM42 will be introduced. No changes in HW or SW compared to CM42.
- 3. Additional sensor type designation "S"
  The range of MEMOSENS sensors will be extended to measure dissolved oxygen (DO) using optical sensors. The CM42 interface remains the module FSDG1. No changes in hardware. The optical DO interface is denoted with "S" in the product order code:
  S = Digital Sensor Dissolved Oxygen, Optical, MEMOSENS (FSDG1)
- 4. Changes with already have been documented in notification of change 557 / Ex 7459.04 / 13.

### Annex:

IECEx TUR 11.0007X\_N4\_attachment.pdf



## Attachment to Certificate IECEx TUR 11.0007X Revison 4



Equipment: Transmitter Liquiline M type CM42-\*|\* \*\* \* \*\*\*\*\* or type OCM42-\*|\* \*\* \* \*\*\*\*\*


Manufacturer: Endress+Hauser Conducta GmbH+Co. KG

Address: Dieselstraße 24,

70839 Gerlingen

Germany

### General product information:





## Attachment to Certificate IECEx TUR 11.0007X Revison 4



### Details of change:

1. The Power/ Communications Circuit designator will be extended by the options 7 and 8. The hardware is identical to the Power/ Communication options 0 and 1, however HART-Communication is disabled by firmware settings.

The options use the same communication assembly FBIH1:

0 = 420mA, HART-Communication	7 = 420mA
1 = 2x420mA, HART-Communication	8 = 2x420mA

- 2. The alternative product designation root OCM42 will be introduced. No changes in HW or SW compared to CM42.
- 3. Additional sensor type designation "S" The range of MEMOSENS sensors will be extended to measure dissolved oxygen (DO) using optical sensors. The CM42 interface remains the module FSDG1. No changes in hardware. The optical DO interface is denoted with "S" in the product order code: S = Digital Sensor Dissolved Oxygen, Optical, MEMOSENS (FSDG1)
- Changes with already have been documented in notification of change 557 / Ex 7459.04 / 13.

_					
Tec	lha i	210	201		+
1 625.4			· (3)	ua	ILCI.

Unchanged

### **Specific Conditions of Use:**

Unchanged