



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

I. PROWIRL Vortex Flowmeter

PROWIRL 7abcc-defghiklmnop. Vortex Flowmeter.

IS/I,II,III/1/ABCDEFGH/T* – FES0068, FES0068-0001, FES0068-0003, Entity; FES0068-0002, FISCO; Type 4X

I/O/AEx ia/IIC/T* – FES0068, FES0068-0001, FES0068-0003, Entity; FES0068-0002, FISCO; Type 4X

NI/II/2/ABCD/T* – FES0068-0004; Type 4X

NI/II/2/IIC/T* – FES0068-0004; Type 4X

DIP/II,III/1/EFH/T*; Type 4X

Entity Parameters:

I/O option A (4-20mA, HART Pulse, Entity) or W (4-20mA, HART, Entity):

Terminals 1 and 2: $V_{max} = 30\text{ V}$, $I_{max} = 300\text{ mA}$, $P_i = 1\text{ W}$, $C_i = 5.3\text{ nF}$, $L_i = 0\text{ }\mu\text{H}$

Terminals 3 and 4: $V_{max} = 30\text{ V}$, $I_{max} = 300\text{ mA}$, $P_i = 1\text{ W}$, $C_i = 0\text{ nF}$, $L_i = 0\text{ }\mu\text{H}$

I/O Option H (Profibus PA, FISCO) or K (Foundation Fieldbus, FISCO):

$V_{max} = 17.5\text{ V}$, $I_{max} = 500\text{ mA}$, $P_i = 5.5\text{ W}$, $C_i = 5\text{ nF}$, $L_i = 10\text{ }\mu\text{H}$

I/O Option H (Profibus PA, Entity) or K (Foundation Fieldbus, Entity):

$V_{max} = 17.5\text{ V}$, $I_{max} = 500\text{ mA}$, $P_i = 5.5\text{ W}$, $C_i = 5\text{ nF}$, $L_i = 10\text{ }\mu\text{H}$

or

$V_{max} = 24\text{ V}$, $I_{max} = 250\text{ mA}$, $P_i = 1.2\text{ W}$, $C_i = 5\text{ nF}$, $L_i = 10\text{ }\mu\text{H}$

a = Type of electronic: 2 or 3.

b = Type of sensor: F, W or X.

cc = Size: any double number or letter.

d = Material: any single number or letter.

e = Process connection: any single number or letter.

f = Sensor: 0, 1, 2, 3, 4, 5, 6, 7, B, C, F, G, H, or X.
g = Sealing of sensor: any single number or letter.
h = Calibration: any single number or letter.
i = Certificates: any single number or letter.
k = Approvals: N.
l = Version: A, E, F, J, K or L.
m = Cable gland: any single number or letter.
n = Display: any single number or letter.
o = Software: any single number or letter.
p = I/O's: A, H, K, W or X.

Special conditions of use:

1. For installation instructions and the Temperature Class (*) which applies to specific models, ambient temperatures (T_a), and process medium temperatures (T_{med}), refer to Control Drawing FES0068.

II. PROWIRL Vortex Flowmeter

PROWIRL 7abcc-defghiklmnop

XP-AIS-DIP/I,II,III/1/ABCDEFG/T* – FES0077, FES0077-0001; Type 4X

XP-AIS/II/1/IIC/T* – FES0077, FES0077-0001; Type 4X

a = Type of electronic: 2 or 3.
b = Type of sensor: F, W or X.
cc = Size: any double number or letter.
d = Material: any single number or letter.
e = Process connection: any single number or letter.
f = Sensor: 0, 1, 2, 3, 4, 5, 6, 7, B, C, F, G, H, or X.
g = Sealing of sensor: any single number or letter.
h = Calibration: any single number or letter.
i = Certificates: any single number or letter.
k = Approvals: P.
l = Version: A, E, F, J, K or L.
m = Cable gland: B.
n = Display: any single number or letter.
o = Software: any single number or letter.
p = I/O's: A, H, K, W or X.

Special conditions of use:

1. For installation instructions and the Temperature Class (*) which applies to specific models, ambient temperatures (T_a), and process medium temperatures (T_{med}), refer to Control Drawing FES0077.

Equipment Ratings:

I. Compact and Remote Versions

Intrinsically Safe for use in Class I, II & III, Division 1, Groups A, B, C, D, E, F & G; Class I, Zone 0, AEx ia IIC in accordance with Entity requirements when installed per FM Control Drawings FES0068, FES0068-0001, FES0068-0003, FES0068-0004 or in accordance with FISCO requirements when installed per FM Control Drawing FES0068-0002; Nonincendive for use in Class I, Division 2, Groups A, B, C & D, and Class I, Zone 2, Group IIC; Dust-Ignitionproof for use in Class II & III Division 1, Groups E, F & G Hazardous (Classified) indoor/outdoor (Type 4X) Locations

II. Compact and Remote Versions

Explosionproof Apparatus with Intrinsically Safe electronic compartment for Class I, Division 1, Groups A, B, C & D, when installed per FM Control Drawings FES0077 and FES0077-0001; Dust-Ignitionproof for Class II & III, Division 1, Groups E, F & G Hazardous (Classified) indoor/outdoor (Type 4X & IP67) Locations

FM Approved for:

Endress + Hauser Flowtec AG
Kaegenstrasse 7
CH-4153 Reinach
Switzerland

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2010
Class 3611	2004
Class 3615	2006
Class 3810	2005
ANSI/ISA-82.02.01	2004
NEMA 250	1991

Original Project ID: 3015769

Approval Granted: December 5, 2002

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3017442	May 1, 2003		
3018695	November 24, 2003		
3020410	June 3, 2004		
100406	July 28, 2010		
100805	September 9, 2010		

FM Approvals LLC



J. E. Marquedant
Group Manager, Electrical




Date

Hazardous Locations

Class I Division 1 Groups ABCD or Class I Zone 1 Group IIC
Class II Division 1 Groups EFG
Class III

Remote version



Sensor:

PROWIRL 7** **_1**N****, PROWIRL 7** **_2**N****, PROWIRL 7** **_3**N****,
PROWIRL 7** **_4**N****, PROWIRL 7** **_6**N****, PROWIRL 7** **_7**N****,
PROWIRL 7** **_C**N****, PROWIRL 7** **_F**N****, PROWIRL 7** **_H**N****:

Max. medium temperature						
	T6 2)	T5 2)	T4	T3	T2	T1
Ta = 104°F	176°F	203°F	266°F	374°F	554°F	824°F
Ta = 140°F	---	203°F	266°F	374°F	554°F	824°F
Ta = 185°F	---	---	266°F	374°F	554°F	824°F

PROWIRL 7** **_0**P****, PROWIRL 7** **_5**P****,
PROWIRL 7** **_B**P****, PROWIRL 7** **_G**P****:


Max. medium temperature					
	T6 2)	T5 2)	T4	T3	T2
Ta = 104°F	176°F	203°F	266°F	374°F	536°F
Ta = 140°F	---	203°F	266°F	374°F	536°F
Ta = 185°F	---	---	266°F	374°F	536°F

Transmitter:

PROWIRL 7** **_*****P****:

	T6 2)	T5 2)	T4 - T1
Ta =	104°F	140°F	140°F

Compact version



PROWIRL 7** **_1**N****, PROWIRL 7** **_2**N****, PROWIRL 7** **_3**N****,
PROWIRL 7** **_4**N****, PROWIRL 7** **_6**N****, PROWIRL 7** **_7**N****,
PROWIRL 7** **_C**N****, PROWIRL 7** **_F**N****, PROWIRL 7** **_H**N****:

Max. medium temperature						
	T6 2)	T5 2)	T4	T3	T2	T1
Ta = 104°F	176°F	203°F	266°F	374°F	554°F	824°F
Ta = 140°F	---	203°F	266°F	374°F	554°F	824°F

PROWIRL 7** **_0**P****, PROWIRL 7** **_5**P****, PROWIRL 7** **_B**P****,
PROWIRL 7** **_G**P****:

Max. medium temperature					
	T6 2)	T5 2)	T4	T3	T2
Ta = 104°F	176°F	203°F	266°F	374°F	536°F
Ta = 140°F	---	203°F	266°F	374°F	536°F

Notes:

- Assignment of Control Drawings:

Drawing-No.	Model Codes:
FES0077 A	Prowirl 7** **_*****P****
FES0077-0001 A	Prowirl 7** **_*****P****A, Prowirl 7** **_*****P****W, Prowirl 7** **_*****P****H, Prowirl 7** **_*****P****K

- Max. cable length for intrinsically safe installation 100m for using cable parameters
 $L_{\text{Cable}} = 1\text{mH/km} / 0.3\mu\text{H/ft}$ and $C_{\text{Cable}} = 1\mu\text{F/km} / 300\mu\text{F/ft}$
- Temperature class T6 and T5 is not allowed for versions of Profibus PA and Fieldbus Foundation
(not for PROWIRL 7** **_*****P****H and PROWIRL 7** **_*****P****K)
- Caution: Use supply wires suitable for 50°F above maximum ambient temperature
- Caution: Surface temperature of transmitter enclosure can exceed 158°F depending on ambient temperature or medium temperature
Dust tight seals must be used at conduit entries for Class II and III installation
- The Prowirl 72/73 is Factory Sealed. This means that a conduit seal is not required within 18 inches (450mm) of the enclosure.
- The Prowirl 72/73 is a Dual Seal Device in accordance to ANSI/ISA-12.27.01-2003
- Prowirl 72 and Prowirl 73 transmitter is intended for installation to Service Interface FXA 193 when using the PROLINE EX-ZWEILEITER-KABEL (blue cable)
- Sensor of remote version and interior of measuring tube of remote and compact versions are permissible for use in Zone 0

Änderungen:

A	10.12.03 / Bn	F
B		G
C		H
D		J
E		K

Alle gesetzlichen Urheberrechte vorbehalten.
Diese Zeichnung darf ohne unsere
Genehmigung weder vervielfältigt werden
noch dritten Personen und Konkurrenzfirmen
zugänglich gemacht werden.

Mat. Nr.: 71040753

Ersatz für:

Ersteller: FES/Bn

File: M:\ZEICHNUNG\031210c.doc ID 1112

FM CONTROL DRAWING
PROWIRL 72, PROWIRL 73 (XP-version)
Compact Version, Remote version

Masstab

Gezeichnet	08.09.03	Bn
Geprüft		
Ex-geprüft	10.12.03	Bn
Gesehen		



Flowtec AG, Kaegenstrasse 7, CH-4153 Reinach BL1, Postfach


FES0077 A

Hazardous Locations

Class I Division 1 Groups ABCD or Class I Zone 1 Group IIC

Class II Division 1 Groups EFG

Class III



Prowirl 7* **_*****P****A

Division 1 and Division 2 installation

1) Terminal 1 and 2

Supply voltage: $U \leq 36 \text{ Vdc}$

$U_{\max} = 250 \text{ Vdc}$

Signal current: $4 \dots 20 \text{ mA}$ (max. 25 mA)


Prowirl 7* **_*****P****H and Prowirl 7* **_*****P****K

Division 1 and Division 2 installation

2) Terminal 1 and 2

Supply voltage: $U \leq 36 \text{ Vdc}$

$U_{\max} = 250 \text{ Vdc}$



Prowirl 7* **_*****P****W

Division 1 and Division 2 installation

3) Terminal 1 and 2

Supply voltage: $U \leq 36 \text{ Vdc}$

$U_{\max} = 250 \text{ Vdc}$

Signal current: $4 \dots 20 \text{ mA}$ (max. 25 mA)

4) Terminal 3 and 4

Pulse Output: $U \leq 30 \text{ V}$

$U_{\max} = 250 \text{ Vdc}$

Signal current: $\leq 30 \text{ mA}$

Class II, III installation

5) Transmitter circuit wiring in conduit in accordance with the NEC ANSI/NFPA 70

Note:

- 6) Installation of transmitter circuit wiring according to National Electrical Code using threaded conduit.
- 7) **WARNING** Terminal compartment:
KEEP COVER TIGHT WHEN CIRCUITS ARE ALIVE
OR THE AREA IS KNOWN TO BE HAZARDOUS
- 8) Control room equipment may not use or generate over 250Vrms.
- 9) **WARNING:** SUBSTITUTION OF COMPONENTS MAY IMPAIR
INTRINSIC SAFETY.

Änderungen:	A	10.12.03 / Bn	F		Alle gesetzlichen Urheberrechte vorbehalten. Diese Zeichnung darf ohne unsere Genehmigung weder vervielfältigt werden noch dritten Personen und Konkurrenzfirmen zugänglich gemacht werden.	Mat. Nr.: 71040753 Ersatz für: Ersteller: FES/Bn File: M:\ZEICHNG\...\031210c.doc ID 1112			
	B		G						
	C		H						
	D		J						
	E		K						
FM CONTROL DRAWING PROWIRL 72, PROWIRL 73 (XP-version)						Massstab	Gezeichnet	08.09.03	Bn
							Geprüft		
							Ex-geprüft	10.12.03	Bn
							Gesehen		
 Flowtec AG, Kaegenstrasse 7, CH-4153 Reinach BL1, Postfach						FES0077-0001 A			