



Certificate of Compliance

Certificate: 1575301

Master Contract: 205557

Project: 1733901

Date Issued: 2005/12/07

Issued to: Endress + Hauser Conducta GmbH & Co

Dieselstrasse 24
Gerlingen, 70839
Germany
Attention: Dr. Uwe Tenner

The products listed below are eligible to bear the CSA Mark shown



Issued by: Glenn Black

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non -
Incendive Systems - For Hazardous Locations

Ex [ia] IIC:

Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III; Type 4:

MYCOM S, type CPM153-S pH/ORP transmitter or type CLM153-S conductivity transmitter, rated 120/240 Vac, 50/60 Hz, 18 VA or 24Vac/Vdc, 12VA; suitable for installation in Class I, Div. 2, Groups A,B,C,D or Class II, Div.1, Groups E,F,G, Class III; temperature code T4. May be used with type CPG30-S or CPG300-S Controllers. Provides intrinsically safe circuits and contains non-incendive field wiring circuits when installed per connection drawing 136783.



Certificate: 1575301

Master Contract: 205557

Project: 1733901

Date Issued: 2005/12/07

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations

CAN/CSA C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CAN/CSA C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

CSA Std C22.2 No. 213-M1987 - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

CAN/CSA-E60079-11:02 - Electrical apparatus for explosive gas atmospheres, Part 11: Intrinsic safety "i"



Supplement to Certificate of Compliance

Certificate: 1575301

Master Contract: 205557

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1733901	2005/12/07	Addition of MKDI Modules and MEMOSENS Sensors


HAZARDOUS LOCATION

Class I, Division 1, Groups A,B,C,D.
Class I, Zone 1, Groups IIC


HAZARDOUS LOCATION

Class I, Division 2, Groups A,B,C,D.
Class II, Division 1, Groups E,F,G, Class III
Class I, Zone 2, Groups IIC T4
Ta = -10°C..+50°C

NON HAZARDOUS LOCATION




CLS12/13
CLS15
CLS16
CLS21
or
other
simple apparatus
approved
by CSA




CTSI
CPS11/12/13
CPS41/42
CPS71/72
CPF81-...A.
CPF81-...C.
CPF82-...A.
or other simple
apparatus approved
by CSA

max. cable length 50m / 164 ft



CPS 401/441/471/491
(IsFET-pH-Sensor)




CPM153-S.....
CLM153-S.....


Input connection
details (see Note 4
and Details 2 and 3)

I/O connection
details (see sheets
2 and 3)


Sensor connection
details (Note 5)
CLM153-S




Sensor connection
CPM153-S1 (-S2)



Sensor connection
CPM153-S2 (-S4)




Detail 2)



Order code	Version
C.M153-S...1....	100 ... 230 VAC

Detail 3)



Order code	Version
C.M153-S...8....	24 AC/DC

NOTES

1. Install per the Canadian Electrical Code, Part I
2. Substitution of components may impair intrinsic safety and suitability for use in Class I, Div. 2 locations.
3. Control room equipment connected in the non-hazardous location must not use or generate voltages greater than 250Vrms
4. Supply wiring must be installed per Class I, Div. 2 and/or Class II/III, Div. 1 wiring methods, as applicable.
5. Sensor wiring is intrinsically safe for connection to specified sensors.
6. Refer to Sheet 2 and 3 for I/O connection wiring details.
7. When the C.M153 and CPG30/300 are installed in Class II and Class III, Division 1 hazardous locations, applicable Class II and III, Div. 1 wiring practices must be followed, except for intrinsically safe wiring to the sensors.






				Kantenverrundung R 0.2		USED FORMAT: 0414 - 3A	
		Datum	Name	Werkstoff:		Halbzeug:	
Bearb.		23.01.03	Si				
Geprüft		23.01.03	Ha	Oberfl & che:		Teilegewicht:	
Freimaßtoleranz:				DIN ISO 2768 - mittel		Maßstab: — Zng.-Nr. 136783	
ENDRESS+HAUSER CONDUCTA Dieselstraße 24 Postfach 10 01 54 D-70839 Gerlingen Telefon 07156/209-0 Telefax 07156/28158				Benennung:		Control drawing Mycom 153-S	
--	Approval	21.05.04	Ku	Ha			
Ind.	Änderung	Datum	Bearb.	Gepr.	Verwendung:	CXM153 CSA Page 1/ 3	

HAZARDOUS LOCATION



Class I, Division 2, Groups A,B,C,D.
Class II, Division 1, Groups E,F,G, Class III

NON HAZARDOUS LOCATION

I/O connection terminal layout



Digital Inputs
-connect only to switches
powered by terminals 85/86



CSA Certified IS barriers
with entity parameters
 $V_{oc} \leq 30V$, $I_{sc} \leq 100mA$

NOTES:


1. Install per the Canadian Electrical Code, Part I.
2. Substitution of components may impair intrinsic safety and suitability for use in Class I, Div. 2 locations.
3. Control room equipment connected in the non-hazardous location must not use or generate voltages greater than 250 Vrms.
4. Certified intrinsic safety barriers must be used to maintain IS outputs to sensors and nonincendive wiring (where noted). Each barrier circuit must use twisted, shielded pairs. Cable insulation and shielding must be maintained to within 10mm from terminal block connection.
5. Wiring to CPG30-S/CPG300-S and Digital Input switches is nonincendive for Class I, Div. 2 locations.
6. When the C.M153 and CPG30/300 are installed in Class II and Class III, Division 1 hazardous locations, applicable Class II and III, Div. 1 wiring practices must be followed, except for intrinsically safe wiring to the sensors.

				Kantenverrundung R 0.2		USED FORMAT: 0414 - 3A		
				Datum	Name	Werkstoff: Halbzeug:		
				Bearb.	23.01.03			Si
				Geprüft	23.01.03	Ha	Oberfläche: Teilegewicht:	
				Freimaßtoleranz: DIN ISO 2768 - mittel				
				ENDRESS+HAUSER CONDUCTA Dieselstraße 24 Postfach 10 01 54 D-70839 Gerlingen Telefon 07156/209-0 Telefax 07156/28158			Maßstab: Zng.-Nr. 136783	
				-- Approval 21.05.04 Ku Ha Ind. Änderung Datum Bearb. Gepr. Verwendung: CXM153 CSA			Benennung: Control drawing Mycom 153-S	
							Page 2 / 3	

HAZARDOUS LOCATION

Class I, Division 2, Groups A,B,C,D.
Class II, Division 1, Groups E,F,G, Class III

NON HAZARDOUS LOCATION



NOTES:

1. Install per the Canadian Electrical Code, Part I.
2. Substitution of components may impair intrinsic safety and suitability for use in Class I, Div. 2 locations.
3. Control room equipment connected in the non-hazardous location must not use or generate voltages greater than 250 Vrms.
4. Certified intrinsic safety barriers must be used to maintain IS outputs to sensors and nonincendive wiring (where noted). Each barrier circuit must use twisted, shielded pairs. Cable insulation and shielding must be maintained to within 10mm from terminal block connection.
5. Wiring to MYCOM CPM153-S, Level Switches and external proximity switches is nonincendive for Class I, Div. 2 locations.
6. When the C.M153 and CPG30/300 are installed in Class II and Class III, Division 1 hazardous locations, applicable Class II and III, Div. 1 wiring practices must be followed, except for intrinsically safe wiring to the sensors.

				Kantenverrundung R 0.2			
				Datum		Name	
				Bearb.		Halbzeug:	
				Geprüft		Oberfläche:	
				Freimastoleranz:		Teilgewicht:	
				DIN ISO 2768 - mittel		Maßstab:	
				Zng.-Nr.		Benennung:	
				136783		Control drawing Mycom 153-S	
				Verwendung:		Blatt 3 / 3	
				CXMI53 CSA			