

Certificate of Compliance

Certificate: 1583207

Master Contract: 151079

Project:

1583207

Date Issued: October 8, 2004

Issued to:

Endress + Hauser GmbH + Co. KG

P.O. Box 1261, Hauptstrasse 1

Maulburg, Baden Wurttemberg 79690

GERMANY

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Authorized by: O. Ewanchyna, P. Eng.

PRODUCTS

CLASS 2252 03 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Capactive Level Detector, 'Liquicap T' model FM121-XXXXXX, permanently connected, rated 10-30 Vdc, 0.7 W max.; Class II equipment, Pollution Degree 2, Installation Cat. II, IP66

NOTE: The X ... in the model designation refers to any combination of numeric characters not effecting electrical ratings.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-04

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

US Standard UL 61010-1, 2nd Edition

Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Supplement to Certificate of Compliance

Certificate:

1583207

Master Contract: 151079

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1583207	October 8, 2004	CSAc-us original Certification of 'Liquicap T' model FM121.