

Certificate of Compliance

Certificate: 1053889

Master Contract: 200600

Project: 1449136

Date Issued: June 26, 2003

Issued to: Endress & Hauser Wetzer GmbH.
Obere Wank 1
Nesselwang, D-87481
GERMANY
Attention: Mr. Michael Pfanzelt

The products listed below are eligible to bear the CSA Mark shown



Issued by:


Edward Foo, C.E.T.

Authorized by:


Nick Alfano
Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class II, Groups E, F and G, Class III; Type 4X:

- Level Limit Switch for Solids, Types FTE31-abcd; rated as follows, FTE31-Abcd, 240 VAC, 4.5 VA, 50/60 Hz, FTE31-Bbcd, 120 VAC, 4.5 VA, 50/60 Hz, FTE31-Cbcd, 48 VAC, 4.5 VA, 50/60 Hz, FTE31-Dbcd, 24 VAC, 4.5 VA, 50/60 Hz, FTE31-Ebcd, 24 VDC, 66 mA; contacts rated 250 VAC, 10 A.



Certificate: 1053889
Project: 1449136

Master Contract: 200600
Date: June 26, 2003

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations
CAN/CSA C22.2 No. 94-M91 - Special Purpose Enclosures
CSA Std. C22.2 No. 142-M1987 - Process Control Equipment

MARKINGS

Refer to Descriptive Documents Package for Label Drawing(s).



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1053889

Master Contract: 200600

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1449136	June 26, 2003	Supersedes Report 2500008324. Update to cover revised drawings and minor alterative constructions per letter of May 23, 2003.
1053889	Jan 24/00	Original Certification. Superseded by report 1449136. ORIGINALLY ISSUED AS 2500008324.