

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

TMT 165 ab-c. Temperature Transmitter.

XP/II/1/ABCD; DIP/II,III/1/EFG; IS/I,II,III/1/ABCDEFG - 14 09 00 111/1; Entity; NI/II/2/ABCD

Entity Parameters: Vmax=24 V, Imax=250 mA, Ci=5nF, Li=8uH

a=Local indicator 0 or 1.

b=Mounting bracket 0, 1 or 2.

c=Electrical connections 0, A or B (A or B for intrinsically safe version only).

Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups A, B, C and D; Dust Ignition Proof for use in Class II and III, Division 1, Groups E, F and G; Intrinsically Safe for use in Class I, II and III, Division 1, Groups A, B, C, D, E, F and G when installed in accordance with document number 14 09 00 111 Revision 1; Nonincendive for use in Class I, Division 2, Groups A, B, C and D Hazardous (Classified) Locations.

Approved for:

Endress + Hauser Wetzler GmbH + Co.KG
Obere Wank 1
87484 Nesselwang, Germany


This certifies that the equipment described has been found to comply with the following Factory Mutual Research Approval Standards and other documents:

Class 3600	1989
Class 3610	1988
Class 3611	1986
Class 3615	1989
Class 3810	1989

Original Approval Job Identification: 3009468 Approval Granted: December 15, 2000

Subsequent Revision Reports / Date Approval Amended

Factory Mutual Research Corporation



Robert L. Martell, Assistant Vice President
Approvals Division

12-15-00
Date