

















Manufacturer Information

for users regarding software updates (following the NAMUR recommendation 53)

Field Xpert - SFX100

1	Type of Product			
	 □ Field device / signal processing device ☑ Software application for display and monitoring / asset management / handheld terminal etc. □ Modem / interface 			
	Manufacturer	: Endress+Hauser Process Solutions AG		
	Product	: Field Xpert		
	Type and order code	: SFX100		
2	Software			
	Previous software version	: 1.5.0 Device Xpert HART		
	New software version	: 1.6.0 Device Xpert HART		
	How can the previous software version number be identified?	Checking the version by using the menu item selection, "About Device Xpert" on the Device Xpert software.		
	Description of the modification in comparison with the predecessor version	: Please refer to the attached document for further details of the features. This Software is available as Download on product website(www.products.endress.com/sfx100) and will be available on the Product CD of Field Xpert 1.02.00		
3	Compatibility			
	Is the new product software compatible with the previous version, installed device driver components and operating tools?			
	YesNo, reason:			

Is a software update generally recommended?

In general Device Xpert 1.6.0 is recommended for the following reasons

- Device Report Enhancement.
- Reported scanning problems with MacTek Viator Bluetooth modem fixed.
- Generic DD Support.
- Increase HART scan range to 63.





















Manufacturer Information

for users regarding software updates (following the NAMUR recommendation 53)

- Other minor bug fixes.
 - Long help text truncation fixed.
 - UDT support listed in DD library tree

		 Fix small spelling n 	nistake in English help file.			
		. 0	nessage when Device Report c	completes.		
	☐ No, reason					
		•				
4	Instruction manual					
	Is a new instruction manual necessary due to the software modification?					
	□ No					
	The manual tha	The manual that corresponds to the new software version is:				
	Product	Communication options	Manual type	Document identifier		
	SFX100	HART	BA	BA060S/04/en/09.09		
		iction manuals can be dowr .endress.com/sfx100	nloaded from the Internet:			
	www.products	.c.iui coo.com/ oix i oo				

5 Price

Change in price of device in comparison with the predecessor version?

☐ Yes, new list price and update costs (without installation) are enclosured

⊠ No

