

N

σ

C

Installation Notes TMT121, TMT127, TMT128



 $\boldsymbol{\varpi}$

S

- FM approved apparatus must be installed in accordance with manufacturer's instructions.
- Use supply wires suitable for 5°C above surroundings.
- Stating that only simple apparatus should be terminated to the sensor connection.
 Simple apparatus is defined as a device that will neither generate nor store more than 1.2V, 0.1A, 0.25mW or 20µI. Examples are Thermocouples or RTDs.

INTRINSICALLY SAFE

ω

IS / Class I / Div. 1 / Groups ABCD

- Installation should be in accordance with ANSI/ISA RP 12.6.01 "Installation of Intrinsically safe systems for Hazardous (classified) locations" and the National Electrical Code (ANSI/NFPA 70).
- FM Approved Associated Apparatus must meet the following parameters:

 $Uo \leq Ui \qquad Io \leq Ii \qquad Po \leq Pi \qquad Ca \geq Ci + Ccable \qquad La \geq Li + Lcable$ Transmitter entity parameters are as follows:

 $\begin{array}{lll} \mbox{Ui or Vmax} & \leq 30 \mbox{ V DC} & \mbox{Ci} = 0 \\ \mbox{Ii or Imax} & \leq 100 \mbox{ mA} & \mbox{Li} = 0 \\ \mbox{Pi} & < 750 \mbox{ mW} \end{array}$

- The configuration of the transmitter TMT121 is only permitted in non-hazardous locations.
- The voltage of the "tools" used for configuration should not exceed Um = 30 V. This can be achieved e.g. by a battery powered laptop. An approved adapter with barrier (e.g. TMT181A) has to be used for configuration using a PC with mains connection (Um < 253V).
- Warning: Substitution of components may impair intrinsic safety.

NONINCENDIVE

NI / Class I / Div. 2 / Groups ABCD

- Intrinsic safety barrier is not required. Vmax ≤ 35 V DC.
- Warning: Do not disconnect equipment unless power has been switched off or the area is known to be non-hazardous.
- Transmitter provides nonincendive field wiring to the Thermocouple/RTD
- Nonincendive field wiring installation

The Nonincendive Field Wiring Circuit Concept allows interconnection of Nonincendive Field Wiring Apparatus with Associated Nonincendive Field Wiring Apparatus or Associated Intrinsically Safe Apparatus or Associated Apparatus not specifically examined in combination as a system using any of the wiring methods permitted for unclassified locations, when $Voc \le Vmax$, $Ca \ge Ci + Ccable$, $La \ge Li + Lcable$.

Transmitter Nonincendive Field Wiring parameters are as follows:

 $Ui \ or \ Vmax \ \le 30 \ V \ DC$

Ci = 0

Li = 0

Ii or Imax = see following note below

For these current controlled circuits, the parameter Imax is not required and need not to be aligned with parameter Isc and It of the Associated Nonincendive Field Wiring Apparatus or Associated Apparatus.

Functional ratings

These ratings do not supersede Hazardous Location values

Unom \leq 35 V DC Inom \leq 4 to 20 mA

7		Approved	Date (yyyy-mm-dd)	Drawing No.	Dwg.rev.	Revision no.	Revision date (yyyy-mm-dd)	Name	Material 7	1342008	
		Pfanzelt	2001-12-04	14 10 01 111	Α	W15105	2015-01-08	MP		.0.2000	Endress+Hauser ムゴリ
	Volume (mm³)	Designed	Date (yyyy-mm-dd)	Unit	Scale	Title					
		Pfanzelt	2001-12-04	iTEMP TMT121(7)(8)	1:1	CONTR	OL DRAWING	3 FM	Serie	es :	
	Refer to protection notice	Edge of working parts	Geometrical tolerancing	Part No.	Format	ZD00015R	2/09/EN/13.16		Objekt version	Sheet	Endress + Hauser Wetzer
	ISO 16016	ISO 13715	ISO 2768-mH-E	-	A4						GmbH+Co. KG Nesselwang / Germany

ω

4

O